

# Worldwide Pollution Control Association

WPCA-Duke Energy  
FGD Wastewater  
Treatment Seminar  
March 7, 2013

All presentations posted on this website are copyrighted by the Worldwide Pollution Control Association (WPCA). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or to obtain copies for any other purposes than the training of attendees to WPCA Conferences is expressly prohibited, unless approved in writing by the WPCA or the original presenter. The WPCA does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of the WPCA.



Visit our website at [www.wpca.info](http://www.wpca.info)



# EPA's Proposed 316(b) Rule for Existing Facilities

WPCA/Duke Energy  
FGD Wastewater Treatment Seminar  
March 7, 2013

Presented by Nathan Craig, Environmental Specialist

# Introduction

## Clean Water Act (CWA) §316(b)

- Requires that the location, design, construction and capacity of cooling water intake structures reflect the Best Technology Available (BTA) for minimizing adverse environmental impact
- The rule currently being developed applies to existing facilities
- 316(b) Rule for New Facilities was effective January 17, 2002

## EPA Actions to Date

- Proposed Rule for Existing Facilities published on April 20, 2011
- Notice of data availability (NODA) Related to Impingement Mortality Control Requirements, published on June 11, 2012
- NODA Related to EPA's Stated Preference Survey published on June 12, 2012

# Proposed Rule Highlights

- EPA proposed 4 options
  - Option 1 (EPA preferred)
    - Entrainment: Standards determined on a site-by-site basis by appropriate state agency
    - Impingement: Mortality standard (12% annual and 31% monthly) or reduce intake velocity to <math><0.5</math> fps
    - Modify traveling screens or other active screens to be “fish friendly”

# Proposed Rule Highlights

- Option 1 (continued)
  - Operate and maintain intake with less than 15% blockage
  - Ensure intake does not lead to entrapment of fish
  - For water withdraws from ocean or tidal waters, achieve impingement mortality reductions of shellfish comparable to barrier nets
  - Several evaluations / studies / information submittals required

# Proposed Rule Highlights

- Requirements for New Units
  - Proposal includes special requirements for “new units” (defined to exclude replacement or repowered units), modeled on Phase II rule
  - New units must have flows consistent with closed-cycle cooling (CCC) or demonstrate entrainment mortality reductions equivalent to 90% or greater of reduction that could be achieved by CCC, and meet 0.5 fps through-screen velocity standard

# Proposed Rule Highlights

## Compliance Schedule

- Impingement: Within 8 years of the effective date of the rule
- Entrainment: To be determined by the NPDES Permit Writer (some entrainment studies not due until 5 years after the effective date of the rule)

# NODA on Impingement Mortality

- Alternatives / Clarifications presented:
  - Site Specific Approach for Reducing Impingement Mortality
  - Closed-Cycle Recirculating Systems
  - Measurement of Intake Velocity
  - Impingement Mortality Limitations
  - Credit for Existing or Newly Installed Technologies
  - Facilities With Low Impingement Rates
  - Species of Concern

# NODA on Stated Preference Survey

- Results range widely among the regional studies, e.g., from \$0.75 per percentage improvement in SE to \$2.52 in Pacific
- EPA notes that conclusion on BTA for entrainment is unaffected by the results

# Regulatory Update

## Impingement Compliance Alternatives under Consideration as of January 2013

- Direct biological monitoring with traveling screens with modifications to reduce risk of non-compliance
- Achieving a 0.5 fps through screen velocity or less with modifications to reduce risk of non-compliance
- **New:** Streamlined (pre-approved) approach based on modified traveling screens
- **New:** Use of “defined” technology
- **New:** Site-specific approach (may be limited to facilities that cannot comply with any other option)
- **New:** Exemption for low levels of impingement

# Regulatory Update

- EPA is working to provide an integrated schedule toward meeting the impingement and entrainment requirements
- On some issues such as the 0.5 through-screen velocity (e.g., where measurement is to be made) and entrapment, EPA may be less prescriptive
- Recalculating impingement mortality criteria

# Regulatory Update

- Stated Preference survey is not expected to be part of the final rule.
- More flexibility to the State, especially with respect to entrainment compliance
- Concern with Peer Review requirement
- Concern with the definition of closed-cycle cooling

# Regulatory Update

- Efforts to inform EPA on industry concerns are still ongoing
- Edison Electric Institute (EEI) recently provided EPA with a paper outlining key elements needed to produce a reasonable, workable final rule, including:
  - Abandoning the impingement mortality standard
  - Pre-Approving a Suite of Technologies
  - Allowing Comparable Alternative Technology
  - Allowing Site-Specific Review, Including Credit for Past Action and Relief for *De Minimis* Effects

# Regulatory Update

- Rule is expected to be finalized in **June 2013** with an effective date 90 days after publication in the Federal Register (**~October 2013**)
- If finalized as proposed, initial submittals for facilities with a DIF greater than 50 MGD due **~ April 2014**
- EPA on notice from the Riverkeeper that they will litigate

Questions???

# Steam Electric Effluent Guidelines

**WPCA/Duke Energy  
FGD Wastewater Treatment Seminar  
March 7, 2013**

Presented by Nathan Craig, Environmental Specialist

# What are Effluent Guidelines?

- Developed for a specific industrial category
- EPA selects a *model technology* for the industry and/or waste stream
- Establishes permit limits for applicable parameters based on the performance of the model technology
- Requirements are incorporated into National Pollutant Discharge Elimination System (NPDES) discharge permits

# What are Effluent Guidelines?

- Historically, for all ELG rules, EPA estimates pollutant removals (lbs/yr) for candidate technologies and then calculates individual pollutant “toxic weighted pounds equivalent” or TWPEs, by multiplying the lbs/yr by a toxic weighting factor (TWF)
- Example: 1 lb. Hg x 117.2 (TWF) = 117.2 TWPEs
- EPA evaluates technologies for cost effectiveness using cost per TWPE of pollutant removed

# STEAM ELECTRIC EFFLUENT GUIDELINES

- 40 CFR Part 423
- Promulgated in 1974, and amended 1977, 1978, 1980 and 1982
- Applicable to generation of electricity for distribution and sale which results primarily from a process utilizing fossil-type fuel (coal, oil, or gas) or nuclear fuel in conjunction with a thermal cycle employing the steam water system

# STEAM ELECTRIC EFFLUENT GUIDELINES

- **Last Revised in 1982**
- **Fly Ash Transport Water:** No Best Available Technology (BAT) limits with the exception of no discharge of PCBs. Maintained Best Practicable Control Technology (BPT) limits
- Established New Source Performance Standards (NSPS) for no discharge of pollutants from fly ash transport water
- **Bottom Ash Transport Water:** No BAT limits with the exception of no discharge of PCBs. Maintained BPT limits
- Reserved BPT and BAT for several other waste streams, including FGD wastewater until future rule-making

# EPA Plans for Revision

- Limits are expected to be revised/developed for the following waste streams:
  - FGD Wastewater
  - Fly Ash Transport Water
  - Bottom Ash Transport Water
  - Leachate from CCR Landfills / Ponds
  - Gasification Wastewater (IGCC)

# EPA Plans for Revision

For FGD wastewater, EPA is considering:

- No change

Or setting limits based on the performance of:

- Chemical precipitation
- Chemical precipitation plus biological
- Chemical precipitation with vapor-compression evaporation

# EPA Plans for Revision

- Draft NPDES Permit for PSNH Merrimack Station (Fall 2011)
- Region 1 proposed internal BAT limits on the FGD wastewater based on the performance of a physical/chemical plus bioreactor treatment system

# EPA Plans for Revision

Internal Limits on FGD Wastewater Proposed for PSNH Merrimack Station based on Analysis by EPA Headquarters

Compound/Units	Maximum Daily Limit	Monthly Average Limit
Arsenic (ug/L)	15	8
Chromium (ug/L)	10	Report
Copper (ug/L)	16	8
Selenium (ug/L)	19	10
Mercury (ug/L)	55	22
Zinc (ug/L)	15	12

# EPA Plans for Revision

For fly ash transport water, EPA is considering:

- No discharge of pollutants in fly ash transport water (based on conversion to dry fly ash transport)

or

- No change

# EPA Plans for Revision

For bottom ash transport water, EPA is considering:

- No discharge of pollutants in bottom ash transport water based on either complete recycle of transport water or conversion to dry bottom ash handling

or

- No change

# EPA Plans for Revision

For leachate from landfills / ponds containing CCRs, EPA is considering:

- No change

Or setting limits based on the performance of:

- Chemical precipitation
- Chemical precipitation plus biological

# EPA Plans for Revision

For Gasification Wastewater, EPA is considering:

- No change

Or setting limits based on the performance of:

- Vapor-compression evaporation
- Vapor-compression evaporation plus cyanide destruction

# EPA Plans for Revision

## Other issues

- Metal Cleaning, non-chemical and chemical, Wastewater
- Mercury Control System Wastewater
- Best Management Practices (coal pile runoff, etc.)

# EPA Plans for Revision

- January 14, 2013: EPA sent the proposed rule to OMB for interagency review.
- **April 19, 2013:** EPA to sign proposed rule according to stipulation in *Defenders of Wildlife v. Jackson*.
- Early May 2013: Proposed rule to be published in the Federal Register, starting a comment period.
- Early August 2013: Assuming a 90-day period, the comment period on the proposal ends.
- **May 22, 2014:** EPA to take final action on the rule.
- 2014-2018 (?): Rule implementation. Specifics of timing unknown at this time.

# EPA Plans for Revision

UWAG met with DOE on Feb. 13 and emphasized:

- Based on preliminary work, FGD wastewater treatment by ZLD or biological treatment are not cost effective.
- Dry bottom ash handling is not cost effective.
- Industry needs a reasonable compliance period (8-10 yrs.) if forced to retrofit FGD WWT and dry bottom ash and fly ash handling.
- Rule may require treatment of non-chemical metal cleaning wastes. That change will affect all types of facilities that wash metal process equipment with water and discharge the wastewater.

# Potential Impacts

- Installation of enhanced treatment of FGD Wastewater
- Limits at the internal outfall
- Possibly more rigor in the O&M of the FGD WWTS
- May need to install back-up equipment for critical shared components of the dry fly ash collection system
- Rerouting landfill / ash pond leachate to a treatment system

# Potential Impacts

- Reconfiguring the boiler for dry bottom ash handling or installing hydrobins
- Still need to meet water quality based effluent limits (WQBEL)
- Handling of other low volume waste streams
- Need for additional ash storage in landfills

# Questions & Thoughts?