

# Worldwide Pollution Control Association

Michigan Coal to Gas Seminar  
June 5-6, 2012

All presentations posted on this website are copyrighted by the Worldwide Pollution Control Association (WPCA). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or to obtain copies for any other purposes than the training of attendees to WPCA Conferences is expressly prohibited, unless approved in writing by the WPCA or the original presenter. The WPCA does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of the WPCA.



Visit our website at [www.wpca.info](http://www.wpca.info)

W  
P  
C  
A



# WPCA Natural Gas Conversion

**Danny Gelbar**

**Manager of Performance Design Engineering**

May 30, 2012

**ALSTOM**

# WPCA – Natural Gas Conversions of Coal Fired Boilers

---



## Items to be covered




- **Boiler Sizing**
- **Gas Firing Components**
- **Gas Firing – Emissions**
- **Converting Bituminous Coal Fired Boiler to Gas Firing**
- **Converting PRB Coal Fired Boiler to Gas Firing**
- **Pulverizer and Fan Systems**
- **Summary**

WPCA Gas Conversion- 5/23/12 - P 2




# Normal Boiler Sizing




- Boilers are normally designed for a specific fuel.



- Anytime a boiler has a change in fuel, there will be performance compromises.




# Coal Fired Boilers



# Gas Firing Components

- Flame Pattern of Tangential Firing System




# Key Gas Design Criteria

---




- Gas Composition
  - Flame Propagation Velocity
  - Heating Value
  - Specific Gravity
- Adiabatic Flame Temperature
- Air Flow Requirements
- Nozzle Design

# Typical Gas Compartment



# Gas With Oil Gun



# Option for Skid-Mounted Gas & Ignitor Pipe Trains



WPCA Gas Conversion- 5/23/12 - P 10

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Option for Skid-Mounted Gas & Ignitor Pipe Trains



WPCA Gas Conversion- 5/23/12 - P 11

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Gas Firing - Emissions

NOx is formed by two primary mechanisms:

- Thermal fixation of atmospheric nitrogen--  
“thermal NOx”
- Fixation of nitrogen contained in the fuel--  
“fuel NOx” (no fuel NOx in gas)

# Parameters Influencing NOx Formation

---



- Boiler Operation
  - Unit Load
  - Tilt Position
  - Excess Air
  - WB Air Distribution
  - Fuel/Air Staging

# Parameters Influencing NOx Formation

---



- Boiler Design
  - Heat Release Rates
  - Air Inleakage
  - Firing Systems Design
  
- Fuel Properties
  - Fuel Nitrogen - Not applicable

- Current NOx Emissions Levels
- Required (or desired) NOx Emissions Levels
- Available Options
- Current Performance
- Performance Requirements

- **Reduce Burner Zone Stoichiometry**
  - Low NOx Burners
  - Lower Excess Air
  - Overfire Air (OFA)
  - Flue Gas Recirculation
- **Lower Flame Temperature**
  - Reduce Secondary Air Temperature
  - Reduce Load
  - Steam/H<sub>2</sub>O Injection
  - Flue Gas Recirculation
  - Spread Out the Heat Release
- **Flue Gas Recirculation**
  - Forced
  - Induced
  - Premixed
- **Reburn**
- **SNCR**

# Low NOx Gas Fired Experience List



Plant	Nominal MW's	FHI / PA	Pre NOx, lb/Mbtu	Post NOx, lb/Mbtu	Low NOx System
Plant A	160	1.58	0.22	0.08	SOFA & Hopper FGR
Plant B	400	2.74	0.33	0.18	CCOFA
Plant C	400	2.74	0.33	0.18	CCOFA
Plant D	225	1.57	0.23	N/A	CCOFA
Plant E	235	1.69	0.42	N/A	CCOFA
Plant F	375	2.66	0.59	N/A	CCOFA
Plant G	365	1.97	N/A	0.14	CCOFA
Plant H	370	2.20		0.15	CCOFA & Hopper FGR
Plant I	370	2.20		0.15	CCOFA & Hopper FGR
Plant J	370	2.20		0.11	CCOFA & Hopper FGR
Plant K	363	2.95		0.11	CCOFA
Plant L	363	2.95		0.10	CCOFA
Plant M	500	2.05	0.14	N/A	SOFA
Plant N	550	3.03	0.21	N/A	VCCOFA

N/A = Not Available


- CO
  - Incomplete Combustion
  - Time, Temperature, Turbulence

# Converting Bituminous Coal Fired Boiler to Gas Firing

# Bituminous Coal Fired Boiler #1



<b>PROPOSED FUEL</b>		VIRGINIA BITUMINOUS		ASH FUS. TEMP. F	2310	BTU PER LB AS FIRED	HARDGROVE GRIND
F.C.	47.84 %	VOL.	33.13 %	MOIST.	6.03 %	ASH	13.0 %
				SUL.			12,450
<b>FUEL BURNING EQUIPMENT</b>		CONT. NO.	16648-RB		8 - No. 613 Raymond Bowl Mills		
and Type TV Burners							
<b>FURNACE</b>	CONT. NO.	16648-PS		SQ. FT. H.S. PER FURN.	38,480		
				TYPE OF BOTTOM	Contant		
Plain Tube Furnace							
FRONT TO REAR	24'-11-3/4"		WIDTH	32'-7-1/4"		VOLUME	63,000
						CU. FT. GROSS	
<b>BOILER</b>	CONT. NO.	16648-BR		NO.	2		SQ. FT. H.S.EA.
					-		
					<b>PRESSURE</b>		
					DESIGN		OPERATING
DESIGNATION				MFR.	C-E		
32'-7-1/4" 123-3 R 54-60					1450		1295 at S.O.
24'-11-3/4" 94-3							
				STEAM WASHER	Bubble Type		
				BOILER NUMBER	1 and 2		
<b>SUPERHEATER</b>	CONT. NO.	16648-SH		TYPE	Elesco 2-Stage		
CONTROL RANGE	490,000 to 780,000			SQ. FT. H.S.	32,422		
by burner tilt & desuperheaters					FOR SUPHT'R. Spray Type		
<b>REHEATER</b>	TYPE	Interstage		SQ. FT. H.S.	10,522		
					FOR REHEATER Spray Type		
<b>ECONOMIZER</b>	CONT. NO.	16648-CONS		NO.	2		
TYPE	CF-S 10H x 45W x 33'-6" Split			SQ. FT. H.S.EA.	15,795		
<b>AIR HEATER</b>	CONT. NO.	16648-CAHL		NO.	4		
TYPE	32 V 62			SQ. FT. H.S.EA.	90,800		
<b>MISCELLANEOUS DATA</b>		Contract included partial steel, casing, setting, insulation, ductwork.					
<b>EXPECTED PERFORMANCE</b>							
LB STEAM PER HR-ACTUAL	Primary Reheat	490,000	640,000	*750,000	**780,000	*Guaranteed (Max. Cont.) **12 Hr. Peak	
	Econ. Boiler	424,000	553,000	645,000	670,000		
FEEDWATER TEMP. TO		408	432	447		<b>REHEATER DATA</b> 645,000 lb steam/hr. Enter Temp. 690 F * Press. 431 PSI Leav. * 405 PSI	
		466	489	500			
STEAM TEMP. Fat S.O. & R.O		950	950	* 950			
HEAT RELEASE BTU/CU. FT./HR.		10,600	13,600	15,600			
TEMP. GAS FROM AIR HEATER		259	285	291			
TEMP. AIR FROM AIR HEATER		578	610	619			
OVERALL EFFICIENCY %		89.35	88.78	*88.66			



WPCA Gas Conversion- 5/23/12 - P 21

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Bituminous Coal Fired Boiler #1



		Original Design	Test Data Coal	Natural Gas	Natural Gas
Date			2/16/2011		
Gross Load	MW		110		
Load	%	104% MCR	106% MCR	106% MCR	106% MCR
Main Steam Flow	lb/hr	780,000	795,110	795,110	795,110
Reheater Steam Flow	lb/hr	670,000	689,093	697,292	702,476
SH Spray Flow	lb/hr	0	11,574	18,350	18,077
RH Spray Flow	lb/hr	0	0	8,199	13,383
SH Outlet Steam Temperature	°F	950	944	950	950
RH Outlet Steam Temperature	°F	950	961	962	950
CRH Steam Temperature	°F	697	692	697	697
Economizer Water Inlet Temperature	°F	450	442	442	442
Economizer Water Outlet Temperature	°F	502	478	477	477
Drum Pressure	psig	1,356	1,243	1,243	1,243
SHO Pressure	psig	1,295	1,200	1,200	1,200
CRH Pressure	psig	447	400	400	400
Economizer Outlet Gas Temperature	°F	720	687	691	691
Air Heater Inlet Gas Temperature	°F	720	628	691	691
Air Heater Outlet Gas Temperature uncorr.	°F	309	345	345	345
Air Heater Outlet Gas Temperature corr.	°F	290	325	324	324
Air Heater Outlet Air Temperature	°F	616	552	593	592
Air Heater Inlet Air Temperature	°F	80	108	108	108
Boiler Efficiency	%	88.59	88.60	84.08	84.08
Heat Input	Mbtu/hr	1,020	1,051	1,120	1,121
Excess Air	%	15	18	8	8
Fuel Nozzle Tilt	degrees	Horiz	-8	-12	-12
Fuel Elevations in Service	number	4	4	3	3

WPCA Gas Conversion- 5/23/12 - P 22

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Bituminous Coal Fired Boiler #1



		Original Design	Test Data Coal	Natural Gas
Date			2/16/2011	
Gross Load	MW		20 MW	
Load	%	65% MCR	23% MCR	23% MCR
Main Steam Flow	lb/hr	490,000	169,490	169,490
Reheater Steam Flow	lb/hr	424,000	154,514	154,514
SH Spray Flow	lb/hr	0	1,560	0
RH Spray Flow	lb/hr	0	0	0
SH Outlet Steam Temperature	°F	950	808	808
RH Outlet Steam Temperature	°F	950	741	740
CRH Steam Temperature	°F	625	450	450
Economizer Water Inlet Temperature	°F	408	318	318
Economizer Water Outlet Temperature	°F	466	389	379
Drum Pressure	psig	1,320	1,017	1,017
SHO Pressure	psig	1,295	1,013	1,013
CRH Pressure	psig	281	70	70
Economizer Outlet Gas Temperature	°F	644	489	479
Air Heater Inlet Gas Temperature	°F	644	489	479
Air Heater Outlet Gas Temperature uncorr.	°F	274	314	299
Air Heater Outlet Gas Temperature corr.	°F	254	301	288
Air Heater Outlet Air Temperature	°F	572	475	462
Air Heater Inlet Air Temperature	°F	80	118	118
Boiler Efficiency	%	89.35	87.62	84.12
Heat Input	Mbtu/hr	674	239	249
Excess Air	%	15	73	47
Fuel Nozzle Tilt	degrees	+30	Horiz	Horiz
Fuel Elevations in Service	Number	2	1	1

WPCA Gas Conversion- 5/23/12 - P 23

# Bituminous Coal Fired Boiler #1



		Original Design	Coal Data 2/16/2011	Natural Gas
Air Weight to FD Fan	lb/hr	900,000	908,921	961,999
Excess Air	%	15	18	8
Air Temperature to FD Fan	°F	100	100	100
Air Volume	ACFM	211,500	219,989	232,163
Air Volume per Fan	ACFM	105,750	109,995	116,418
25% Tolerance @ 100°F	ACFM	132,200		
Delta P	"w.g.	9.30	9.03	9.60
25% Pressure Tolerance	"w.g.	11.60		

		Original Design	Coal Data 2/16/2011	Natural Gas
Gas Weight to ID Fan	lb/hr	1,111,000	1,135,113	1,055,110
Excess Air	%	15	18	8
Gas Temperature to ID Fan	°F	302	325	324
Gas Volume	ACFM	356,000	393,341	365,152
Gas Volume per Fan	ACFM	178,000	196,670	182,576
21% Tolerance	ACFM	215,000		
Delta P	"w.g.	7.80	11.34	9.47
37% Pressure Tolerance	"w.g.	10.70		

WPCA Gas Conversion- 5/23/12 - P 24

# Bituminous Coal Fired Boiler #1




- Alstom performed a study to convert to 100% natural gas firing. For study purposes, the customer has defined normal full load (NFL) at 107 MW (approximately 795 MBtu/hr steam flow). Coal firing will be eliminated.
- To convert this unit to natural gas firing, the Company will provide three elevations of load carrying gas guns, coupled with Class 1 gas-fired ignitors. The ignitors will be located adjacent to the gas guns, which will be installed in the bottom three coal elevations. Using Class 1 ignitors eliminates the need for flame scanners; however, they can be used if desired by the plant. The gas guns will be sized for full load capability *without* ignitors on, in case the plant installs flame scanners, now or in the future.

# Bituminous Coal Fired Boiler #1




## Existing 16" Wide Windbox



To convert Units 1 to NG firing, Alstom proposes:


- Three elevations of load carrying gas guns, coupled with Class 1 gas ignitors
- Ignitors located adjacent to the gas guns and installed in bottom 3 coal elevations
- Class 1 ignitors eliminates need for flame scanners, although flame scanners may be used (if desired by Plant)
- Gas guns sized for full load capability *without* ignitors on

## Proposed 16" Wide Windbox



poses only  
sure to thi.

# Bituminous Coal Fired Boiler #1 – Gas Gun Assembly



- Gas gun assemblies based on Alstom's standard gas gun arrangement
- Composed of one spud located in bottom three coal elevations
- Each spud connected to a header at the back of the windbox.
- Flanged inlet pipe will protrude from the windbox to connect to the gas supply stainless steel flex hose.
- Gas gun assembly sized for approx.  $94 \times 10^6$  Btu/hr per compartment.
- 7:1 turndown capability with gas supply pressure of 25 psig to gas gun and minimum operating pressure of 1/2 psig above furnace pressure at burner spud

# Bituminous Coal Fired Boiler #1



---


## Ignitor Air System

- The existing 10,880 CFM ignitor air system is sufficient for the new ignitors (and any flame scanners, if the plant elects to install flame scanners).

## SOFA Windbox

- No modifications are planned for the SOFA windbox. The Company expects the SOFA airflow required to meet NOx emission targets will be less than the current SOFA is designed for. The reduced airflow will require retuning the SOFA over the load range.


# Bituminous Coal Fired Boiler #1 - Gas Pipe Schematic



# Bituminous Coal Fired Boiler #2



<b>PROPOSED FUEL</b>		EASTERN BITUMINOUS COAL				ASH FUS. TEMP. F.	BTU PER LB AS FIRED	HARDGROVE GRIND
F.C. 55.8 %	VOL. 31.1 %	MOIST. 4.0 %	ASH 9.1 %	S. -	-	13,370	55	
<b>FUEL BURNING EQUIPMENT</b>		CONT. SECT. RB	5 - No. 633 Raymond Bowl Mills					
and Tilting Tangential Burners								
<b>FURNACE</b>	CONT. SECT. PFSS	SQ. FT. H.S. PER FURN. 54,000	TYPE OF BOTTOM Basket					
Plain Tube Furnace								
FRONT TO REAR	28'-2"	WIDTH	40'-6-1/2"	VOLUME	116,500	CU. FT. GROSS		
<b>BOILER</b>	CONT. SECT. BCC	NO. 1	SQ. FT. H.S.EA. -	<b>PRESSURE</b>				
DESIGNATION	40'-6 1/2" 28'-2"	320-1 1/2 160-1 1/2	CCRR 60 2-36	MFR. C-E	2700	2450 at S.O.		
				STEAM WASHER	BOILER NUMBER 3			
<b>SUPERHEATER</b>	CONT. SECT. SH	TYPE Multi-Stage with Channel		<b>DESUPERHEATER</b>				
CONTROL RANGE	660,000 to 1,200,000 with burner tilt & desuperheater		SQ. FT. H.S. 100,300	FOR SUPHT'R. Spray				
<b>REHEATER</b>	TYPE Interstage	SQ. FT. H.S. 15,200		FOR REHEATER Spray				
<b>ECONOMIZER</b>	CONT. SECT. CONS	NO. 1		MAKE C-E				
TYPE:	CF-S 8H x 76W x 40'-6" lg.			SQ. FT. H.S.EA. 26,575				
<b>AIR HEATER</b>	CONT. SECT. CAHL	NO. 2		MAKE Ljungstrom				
TYPE	24-1/2 H 54			SQ. FT. H.S.EA. 100,800				
<b>MISCELLANEOUS DATA</b> Contract included steel-encased settings, insulation, duct-work, circulation pumps & piping, steam temp. controls.								
<b>EXPECTED PERFORMANCE</b>						<b>GENERATOR KW</b>		
FUEL		C O A L				1 - 165,000		
LB STEAM PER HR-ACTUAL	PRIMARY REHEAT	660,000	1,100,000	*1,160,000	*1,200,000	- 6 Hr. Peak - 18 Hr. Interval.		
	ECON. BOILER	592,500	975,000	1,023,000				
FEEDWATER TEMP. TO		420	467	470				
		465	505	507				
STEAM TEMP. at S.O. & R.O.		1050-1000	1050-1000	*1050-1000		REHEAT DATA 1,023,000 LB STEAM/HR. Enter. Temp. 669 F " Press. 507 Psi Leav. Temp. 1000 F " Press. 474 Psi		
HEAT RELEASE BTU/CU. FT./HR.		8,150	12,850	13,450				
TEMP. GAS FROM AIR HEATER		245	280	282				
TEMP. AIR FROM AIR HEATER		525	562	567				
OVERALL EFFICIENCY %		89.71	88.99	*68.95				



WPCA Gas Conversion- 5/23/12 - P 30

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Bituminous Coal Fired Boiler #2



		Original Design	Test Data Coal	Natural Gas	Natural Gas	Natural Gas
Date			03/29/2' 011			
				No Mods.	Add 31% more RH Finishing Surface	Add Gas Recirculation
Gross Load	MW		184			
Load	%	103.5% MCR 6Hr. Peak	104.8% MCR	104.8% MCR	104.8% MCR	104.8% MCR
Main Steam Flow	lb/hr	1,200,000	1,216,118	1,216,118	1,216,118	1,216,118
Reheater Steam Flow	lb/hr	1,063,000	1,113,651	1,113,651	1,113,651	1,113,651
SH Spray Flow	lb/hr	0	51,558	11,804	7,062	85,317
RH Spray Flow	lb/hr	0	0	0	0	0
SH Outlet Steam Temperature	°F	1,050	1,050	1,050	1,050	1,050
RH Outlet Steam Temperature	°F	1,000	999	972	1,000	990
CRH Steam Temperature	°F	670	686	686	686	686
Economizer Water Inlet Temperature	°F	472	457	457	457	457
Economizer Water Outlet Temperature	°F	508	509	507	507	519
Drum Pressure	psig	2,568	2,386	2,386	2,386	2,386
SHO Pressure	psig	2,450	2,290	2,290	2,290	2,290
CRH Pressure	psig	524	494	494	494	494
Economizer Outlet Gas Temperature	°F	681	665	664	664	689
Air Heater Inlet Gas Temperature	°F	681	619	664	664	689
Air Heater Outlet Gas Temperature uncorr.	°F	290	310	314	314	323
Air Heater Outlet Gas Temperature corr.	°F	270	301	305	305	313
Air Heater Outlet Air Temperature	°F	570	512	532	531	556
Air Heater Inlet Air Temperature	°F	80	93	93	93	93
	%	88.94	88.76	83.98	83.98	84.08
Heat Input	Mbtu/hr	1,618	1,667	1,742	1,763	1752
Excess Air	%	15	16	20	20	12
Fuel Nozzle Tilt	degrees	Horiz.	-7	+15	+15	+15
Gas Recirculation	%					20
Fuel Elevations in Service	Number	5	5	4	4	4

WPCA Gas Conversion- 5/23/12 - P 31

# Bituminous Coal Fired Boiler #2




		Original CL Design	Test Data Coal	Natural Gas	Natural Gas
Date			03/29/2'011		
				No Mods.	Add 31% more RH Finishing Surface
Gross Load	MW		45		
Load	%	57% MCR	31% MCR	31% MCR	31% MCR
Main Steam Flow	lb/hr	660,000	356,085	356,085	356,085
Reheater Steam Flow	lb/hr	592,500	330,859	331,158	330,859
SH Spray Flow	lb/hr	0	0	1,047	1,343
RH Spray Flow	lb/hr	0	0	299	0
SH Outlet Steam Temperature	°F	1,050	916	916	916
RH Outlet Steam Temperature	°F	1,000	795	797	824
CRH Steam Temperature	°F	590	466	464	466
Economizer Water Inlet Temperature	°F	420	337	337	337
Economizer Water Outlet Temperature	°F	464	424	425	425
Drum Pressure	psig	2,490	1,820	1,820	1,820
SHO Pressure	psig	2,450	1,810	1,810	1,810
CRH Pressure	psig	288	124	124	124
Economizer Outlet Gas Temperature	°F	605	512	517	517
Air Heater Inlet Gas Temperature	°F		474	517	517
Air Heater Outlet Gas Temperature uncorr.	°F		283	282	283
Air Heater Outlet Gas Temperature corr.	°F	245	275	275	275
Air Heater Outlet Air Temperature	°F	525	440	462	462
Air Heater Inlet Air Temperature	°F		102	102	102
Boiler Efficiency	%	89.71	88.72	83.70	83.68
Heat Input	Mbtu/hr	940	511	541	546
Excess Air	%		54	54	54
Fuel Nozzle Tilt	degrees	+30	Horiz	Horiz	+2
Fuel Elevations in Service	Number	3	2	2	2

WPCA Gas Conversion- 5/23/12 - P 32

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.


# Bituminous Coal Fired Boiler #2



WPCA Gas Conversion- 5/23/12 - P 33

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Bituminous Coal Fired Boiler #2



WPCA Gas Conversion- 5/23/12 - P 34

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Bituminous Coal Fired Boiler #2



		Original Design	Coal Data	Natural Gas
			2/16/2011	With or Without Additional RH Surface
Air Weight to FD Fan	lb/hr	1,418,000	1,367,521	1,578,988
Excess Air	%	15	16	20
Air Temperature to FD Fan	°F	100	100	100
Air Volume	ACFM	333,600	330,986	382,169
Air Volume per Fan	ACFM	166,800	165,493	191,085
27% Tolerance @ 140°F	ACFM	212,000		
Delta P	"w.g.	11.00	10.59	11.10
41% Pressure Tolerance	"w.g.	15.50		

		Original Design	Coal Data	Natural Gas
			2/16/2011	With or Without Additional RH Surface
Gas Weight to ID Fan	lb/hr	1,684,000	1,685,711	1,733,470
Excess Air	%	15	16	20
Gas Temperature to ID Fan	°F	285	301	305
Gas Volume	ACFM	524,000	565,177	585,380
Gas Volume per Fan	ACFM	262,000	282,588	292,690
15% Tolerance	ACFM	301,000		
Delta P	"w.g.	16.00	11.41	10.92
26% Pressure Tolerance	"w.g.	20.20		

## Bituminous Coal Fired Boiler #2




- Alstom performed a study to convert to 100% natural gas firing. For study purposes, customer has defined normal full load (NFL) at 185 MW. Coal firing will be eliminated.
- To convert the unit to natural gas firing, the Alstom will provide four elevations of load carrying gas guns, coupled with Class 1 gas-fired ignitors. The ignitors will be located adjacent to the gas guns, which will be installed in the top four coal compartments. Using Class 1 ignitors eliminates the need for flame scanners; however, they can be used if desired by the plant. The gas guns will be sized for full load capability *without* ignitors on, in case the plant installs flame scanners, now or in the future.

# Bituminous Coal Fired Boiler #2




## Existing 16" Wide Windbox




## To convert Unit 2 to NG firing, Alstom proposes:

- Four elevations of load carrying gas guns, coupled with Class 1 gas ignitors.
- Ignitors located adjacent to gas guns and installed in the *top four* coal compartments.
- Class 1 ignitors eliminates need for flame scanners, although flame scanners may be used (if desired by Plant)
- Gas guns sized for full load capability *without* ignitors on

## Proposed 16" Wide Windbox



# Bituminous Coal Fired Boiler #2 – Gas Gun Assembly



- Gas gun assemblies based on Alstom's standard gas gun arrangement
- Composed of two spuds located in the top four coal compartment
- Each spud connected to a header at the back of the windbox.
- Flanged inlet pipe will protrude from the windbox to connect to the gas supply stainless steel flex hose.
- Gas gun assembly sized for approx.  $111 \times 10^6$  Btu/hr per compartment.
- 7:1 turndown capability with gas supply pressure of 25 psig to gas gun and minimum operating pressure of 1/2 psig above furnace pressure at burner spud

# Bituminous Coal Fired Boiler #2



---

## Ignitor Air System

- The existing 12,880 CFM ignitor air system is sufficient for the new ignitors (and any flame scanners if the plant elects to install flame scanners).

## SOFA Windbox


- No modifications are planned for the SOFA windbox. The Company expects the SOFA airflow required to meet NOx emission targets will be less than the current SOFA is designed for. The reduced airflow will require retuning the SOFA over the load range.

# Converting PRB Coal Fired Boiler to Gas Firing

# PRB Coal Fired Boiler



BOILER		Units #1 & #2	SQ. FT. H.S. PER UNIT	107,647	DESIGN	2990		
DESIGNATION		65' - 0"	311 - 2"	CCRR	OPER.	2620		
		52' - 7 15/16"	234 - 2"		S.O.	TURBINE		
					THRITTLE	2520		
FURNACE		VOLUME CU. FT. TOTAL	597,625	TYPE OF BOTTOM	Hopper	WIDTH 65' - 0"		
		Fusion Welded Walls - Balanced Draft				FRONT TO REAR	52' - 7 15/16"	
SUPERHEATER		Multistage with Panels & Platens		REHEATER	Multistage with Radiant Wall - Front & Sides			
ECONOMIZER		NO. 1	TYPE Plain Tube - In Line 206 W x 48 H					
AIR HEATER		NO. 2	TYPE 3 1/2 VI 84 (T)		MAKE Ljungstrom			
FUEL BURNING EQUIPMENT		TT Fuel Nozzles 6-1003 RP Mills*						
FUEL		East Decker Sub-Bituminous - C			ASH FUSION TEMP. F	GRIND-ABILITY	WHV	
		24.71% Moist.	31.76% Vol	39.23% F.C.	43% Ash	2190	50	9238
		(Future - Texas Lignite)						
		FOSSIL SERVICES						
<b>OPERATING CONDITIONS</b>								
		CONTROL POINT		MCR				
LB STEAM PER HOUR ACTUAL	PRIMARY	2,100,000	4,199,000					
	REHEAT	1,899,000	3,724,000					
STEAM TEMP. F LEAVING	SUPERHEATER	1005	1005					
	REHEATER	1005	1005					
REHEAT DATA	ENTERING TEMP.	572	648					
	ENTERING PRESS.	319	628					
FEEDWATER TEMP. F		426	495.2					
TEMP. AIR TO AIR HEATER		125	90					
TEMP. GAS FROM AIR HEATER		256	290 (UNCORR.)					
OVERALL EFFICIENCY % *Guaranteed		87.49	86.56*					
SUPPLEMENTARY DATA		*Provision made for 7th Mill for Lignite O.F.A.; Refractory: Insulation & Lagging; F.D. & P.A. Fans; Soot Blowing System; Steam Coil; Circ. System; Cold Precipitator by Customer.				GENERATOR KW MFR. RATING		
						600,000		
						PLANT ELEV. 376 FT.		



PUB. NO 1-2-62

WPCA Gas Conversion- 5/23/12 - P 41

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# PRB Coal Fired Boiler– Full Load



SH Steam Flow	lb/hr	4208428	4208428	4208428	4208428	4208428	4208428	4208428
RH Steam Flow	lb/hr	3926131	3848276	3899221	3814276	3814276	3839524	3814276
SHO Temp	degF	1004	990	1004	863	986	1004	978
SH Desup Spray	%	1.3	0.1	0.6	0	0	0	0
RH Desup Spray	%	2.9	0.9	2.2	0	0	0.7	0
SHDesuperheater Spray	lb/hr	56190	0	26563	0	0	625	0
RHDesuperheater Spray	lb/hr	111855	0	84945	0	0	25248	0
RHO Temp	degF	1005	1004	1005	789	988	1006	974
RHDESUP OUT TMP	degF	589	606	599	506	617	622	609
Feedwater Temp	degF	470	470	470	470	470	470	470
Econ Exit Gas Temp	degF	778	763	769	695	765	760	783
AH TGO Uncorr	degF	308	304	306	306	317	320	336
Tilt	degree	-5	-5	5	5	25	15	5
Excess Air	%	20	20	20	10	30	20	10
Boiler Efficiency	%	85.58	85.32	85.27	84.21	83.11	83.47	83.58
Gas Recirculation	%	0	0	0	0	0	0	35
NHI/PA	Btu/hr-ft <sup>2</sup>	1.85	1.81	1.83	1.54	1.79	1.79	1.84
Q FIRED	Btu/hr	6052.8	5952	6037.9	5347.5	6017.8	6084.5	5940.5
Gas Leaving AH	degF	6524397	6317903	6400794	4889759	6347443	5967469	5403267
Gas In Temp	degF	2699	2642	2684	2454	2555	2687	2353
Percent Coal		100	80	80	0	0	0	0
Percent Gas		0	20	20	100	100	100	100
Existing Windbox Configuration		Yes	Yes	Yes	Yes	Yes	No	Yes

# PRB Coal Fired Boiler– Low Load




SH Steam Flow	lb/hr	1501008	1501008	1387762	1387762	1387762
RH Steam Flow	lb/hr	1461186	1461186	1329376	1329376	1329376
SHO Temp	degF	999	962	933	1005	1005
SH Desup Spray	%	0.6	0	0.4	4.4	5.2
RH Desup Spray	%	0	0	0	0	0
SHDesuperheater Spray	lb/hr	9448	0	5218	60655	71677
RHDesuperheater Spray	lb/hr	0	0	0	0	0
RHO Temp	degF	924	867	832	946	952
RHDESUP OUT TMP	degF	601	568	540	605	605
Feedwater Temp	degF	383	383	376	376	376
Econ Exit Gas Temp	degF	539	528	510	529	572
AH TGO Uncorr	degF	249	250	280	284	301
Tilt	degree	-2	-2	25	25	25
Excess Air	%	31.6	31.6	33.3	33.3	33.3
Boiler Efficiency	%	87	86.59	84.12	84.03	83.58
Gas Recirculation	%	0	0	0	0	35
NHI/PA	Btu/hr-ft <sup>2</sup>	0.66	0.64	0.58	0.62	0.66
Q FIRED	Btu/hr	2241.7	2191.9	2055.1	2173	2190.1
Gas Leaving AH	degF	2756536	2656381	2364819	2486853	2508275
Gas In Temp	degF	2025	1943	1900	2156	1882
Percent Coal		100	80	0	0	0
Percent Gas	Percent Gas	0	20	100	100	100
Existing Windbox Configuration		Yes	Yes	Yes	No	Yes

# PRB Coal Fired Boiler




- Retaining coal firing capability
- Existing oil fired ignitors were eliminated that are adjacent to the coal compartments.
- New gas fired ignitors adjacent to the new gas compartments and coal will be ignited by the gas elevations.

**Existing LNCFS™ Level 3 Low NOx System Windbox Arrangement**



**Natural Gas Modification to Existing LNCFS™ Level 3 Arrangement**




# PRB Coal Fired Boiler



- Optional gas firing arrangement
- Install one elevation located in the SOFA to raise furnace outlet gas temperature so steam temperature can be achieved.

**Existing LNCFS™ Level 3 Low NOx System Windbox Arrangement**


**Natural Gas Modification to Existing LNCFS™ Level 3 Arrangement**



# Pulverizer and Fan Systems

- 
- How do we get the required combustion air flow to the windbox and furnace?
  - What operating or equipment modifications will be required?


# Pulverizer System with Exhausters



WPCA Gas Conversion- 5/23/12 - P 48

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.


# Cold Primary Air System



WPCA Gas Conversion- 5/23/12 - P 49

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Cold Primary Air System with Bisector AH



WPCA Gas Conversion- 5/23/12 - P 50

© ALSTOM 2012. All rights reserved. Information contained in this document is provided without liability for information purposes only and is subject to change without notice. No representation or warranty is given or to be implied as to the completeness of information or fitness for any particular purpose. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

# Converting Coal Fired Boilers to Gas Firing Summary

## Possible Issues Include:

- An increase in SH desuperheater spray water flow
- An increase in RH desuperheater spray water flow
- An increase in forced draft fan volumetric flow
- SHO & RHO steam temperatures may not be achieved in some cases

These issues may or may not require capacity increases in their respective equipment

# Bituminous Coal to Natural Gas Conversion

---

## Solution:

- Increase the SH desuperheater spray water capacity
- “Tip” the forced draft fans to increase their volumetric flow capacity
- May require re-surfacing for steam temperature

## Possible Issues Include:

- Inability to attain design SH steam outlet temperature
- Inability to attain design RH steam outlet temperature
- Insufficient forced draft fan volumetric capacity
- Insufficient forced draft fan motor size
- Primary air system not useful
- Exceeding steam turbine steam inlet temperature lower limits
- Exceeding steam turbine SH/RH steam inlet differential temperature limits

## Solution:

Raise the gas firing elevation in the furnace to increase furnace outlet temperature when firing natural gas

- Increases SH steam outlet temperature to design level
- Eliminates steam turbine steam temperature issues
- Customer may choose to let forced draft fan capacity determine MCR
- FD fan volumetric capacity may be increased by “tipping” the fan (may require motor HP increase)
- FD fan volumetric capacity may be augmented with the primary air fans
- Primary air system may need to be redesigned

[www.power.alstom.com](http://www.power.alstom.com)

**ALSTOM**