

Worldwide Pollution Control Association

Duke Energy Seminar
September 3 – 5, 2008
Concord, NC



Visit our website at www.wpca.info

W
P
C
A

Wet Scrubber System Fundamentals

Vic Adamson

WPCA/Duke Seminar
September 3-5, 2008



In what decade was the first wet FGD system commissioned?

The 1930s



FUN

ALSTOM

Where was the first wet FGD system commissioned?

Battersea
Power
Station in
London



FUN

ALSTOM


When, where, and by whom was the first US WFGD system commissioned?

1968 in
Lawrence,
Kansas by
Alstom



- Introduction
- Major Process Equipment
- Operation
- Secondary Emissions
- Summary

Total US Scrubbed Capacity – Approx. 100 GW



US WFGD Experience




- Over 94 GW of WFGD systems in US; first units installed in 1960s
- SO₂ removal efficiencies greater than 98%
- Availability greater than 98%
- Experience with wide range of fuels
- Reagent flexibility (lime, limestone, ammonia, alkaline ash)
- Marketable product or landfill




Duke Energy
Marshall Units 1-4
Terrell, NC

- Introduction
- Major Process Equipment
- Operation
- Secondary Emissions
- Summary


LSFO Process Diagram



Limestone/Forced Oxidation



Absorber Island



Absorber Unit Operations




Unit Operations


- Inlet – gas distribution, humidification
- Spray zone – gas/liquid contact
- Mist eliminator zone – liquid/gas separation
- Reaction tank – oxidation, dissolution, crystallization

Design Goals


- Lowest lifecycle cost
 - Capital
 - O&M
- High reliability




Absorber Designs




Open Spray Tower



Fountain Tower



Tray Tower



Jet Bubbling Reactor

Spray Headers

- Materials
 - Stainless steel
 - Alloy
 - FRP
 - Rubber-lined carbon steel
- Self-supporting or internal support beams or trusses
 - Absorber diameter
 - Material of construction
- Staggered arrangement




Spray Zone

- Dedicated recirculation pump at each spray header
- Performance enhancement plates
- Excellent gas / liquid contact assures high SO₂ removal efficiencies
- Lowest draft loss
- Highest reliability
- Low scaling potential
- Excellent turndown reduces operating costs over 100–0% load range



Spray Nozzles

- Multiple counter-current spray elevations
- Nozzle type
 - Top elevation—single orifice hollow cone
 - Lower elevations—dual orifice hollow cone
- Sauter mean droplet diameter of ~2,000 micron at 8 psig
- Silicon carbide construction




- Functions
 - Limestone dissolution
 - Oxidation
 - Gypsum crystallization
- Side entry agitators with air lances for oxidation
 - 4–6 agitators/lances
 - Simple, reliable and proven design
 - Excellent turndown at lower boiler loads and inlet SO₂ loading
 - Minimizes plugging potential
 - Easy inspection during scheduled outages



Mist Eliminator



- Two stages of vertical-flow chevron vanes
- Construction
 - Polypropylene
 - Polysulfone
 - FRP
 - Alloy/stainless steel



Mist Eliminator Wash System



- Fresh water wash on intermittent basis
 - First stage washed from below (1.5 gpm/ft²) and above (0.75 gpm/ft²)
 - Second stage washed from below (0.75 gpm/ft²)
- Construction
 - Piping: FRP, polypropylene, alloy/SS
 - Nozzles: polypropylene, alloy/SS



Absorber Recycle Pump



- Typical size: 50,000–85,000 gpm at 55–85 TDH
- Pump Efficiency: 87–90+%
- 800–1,500 hp (~1 MW)
- Horizontal, centrifugal
- Rubber-lined casing
- Metal Impeller
- Mechanical Seal




Shell

- Rubber-lined carbon steel
- Flakeglass-lined carbon steel
- Stainless steel (317LMN)
- Duplex stainless steel (2205, 255)
- Nickel-based alloy
- Roll-clad alloy
- Lined concrete (tile, rubber)

External Spray Piping

- FRP
- Rubber-lined carbon steel
- SS/alloy



Mist Eliminators

- FRP
- Polypropylene
- Polysulfone
- SS/alloy

Headers

- Rubber-lined carbon steel
- FRP
- Stainless steel (317LMN)
- Duplex stainless steel (2205, 255)
- Nickel-based alloy

Inlet

- C-276


Organic Acid Enhancement

- Organic acids (e.g. adipic, dibasic) increase the scrubbing capacity of limestone slurry
- Relatively low dosage rates (e.g. 300 - 700 ppm)
- Can be used to improve efficiency or reduce operating costs
- Most effective for high sulfur fuels
- Widely used commodity chemical
 - Nylon manufacture
 - Food additive
 - Curing agents/plasticizers
- Environmentally friendly
 - Initial use promoted by US EPA
 - Approved by US FDA as food additive

Adipic Acid




- Chlorides concentrated in WFGD system due to evaporation
- Chlorides leave WFGD system via:
 - Moisture in gypsum filter cake
 - Disposal gypsum
 - Wallboard gypsum
 - Liquid carryover from absorber (insignificant)
 - Unabsorbed HCl (insignificant)
- Purge stream required for wallboard gypsum production




- Impact on SO₂ removal
 - Chloride from flue gas accumulates as soluble CaCl₂
$$2\text{HCl} + \text{CaCO}_3 \rightarrow \text{CaCl}_2 + \text{CO}_2 + \text{H}_2\text{O}$$
$$\text{CaCl}_2 \rightarrow \text{Ca}^{+2} + 2\text{Cl}^-$$
 - High Ca⁺² concentration depresses pH and alkaline species such as HCO₃⁻, SO₃⁻², HSO₃⁻
 - Result is lower removal efficiency/higher L/G
 - Chlorides that accumulate as NaCl (e.g. from make-up water) have much less impact

Effect of Chlorides on Materials

- Soluble chlorides known to attack steel/alloys
 - General corrosion
 - Pitting
 - Stress corrosion cracking
- Aggravated by
 - Low pH
 - Deposits
 - Stagnant liquids
- Material selection must consider
 - Service/operating conditions
 - Availability requirements
 - Cost



Reagent Preparation Island




Limestone Delivery/Storage

- Truck, rail, or barge delivery
- ¾" x 0" (20 x 0 mm) crushed limestone
- Outdoor long-term storage feasible in most areas
- Indoor storage in harsh/wet climates




Limestone Silo

- Provide buffer between limestone pile and ball mill operation
- 16-24 hr capacity
- Carbon steel construction with polymer or stainless steel hopper lining
- Fluidized bottom/mechanical activation
- Vent filter for fugitive dust control




- Limestone grinding
 - Horizontal/vertical wet ball mills
 - On-site vs. off-site preparation
- Product ground to 90-95% < 40 μ ; 30-35% solids
- Rubber-lined with hardened steel balls



- Dry, pre-ground limestone feed options
 - Pneumatic injection into reaction tank below slurry level
 - Pre-slurry in small tank
- Advantages
 - Low capital cost (i.e. no ball mills, auxiliary equipment, buildings, etc.)
 - Less equipment to maintain
- Disadvantages
 - Higher delivered cost
- Lifecycle cost evaluation on case-by-case basis

Dewatering Island



Dewatering

- Primary dewatering:
 - Hydrocyclone
 - Absorber - 15% solids
 - Overflow - 3% solids
 - Underflow - 55% solids
- Secondary dewatering:
 - Commercial gypsum – vacuum belt filter @ 10% moisture
 - Landfill gypsum – vacuum drum filter @ 15% moisture



- Typical specification:
 - $>95\% \text{ CaSO}_4 \cdot 2\text{H}_2\text{O}$
 - $<0.5\text{--}1.0\% \text{ CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$
 - $<100 \text{ ppm Cl}$
 - $<10\% \text{ moisture}$
 - $\text{pH } 6\text{--}8$
 - $30\text{--}40\mu \text{ MMD}$
- Requires:
 - High purity limestone (95–96%)
 - High efficiency ESP/FF
 - 99+% oxidation
 - Belt filter
 - Cake washing



Gypsum Storage/Handling



- Covered storage options
 - Direct discharge to bunker/
manual reclaim
 - Convey to dome/manual
reclaim
 - Convey to building or silo/
automated reclaim
- Open pile
 - Feasible
 - Possible issues: moisture,
fugitive dust, leaching
- Selection depends on:
 - On-site storage requirement
 - Gypsum contract



- Introduction
- Major Process Equipment
- Operation
- Secondary Emissions
- Summary

Centralia Operations Summary



- Start-up
 - Unit 2 and common equipment – October 2001
 - Unit 1 – July 2002
- 100% availability on both units since start-up
- Emissions and performance well within required limits
- Absorber opened for first time during planned Unit 2 boiler/turbine outage in April 2003



Centralia Steam Plant

Absorber After 11,000 Hours




September 2001




April 2003

Unit 2 Absorber Outage



Unit 2 Absorber Outage



| Position Description | No. | Coverage |
|-----------------------------|------------|-----------------------|
| FGD Supervisor | 1 | 1 shift, 5 days/week |
| FGD Operator | 1 | 3 shifts, 7 days/week |
| FGD Mechanic | 1 | 1 shift, 5 days/week |
| FGD Computer Tech | 1 | 1 shift, 5 days/week |
| FGD Specialist | 1 | 1 shift, 5 days/week |
| FGD Material Handling | 1 | 3 shifts, 7 days/week |


- Introduction
- Major Process Equipment
- Operation
- Secondary Emissions
- Summary

Sulfuric Acid Mist

- SO_3 inlet concentration
 - <1 ppm for western sub-bituminous coal
 - >50 ppm for eastern bituminous
- Sulfuric acid (H_2SO_4) mist created due to rapid quenching of flue gas in absorber
- Fine droplets (< 0.5 micron) are difficult to collect
- Control techniques
 - Alkali injection (e.g. lime, trona, sodium carbonate)
 - Wet electrostatic precipitator



- WFGD systems remove 70-90% of incoming HgCl_2 , but very little Hg^0
 - HgCl_2 water soluble and is absorbed efficiently
 - Removal not strong function WFGD design
- Effluent flue gas contains mostly elemental, vapor-phase Hg
- Mercury can also enter WFGD with limestone and/or make-up water
- Fate of mercury
 - Purge stream
 - Gypsum
- Do WFGD systems re-emit Hg?



- Oxidized mercury readily absorbed by WFGD system; elemental mercury is not
- Oxidized Hg entering WFGD is a function of:
 - Fuel (i.e. Hg, Cl, Br)
 - Boiler operating conditions (e.g. unburned carbon)
 - Upstream equipment (e.g. SCR, ESP, FF)
- Oxidized mercury captured by WFGD can be reduced to elemental mercury and re-emitted
 - Re-emission additives
 - Oxidation/reduction potential
- Fate of mercury
 - Gypsum
 - Purge stream

- Introduction
- Major Process Equipment
- Operation
- Secondary Emissions
- Summary

WFGD Rules of Thumb



| | |
|-------------------|---|
| Limestone Usage | 1.7 ton limestone/ton SO ₂ removed |
| Limestone Cost | \$10-20/ton |
| Gypsum Production | 3.1 ton gypsum/ton SO ₂ removed (95% purity, 10% moisture) |
| Gypsum Value | -\$10 to +\$5/ton |
| Water Consumption | 1.5-1.8 gpm/MW |
| Power Consumption | Low S – 1.2-1.5% generation High S – 1.5-2.0% generation |

600 MW WFGD System



www.alstom.com

ALSTOM