

# Worldwide Pollution Control Association

ESKOM Scrubber Seminar  
April 12<sup>th</sup> – 13<sup>th</sup>, 2007




Visit our website at [www.wpca.info](http://www.wpca.info)

**W  
P  
C  
A**

# Babcock Power Inc.



*One Source*



*Many Solutions*



*One Purpose*

## WPCA/ESKOM Scrubber Seminar

### FGD Design and Operating Criteria

*Tony Licata*

*Babcock Power Environmental Inc.*



# Wet Scrubbing Challenges

- Liquid to Gas Ratio
- Oxidation
- Chloride Concentration (Blowdown)
- Gypsum
- O&M
- Turndown



# Wet FGD Challenges

- Materials of Construction
  - Vessels and headers
- Plugged Nozzles/Lines
- Mist Eliminator Washing
- Filtering Process
- Limestone/lime Storage



# Existing Plants Roadmap Performance Targets

Innovations for Existing Plants	2005	2010	2015
---------------------------------	------	------	------

## Emissions

SO <sub>2</sub> , % removal (emissions, lb SO <sub>2</sub> /MMBtu) mg/Nm <sup>3</sup>	90 – 95 (0.22 – 0.04) 40-7	98+ (0.09 – 0.009) 16 - 5	99 (0.04 - .01) 7 - 2
NO <sub>x</sub> , lb/MMBtu (SCR equipped) mg/Nm <sup>3</sup>	0.04 – 0.08 14 – 28	0.02 – 0.04 7 - 14	0.01 – 0.02 3.5 - 7
NO <sub>x</sub> , lb/MMBtu (comb. cntls.) mg/Nm <sup>3</sup>	0.1 – 0.3 35 - 105	0.06 – 0.1 21 – 35	<0.05 – 0.1 17.5 - 35
Hg removal, %	co-benefits 30 – 90%	65 – 90	80 – 95

Electric Power Research Institute, and the Coal Utilization Research Council



# Existing Plants Roadmap Performance Targets


Innovations for Existing Plants	2005	2010	2015
Emissions			
PM emissions, lb/MM Btu mg/Nm <sup>3</sup>	0.03 – 0.1 43/144	0.01 – 0.02 14/28	0.01 14
SO <sub>3</sub> emissions, ppmv mg/Nm <sup>3</sup>	50 - </=2 14 - 0.56	10 - </=2 2.8 – 0.56	</=2 0.56
Fresh water use, % reduction	baseline	5 – 10	25
By-product utilization, %	39	50	75

Note targets are dependent on the coal type being used and that the data represents targets for both bituminous and sub-bituminous coals


Electric Power Research Institute, and the Coal Utilization Research Council



# Integrated Coal Source to Stack Pollutant Control Solution



# WFGD Process Flow Diagram



Limestone / Gypsum will dominate utility applications





Gypsum storage silos


Ball mills and  
recycle pumps

Limestone unloading &  
Storage

Gypsum loading barge




# Absorber Island Cutaway View Showing Absorber Internals




# Absorber Internals



# FGD Absorber Internals



# Weather Protected Limestone Storage and Feeding



# Enclosed Ball Mill for Sound Protection and Maintenance in Cold Climate



**Outdoor Ball Mill  
Warm Climate**


**Maintenance Crane**



# Oxidation Air Blowers in Sound Enclosure




# Dewatering System



# Gypsum Dewatering

## Hydrocyclone & Belt Filter Arrangement









# Power Optimization

## Design Influence

- **Recycle Pumps**
- **Fans – Gas Side DP**
- **Oxidation Air Blowers**
- **Limestone Grinding Mills**

## Operational Influence

- **On-line Optimization**
- **Automatic and in Real Time**



# Power Optimization Oxidation & Agitation

- **Tank Sizing**
  - **Limestone Dissolution**
  - **Oxidation**
    - **Mixing**
    - **Residence Time**
  - **Reaction Completion**
    - **De-supersaturation**
  - **Gypsum Crystal Growth**
    - **Size**
    - **Shape**
- **On-line Monitoring**



# Power vs. SO<sub>2</sub> Removal

## 750 MW East. Bituminous Coal

### Wet FGD Power Usage

		SO <sub>2</sub> Removal		
		<u>95%</u>	<u>97%</u>	<u>99%</u>
Booster Fan	kW	4,253	4,593	5,303
Recycle Pumps	kW	4,160	4,593	6,961
Oxidation Air Blowers	kW	2,315	2,556	3,500
Ball Mills	kW	1,614	1,648	1,682
Others	kW	2,660	2,710	2,772
total	kW	<u>14,572</u>	<u>16,100</u>	<u>20,218</u>



# *Operation and Maintenance*




# O & M Criteria

- **Safety**
- Balance between initial capital cost vs. long-term operating cost
- Plant availability/redundancy
- Operating economics
  - Elevators vs. stairs
  - Weather encloses
- Wash down/Cleaning
  - Drains/pits/pumps
- All in one building



**Limestone preparation,  
recycle pumps, control  
room and gypsum  
system in one building  
for reduced operating  
cost**

**Elevator**



# Isolation Valves for Pump Maintenance



# All pumps in straight line/overhead cranes



**Note wide  
maintenance  
aisles**

**Floor drains**



**Overhead crane for maintenance**

**Room between pumps for forklift**




# Overhead cranes




# Recycle pump screens to prevent pump wear and nozzle plugging



**Scaffolding Provides Convenient  
And Safe Access to Nozzles  
Allows Maintenance at the Upper Levels  
To Be Performed at the Same Time as Maintenance  
In the Reaction Tank Area (No Fall Thru).**



# Maintenance Support Grid



# Operational WGFD Testing Requirements

	Frequency of sampling	pH	Density	Wt % of solids	Chemical composition of solids SO <sub>4</sub> <sup>-2</sup> SO <sub>3</sub> <sup>-2</sup> CO <sub>3</sub> <sup>-2</sup> Inert	Particle size Distr.	Cl-Content
Slurry recycle	1x per day	X	X	X	X	X (2/week)	X
Gypsum Slurry	1x per week		X	X	X	X	--
Gypsum	1x per week				X	X	X
Limestone Slurry	1x per week	X	X	X	X	X	X
Limestone	Weekly composite				X		
Ball Mill Hydrocyclones						X	
Make Up Water	1x per week	X					X
Waste Water	1x per week	X		X			X



# Operational WGFD Testing Requirements

<b>Test Description</b>	<b>Test Method</b>
<b>pH</b>	<b>EPRI -C1</b>
<b>Density</b>	<b>EPRI -D2</b>
<b>Wt % of Solids</b>	<b>EPRI -F3</b>
<b>Chemical Composition-Sulfate</b>	<b>EPRI -L2</b>
<b>Chemical Composition-Sulfite</b>	<b>EPRI -M1</b>
<b>Chemical Composition-Carbonate</b>	<b>EPRI -N3</b>
<b>Particle Size</b>	<b>EPRI -G1</b>
<b>Crystal Water</b>	<b>ASTMC471M</b>
<b>Residual Moisture</b>	<b>ASTMC471M</b>
<b>Chloride</b>	<b>EPRI -I3</b>



# Operational WGF D Testing Manpower

- Man-hours per absorber 14.5 hours / week
- Man-hours plant common systems
  - Reagent system 15.5 hours / week
  - Water system 4.5 hours / week
  - Gypsum byproduct 4 hours / week
- Man-hour estimate 2 absorbers and common systems 53 hours
- Man-hour estimate 2 absorbers and common systems 2756 hours



# Periodic Mechanical Inspection

- Pumps – Check
  - Oil level
  - Seal leakage
  - High vibration
  - Belt tension
  - Bearing temperature
  - Alignment
- Agitators – Check
  - Oil level
  - High vibration
  - Gland seal water leakage
- Strainers
  - Differential pressure each shift, clean if high



# Periodic Electrical Inspection

- Motors – Check
  - Bearing temperature
  - Insulation resistance
  - Bearing vibration
  - Brush wear
  - Slip ring roughness
  - Motor heater current
  - Clean parts of carbon dust
- Electrical
  - Annual inspection or per manufactures instructions
- Relays
  - Differential pressure each shift, clean if high
- Instrumentation
  - Per manufactures instructions



# Periodic Maintenance Manpower

- Man-hours per absorber 20 hours / week
- Man-hours plant common systems
  - Reagent system 20 hours / week
  - Assist with Operational Testing 20 hours / week
- Man-hour estimate 2 absorbers and common systems 80 hours
- Man-hour estimate 2 absorbers and common systems 4160 hours



# Operation and Maintenance Manpower

- WFGD Operator, current control room operator from each unit will monitor and control
- Assistant WFGD Operator, one required for plant, perform WFGD operational testing
- Maintenance Mechanic, two required for plant, perform periodic maintenance and assist with testing



# Scheduled Outage Inspection

- Absorber Tank
  - Inspect for corrosion, scale and deposits
  - Remove loose material
  - Map location of deposits
  - Repair lining as needed
- Spray Headers and Nozzles
  - Check spray nozzles for plugging and map
  - Clean or replace nozzles as necessary
  - Check headers for erosion
- Mist Eliminators
  - Check for damage or deposits
  - Check wash system for valve function and coverage
- Reagent Preparation
  - Inspect and repair in accordance with manufactures' instructions



# Outage and Maintenance Costs

- Estimated outage (3 yr) cost \$250,000 / absorber including
  - Absorber scaffolding
  - Sump cleaning
  - Absorber vessel and header repairs
- Estimated yearly maintenance cost \$150,000 / absorber including
  - Agitator parts
  - Recycle pump rebuilds
  - Misc. pump rebuilds



# Unique Process Features

- Bi-Directional Spray Nozzles
- Wall Rings
- Advanced Hydraulic Spray Header Design
- Maintenance Platforms



# Bi- Directional Spray Nozzles

- Upward Spray Energy Lowers Pressure
- Number of Liquid Orifices Doubles
  - Smaller Droplet Size at Same Pump Power
- Intersections of Spray - Greatly increased
  - Small ‘mist’ droplets are generated
    - Increased surface to mass ratio
  - Droplets mixed and reformed
    - Increased mass transfer at gas-liquid interface




# Characterizing Spray Nozzle Flow

- Bi-Directional
- Hollow Cone
- Wide Angle
- Low Liquid Pressure
- Small Droplets




**Note: All Elevations Spray In 2  
Directions Except the Top Spray Level  
To Avoid Clogging of Mist Eliminators**





**Isometric View Showing  
Spray Pattern Across Five Levels**



- **Spray Nozzles Arranged To Provide Full Coverage Across The Section of the Absorber**
- **Outer Nozzles Arranged to Ensure Maximum Coverage And Reduce Impingement at The Absorber Wall**







Typical Spray Header Branch Line



## Spray Header/Nozzle Arrangement


Plan View

- Spray Level 5
- Spray Level 4
- Spray Level 3
- Spray Level 2
- Spray Level 1

Vessel ID


Wall Ring

- Wall Ring @ Spray Levels 2 & 4 Ensure No Gases Flow Thru At Wall Unrestricted
- Spray Nozzles and Piping Arranged to Minimize Vertical Alignment of Nozzles and Maximize Spray Pattern Coverage



# Alloy Selection Criteria

Increased Pitting & Crevice Corrosion Potential  
Increased (Cl) Stress Corrosion Cracking Potential



## Need

Pitting & Crevice Corrosion Resistance

SCC Resistance

Both Shop & Field Fabricate-ability

Weld-ability

Availability

Economics



<b>Materials of Construction</b>	<b>Design Chloride Limits (ppm)</b>	<b>GPM Wastewater</b>
317LMN Stainless Steel (S31726)	8,000	287
Duplex 2205 Stainless Steel (S32205)	12,000	141
Super Duplex 255 Stainless Steel (S32550)	20,000	115
Super Austenitic 6% Mo Stainless Steel (N08367)	40,000	57
C-276 (N10276)	50,000	46
Carbon Steel/Glass Lined	50,000	46
Carbon Steel/Rubber Lined	50,000	46
Concrete/Tile Lined	> 50,000	46
Concrete/PP Lined	50,000	46




<h2 style="text-align: center;">Materials of Construction</h2>	<h2 style="text-align: center;">Installed Cost Ranking</h2> <p style="text-align: center;">O&amp;M cost not included</p>
317LMN Stainless Steel (S31726)	1
Duplex 2205 Stainless Steel (S32205)	2
Super Duplex 255 Stainless Steel (S32550)	3
Super Austenitic 6% Mo Stainless Steel (N08367)	4
C-276 (N10276)	7
Carbon Steel/Glass Lined	1
Carbon Steel/Rubber Lined	1.5
Concrete/Tile Lined	4
Carbon Steel/Tile Lined	6
Concrete/PP Lined	3




Metal Price Trends (Source: AMM)

Steel Scrap Nickel Molybdenum Chrome Vanadium Manganese Copper Aluminum Tungsten



# Cost of FGD Vessel Materials



# Owners Decisions

- Redundancy
  - Pumps
  - Ball Mills – 3 x 50% or 2 x 100%
  - Dewatering
  - Spares
- Organic Acids
- Waste Water
- Gypsum Markets/landfilling




# Absorber Access

- **Safety First**
  - Confined Space
  - Fall Protection
  - Personal Safety Equipment
  - Working Conditions: Lighting, GFIs, Tools, Noise, Welding. Flash Protection, etc.
- Maintenance
  - Minimize outage time
  - Simple PM programs
  - Easy access for service and cleaning




# Ghent Station Unit 3 Absorber Island Plan View

Oxidation Air Compressors



Recycle Pumps



2<sup>nd</sup> Stage Mist Eliminator  
Access Platform

- Wrap Around Design Provides Access To Spray Header Valves
- A Lay Down Area for Demister Modules

2 – Gypsum Transfer Tanks ea.207,000 gal.  
- Carbon Steel (Rubber Lined)  
- Return from 3 Recycle Pumps  
- Each With Agitators




Existing Unit 1  
FGD Stack



1- Process Water Tank 85,500 gal.  
- Carbon Steel  
- 2 Redundant Mist Eliminator Wash Pumps



# Ghent Station Unit 3 Absorber Island Cutaway View Showing Absorber Internals



# Tile Lined Concrete



# Project Execution



- Market volatility
  - Materials
- Labor
- Project time lines
- Project Management tools

# Equipment Delivery

## In Weeks

<b>Commodity</b>	<b>2003</b>	<b>2006</b>
<b>Structural Shapes</b>	<b>8-12</b>	<b>20-24</b>
<b>Recycle Pumps</b>	<b>26-30</b>	<b>52-94</b>
<b>Ball Mills</b>	<b>26-30</b>	<b>64</b>
<b>ID Fans</b>	<b>72</b>	<b>100</b>
<b>SCR Catalyst</b>	<b>46-48</b>	<b>48-52</b>



# What Can be Done to Mitigate On-Site Labor Cost


- Modularization
- Packaging components
- Alternative materials of construction
- Constructor alliances
- Standard designs
  - Rigging layouts
- Construction manuals
  - Lessons learned



# What can be done to shorten time line ?

- Qualifying new vendors
- Packaging components
- New construction techniques
- Standard designs
- New design tools






# Crane rigging plan

Maintenance platforms

Enclosed building



Inlet Duct  
Wet/Dry Interface

Outlet Hood

Floor Plates

Pro/E Model  
Of  
Ghent Station Unit 3 Absorber Vessel  
Exploded View Showing C-276 Plates  
Before Assembly & Welding





# Construction Modularization

Ohio  
River  
SCR  
Modules  
AEP Amos  
Tier 2



# Mist Eliminator and Absorber Outlet



# Introduction

- **Vectren, F.B. Culley  
Generating Station  
Units 2 & 3**
  - Two boilers feeding  
one WFGD System
  - WFGD supplied by  
BPEI (1994)
  - No Bypass



# Current BPEI FGD Upgrade Projects

- Vectren Culley - Unit 2 & 3
  - Continuous relationship
- LG&E Trimble County – Unit 1
  - Improve operation
  - Increase removal 98%
  - Recycle pump performance



# Changes in Design Parameters


Original Design	Revised Design
368 MW	390 MW
6.5 lb SO <sub>2</sub> /mmBtu	8.0 lb SO <sub>2</sub> /mmBtu
95.0% SO <sub>2</sub> Removal Efficiency	95.5% SO <sub>2</sub> Removal Efficiency
Minimum of 1 Spare Recirculation Pump	Minimum of 1 Spare Recirculation Pump





# Results (Normalized Data)

Vectren, F.B. Culley Station Units 2 & 3  
Absorber Performance

Average SO<sub>2</sub> Removal Efficiency based on  
WFGD system revised design conditions



# Results (Raw Data)



# Accomplishments

- Exceeded performance requirements
  - Customer assured of reliable operation firing maximum sulfur coal with 5 pumps operating and 1 spare
  - Reduction in total operating cost by utilizing only 4 of 6 pumps in operation when firing typical sulfur coal
- Successfully upgraded to 2004 NSR consent decree requirements
- Achieved all goals with existing equipment



# Culley Performance


**WFGD Commissioned in 1994**

**Vectren Has Increased Boiler Load and SO<sub>2</sub> Loading**

	<b>Design</b>	<b>Actual</b>
<b>Boiler Load (MWe)</b>	<b>375</b>	<b>400</b>
<b>SO<sub>2</sub> Loading (lb/MMBtu)</b>	<b>6.5</b>	<b>10</b>
<b>SO<sub>2</sub> Removal Rate</b>	<b>95%</b>	<b>95%</b>



# Operational History (Jan. '03 – Sept. '05)




**Ave =**  
**0.308**

**New**  
**Limit =**  
**0.17**



# Upgrade Results – Long Term Performance



# Thank You

## Questions ??





BabcockPower



BabcockPower  
SERVICES



RILEYPower  
A Babcock Power Inc. Company



TEI CONSTRUCTION SERVICES, INC.  
A Babcock Power Inc. Company



Boiler Tube Company of America  
A Babcock Power Inc. Company



BabcockPower  
ENVIRONMENTAL

