

Worldwide Pollution Control Association

ESKOM Scrubber Seminar
April 12th – 13th, 2007



Visit our website at www.wpca.info

**W
P
C
A**

State-of-the-art FGD Technology

An Independent View of a Long-term FGD-Experience of an Operator and Owner's Engineer



Dr. Hermann Brüggendick

STEAG encotec

Development Emission Regulation in Germany

1964 Technical Instructions on Air Quality Control (Clean Air Act)
Revised 1974 / 1984

Requirements of emissions monitoring systems

1974 Emission Protection Law (BImSchG)

1983 **Large Combustion Plants Directive** (LCPD) – 13. BImSchV

Requirements for continuously operating emission monitoring systems
 $\text{SO}_2 < 400 \text{ mg/m}^3$ (i.N.)dry, SO_2 – Removal efficiency $> 85 \%$


20.7.2004 Regulation for Large Combustion and Gasturbine Plants (13. BImSchV)

Reheating of flue gas downstream FGD cancelled
 $\text{SO}_2 < 300 / 200 \text{ mg/m}^3$ (i.N.) dry

Emissions Limits for existing and new Plants in Germany

Emission-Limits (EL)	German National Regulations		
	old, since 1983	existing- /new plants new, since 20.07.2004	
	EL daily average value	EL daily average value	EL 1/2 h - average value
	<ul style="list-style-type: none"> No daily average value > EL 	<ul style="list-style-type: none"> No daily average value > EL 	<ul style="list-style-type: none"> No 1/2 h average value > 2 x EL
	plus		
	<ul style="list-style-type: none"> No 1/2 h average value > 2 x EL 		
	plus		
	<ul style="list-style-type: none"> 97% of 1/2 h average values $\leq 1.2 \times EL$ 		
Emission Limits (EL)	mg/m ³ i.N. dry, 5/6% O ₂	mg/m ³ i.N. dry, 6% O ₂	
• Dust	50	20 / 20	60 / 40
• NOx	200	200 / 200	400 / 400
• SO ₂	400	300 / 200	600 / 400
• Hg	-	0.03	0.05

STEAG's Development of FGD-Technology



1968	5,000 m ³ /h (stp)	Pilot plant at STEAG power station Lünen
1971	140,000 m ³ /h (stp)	Pilot plant at STEAG power station Lünen (Bischoff-Process)
1974	150,000 m ³ /h (stp)	Pilot plant at STEAG power station Lünen (ACT - Process)
1981	750 MW	First commercial FGD plant at STEAG power station Bergkamen
1999	10,000 m ³ /h (stp)	Pilot plant at STEAG power plant Herne (Ammonia water process)
Today	~ 9,000 MW	FGD Operating experience Total capacity of operational FGD - system
	> 2.0 million	Total FGD operating hours
	> 25 years	FGD operating experience
	~ 10,000 MW	Total capacity of designed STEAG FGD - system
	> 12,000 MW	Total capacity of internat. engineering services as Owner's engineer
	> 20,000 MW	Total capacity of FGD retrofits

STEAG Power Stations with wet FGD-Installations



encotec

Power Stations	Capacity [MW]	Furnace System	FGD Design Data				Operation since
			SOx-Inlet Conc. [mg/m ³ normal cond.]	Process / Absorbent	Byproduct (Gypsum) [t/h]	Approx. Operat. Hours (until 04/2007)	
Bergkamen	750	dry ash	2,600	wet scrubber lime	18.0	172,000	Oct. 81
Voerde A	760	dry ash	2,600	wet scrubber lime	14.5	146,000	Oct. 82 / 2005
Voerde B	760	dry ash		wet scrubber lime		146,000	
Herne 1/2	2 x 150	slag tap	4,300	wet scrubber lime/limestone	13.5	124,000	Jan 87 - Jan 04
Herne 3	1 x 300	slag tap				137,000	
Herne 4	500	dry ash	4,650		30.0	129,000	Sep 89
Luenen 10	150	dry ash	3,850	wet scrubber lime/limestone	6.0	119,000	Apr 88
Luenen 11	350	slag tap		wet scrubber lime/limestone	12.5	139,000	
Walsum 7	410	dry ash	4,000	wet scrubber lime/limestone	6.5	44,000	Oct. 88
Walsum 9	150	slag tap		wet scrubber lime/limestone	18.0	150,000	
West 1	350	slag tap	3,850	wet scrubber lime/limestone	12.5	139,000	Feb 88
West 2	350	slag tap		wet scrubber lime/limestone		139,000	
Leuna	3 x 162 t/h 115 electricity	heavy oil	7,000	wet scrubber lime/limestone	7.0	78,000	Dez 96
Godorf	230 steam 103 electricity	heavy oil	7,000	wet scrubber lime/limestone	8.0	21,500	Sep 04
Bexbach	775	dry ash	2,250	wet scrubber lime/limestone	17.0	134,000	Apr 88
Fenne 1	300	dry ash	2,200	wet scrubber lime/limestone	6.5	134,000	Feb 88
Fenne 2	230	dry ash		wet scrubber lime/limestone	5.0	134,000	
Weiherr 3	710	dry ash	2,250	wet scrubber lime/limestone	15.5	139,000	Feb 88
Iskenderun 1	660	dry ash	33,200	wet scrubber lime/limestone	24.5	25,000	2003
Iskenderun 2	660	dry ash		wet scrubber lime/limestone		25,000	
Σ 9,000 MW						Σ 2,300,000	


Advantages and Disadvantages of the different FGD Systems

	<i>Dry/Semidry FGD</i>	<i>Limestone FGD</i>	<i>Ammonia FGD</i>
Features	<ul style="list-style-type: none"> • Low/medium sulphur • Removal efficiency 90-95% • Smaller flue gas flow • No liquid waste • Small footprint • Low capital costs 	<ul style="list-style-type: none"> • High sulphur • Removal efficiency > 95% • Larger flue gas flow • Rather complex system • Low cost reagent • By-product flexibility • High maintenance costs • Rather high capital costs 	<ul style="list-style-type: none"> • High sulphur • Removal efficiency > 95% • Larger flue gas flow • No liquid waste • High cost reagent • High value by-product • Low maintenance costs • High capital costs
Reagent	Quick lime	Limestone	Ammonia
By-product	Non-marketable mixture of ash, reagent, calcium sulphite and calcium sulphate	Ash from ESP and marketable gypsum	Ash from ESP and marketable fertiliser ammonium sulphate

Flue Gas Desulphurization Dry / Semidry FGD






Dry Desulphurization Process




Desulphurisation with Wet FGD Limestone / Lime - Sum Reactions -

Desulphurisation




Oxidation



Calcium sulfite


Gypsum dihydrate

Wet FGD – Process Flow Sheet Limestone Process




Wet FGD – Process State-of-the-art Arrangements

Variant 1
Absorber
with Flue Gas Reheating




Variant 2
Discharge
via Cooling Tower




Wet FGD – Process State-of-the-art Arrangements

Variant 3
Discharge
via Wet Stack



Variant 4
Combined Absorber/Stack
Arrangement



Comparison of Quicklime / Limestone

Operating and Cost Parameter	Absorbent	
	Quick Lime	Limestone
Power Consumption of scrubber pumps	60 - 75%	100%
Mol. Stoichiometric ratio	< 1.01	1.02 – 1.04
Gypsum Quality		
Purity	98 - 99%	95 - 98%
Whiteness	> 80%	~ 60%
Solid waste Generation from FGD effluent treatment	60 - 70%	100%
Maintenance Cost	80 - 90%	100%
Transport cost of absorbent	54%	100%

Coal Qualities for STEAG Power Stations


Coal Range		
LCV	MJ/kg	19.5 – 25.7
Ash	%	6 – 35 (45)
Water	%	8 – 12 (14)
Volatiles	%	30 - 40
Sulfur	%	0.5 – 1.7
Grindability	°H	50
Softening point	°C	> 1200

STEAG Power Plant with dry FGD Power Plant Mindanao, Philippinen

Commissioning	2006
Installed	
Capacity (gross)	210 MW
Project volume	305 Mio US\$
Fuel	Hard coal



Flue Gas Desulphurization Dry FGD Power Plant Mindanao



Flue Gas Desulphurization Dry FGD Power Plant Mindanao

Fabric
Filter



Comparison of 4 STEAG Power Plants with wet FGD

Plant No. 1
The 500 MW STEAG Power Plant



Plant No. 2
The 660 MW STEAG Power Plant



Plant No. 3
The 760 MW STEAG Power Plant / FGD Retrofit




Plant No. 4
The new 750 MW STEAG Power Plant (CCEC)



Plant No. 1 The 500 MW STEAG Power Plant



The 500 MW STEAG Power Plant



Boiler Height	104 m
Steam Mass Flow	420 kg/s
Power Output gross	500 MW
Steam Pressure	254 bar
Steam Temperature	535°C
Calorific value	19.5 MJ/kg
Sulfur	1.2 %
Ash	35%

\dot{V}	:	1,550,000	m³(i.N.)/h_{wet}
\dot{V}	:	1,400,000	m³(i.N.)/h_{dry}
SO₂ in	:	3,300	mg/m³ (i.N.)
SO₂ out	:	200 (400)	mg/m³ (i.N.)
HCl	:	490	mg/m³ (i.N.)
HF	:	80	mg/m³ (i.N.)
Dust	:	50	mg/m³ (i.N.)

FGD of the 500 MW STEAG Power Plant

FGD




FGD of the 500 MW STEAG Power Plant


Flue gas
Preheater



FGD of the 500 MW STEAG Power Plant / Flue Gas Line



FGD of the 500 MW STEAG Power Plant / Absorber



Plant No. 2 The 660 MW STEAG Power Plant




The 660 MW STEAG Power Plant



The 660 MW STEAG Power Plant

\dot{V}	:		2,000,000	$\text{m}^3(\text{i.N.})/\text{h}_{\text{wet}}$
\dot{V}	:		1,850,000	$\text{m}^3(\text{i.N.})/\text{h}_{\text{dry}}$
SO_2 in	:		1,460	mg/m^3 (i.N.)
SO_2 out	:		350	mg/m^3 (i.N.)
HCl	:	40	→	1 mg/m^3 (i.N.)
HF	:	12	→	<0.5 mg/m^3 (i.N.)
Dust	:	< 142	→	10 mg/m^3 (i.N.)


Boiler Height	93 m
Steam Mass Flow	524 kg/s
Power Output gross	660 MW
Steam Pressure	185 bar
Steam Temperature	541°C
Calorific value	25.8 MJ/kg
Coal	South African Coal




FGD of the 660 MW STEAG Power Plant



FGD of the 660 MW STEAG Power Plant / Plant Overview




FGD of the 660 MW STEAG Power Plant / Absorber



Plant No. 3
The 760 MW STEAG Power Plant / FGD Retrofit



The 760 MW STEAG Power Plant / FGD Retrofit




Boiler Height	85 m
Steam Mass Flow	600 kg/s
Power Output gross	760 MW
Steam Pressure	206 bar
Steam Temperature	530°C
Calorific value	27.3 MJ/kg
Coal	Import (South African)

\dot{V}	:	2,434,000	m³(i.N.)/h_{wet}
\dot{V}	:	2,242,000	m³(i.N.)/h_{dry}
SO₂ in	:	2,420	mg/m³ (i.N.)
SO₂ out	:	<200	mg/m³ (i.N.)
HCl	:	143	→ 1 mg/m³ (i.N.)
HF	:	16.5	→ <0.5 mg/m³ (i.N.)
Dust	:	9.5	→ 20 mg/m³ (i.N.)

The 760 MW STEAG Power Plant / FGD Retrofit

Initial situation



The 760 MW STEAG Power Plant / FGD Retrofit Reasons for the Refurbishment / Project Aims

- Improvement of the environmental situation
 - New FGD retrofit (SO₂: 400 → 200 mg/m³ (i.N.)_{dr})
 - Optimisation ESP (Dust: 50 → 20 mg/m³ (i.N.)_{dr})
- Capacity increase (710 MW → 760 MW, 2 x 50 MW, utilization of the permitted furnace thermal capacity)
- Efficiency improvement
- Reduction of the costs of maintenance
- Improvement of the profitability
- Improvement in competition

The 760 MW STEAG Power Plant / FGD Retrofit

New FGD without Bypass

- Boiler/ Turbine:** Utilization of existing reserve capacity
- DeNOx:** Utilization of existing reserve capacity


ESP: Optimisation, static reinforcement

Raw gas ducts: Static reinforcement


ID-Fans: Retrofit, capacity increase

FGD: New scrubbers

Stack: New wet stack



The 760 MW STEAG Power Plant / FGD Retrofit



State-of-the-art FGD Plant

- One absorber per unit
- ID-fan for total pressure rise
- No bypass, no dampers in the flue gas line
- 4 spray levels (PP), 1 with variable speed
- 3 stage mist eliminator
- Flue gas discharge via “wet stack”

Stand
01. November 2002

The 760 MW STEAG Power Plant / FGD Retrofit New FGD

- One scrubber per unit, without bypass, without dampers
- Existing ID fans for total pressure rise, capacity increase
- Diameter 17 m, height approx. 36 m
- Sump volume approx. 2,400 m³
- Steel rubber lining
- Raw gas inlet Alloy 59
- 4 Spray levels, design in polypropylen (PP)
- Circulation pipe in GRP
- 3 Stage mist eliminator




The 760 MW STEAG Power Plant / FGD Retrofit New Wet Stack

- Flue gas discharge via “wet stack”
- Total height 230 m
- Steel concrete shaft with
2 flue gas pipe of GRP
- Clean gas velocity < 18 m/s at 110% load
- Selective condensate discharge
- Avoidance of interior installed components




The 760 MW STEAG Power Plant / FGD Retrofit


Emergency
water
injection



The STEAG 760 MW Power Plant / Flue Gas Line FGD



The STEAG 760 MW Power Plant / Absorber FGD




Plant No. 4
The new 750 MW STEAG Power Plant (CCEC)

Clean
Competitive
Electricity from
Coal



The new 750 MW STEAG Power Plant (CCEC)




Boiler

The new 750 MW STEAG Power Plant (CCEC)

State-of-the-art FGD Plant

- One absorber
- ID –fan for total pressure rise
- No bypass, no dampers in the flue gas line
- 4 spray levels (PP), 1 with variable speed
- 3 stage mist eliminator
- Flue gas discharge via cooling tower



Clean Competitive Electricity from Coal (CCEC)



■ Lowest Investment

- standardization / modularization
- reduction of costs by lessons learned
- application of proven technology but mono components

■ Shortest Construction Period

■ High Availability


■ Low Maintenance Costs

- quick repair and overhauls, long intervals
- spare parts on stock or on call at supplier
- maintenance friendly design
- skilled and trained team

■ Optimal Logistics (plant sites)

The new 750 MW STEAG Power Plant (CCEC)

Air / Flue Gas Schematic Drawing



\dot{V}	:	2,200,000	m ³ (i.N.)/h _{wet}
\dot{V}	:	2,000,000	m ³ (i.N.)/h _{dry}
SO ₂ in	:	2,200	mg/m ³ (i.N.)
SO ₂ out	:	200	mg/m ³ (i.N.)
HCl	:	< 340	→ <10 mg/m ³ (i.N.)
HF	:	< 116	→ <1 mg/m ³ (i.N.)
Dust	:	20	→ <20 mg/m ³ (i.N.)

Comparison of different FGD Plants

Benchmarking Figures	Dim MW	No. 1 Reheat/Stack 500	No. 3 Wet stack 2 x 760	No. 2 Wet stack 2 x 660	No. 4 Cooling tower 750
Comm.		1989	1982 / 85	2003	2009
Refurbishment/ Retrofit		—	2005	—	—
Plant Efficiency net	%	38.9	38,6	40,23	45,1
Boiler Efficiency net	%	93.2	93,2	93,4	94,5
Sulfur Range	%	< 1.55	1,22	< 1,5	0,5 - 1,5
Spec. Steam Flow	kg/s/MW _{net}	0.93	0.86	0.87	0.81
Spec. Fuel Flow	kg _{Fuel} /s / kg _{Steam} /s	0.141	0.110	0.107	0.114
Spec. Fluegas Mass Flow	kg/s/MW _{net}	1.22	1.29	1.03	1.04
Scrubber Design					
1. Absorbens	—	Quicklime	Quicklime	Limestone	Quicklime
2. L/G Ratio	l/m ³	12.6	11.5	12.4	11.9
3. Velocity gas zone	m/s	2.6	3.8	4.0	< 4
4. Pressure drop	mbar	45	16.5	13	14
5. Gas Temp. beh. Scrubber	°C	46	52	54	50-52
6. Internal Power Consumption	MW	7.0	6.3	5.0	3.5
Equivalent hours of full load Operation	h/a	6,800	approx. 7,000	6,600	approx. 7,000

Water resources

Main data Power Plant	DIM	Mindanao	Flue gas reheat No. 1	Wet Stack No. 2	Wet Stack No. 3	Cooling Tower No. 4
Power Output gross	MW	210	500	2 x 660	2 x 760	750
Water resources						
Quicklime / Limestone	t/h	QL	QL 6,5	LS 5,9	QL 5,9	QL 4,5
Additional Water	m ³ /h	30	90	350	330	150
	l/MWh	143	180	265	217	200
Waste water	m ³ /h	No	40	80	75	40
	l/MWh	No	80	61	49	53
Liquid/fluegas ratio (L/G-Ratio)	l/m ³	No	12.6	12.4	11.5	11.9

Selection of Desulphurization Processes

- General question: Recovery of byproduct \Rightarrow gypsum or landfill
- Semi dry system:
 - \Rightarrow Product has to be landfilled
 - \Rightarrow Problems with $S > 2\%$ in coal
 - \Rightarrow Operating experience up to 350.000 m³/h flue gas for one line
 - \Rightarrow Offers up to 750.000 m³/h flue gas for one line
 - \Rightarrow For 1000 MW min 4 lines necessary
 - \Rightarrow Water 20 – 40 l / 1000 m³/h Flue gas (~ 0.14 l/kWh)
- Wet system:
 - \Rightarrow Produced gypsum marketable
 - \Rightarrow High operating experience with high throughput per line
 - \Rightarrow Water 60 – 80 l / 1000 m³/h Flue gas (~ 0.2 l/kWh)
 - \Rightarrow Waste Water 40 – 80 m³/h ($\sim 0,06$ l/kWh)

Comparison of FGD-Processes

System	Efficiency	Ca/S	Investment (West European basis)
Dry	80 - 90 %	< 2	65 - 78 US\$/KW _{el} (50 – 60 €/KW _{el})
Semi-Dry	90 - 97 %	1.2 -1.5	65 - 78 US\$/KW _{el} (50 – 60 €/KW _{el})
Wet	90 - 99 %	1.05	85 - 115 US\$/KW _{el} (75 – 90 €/KW _{el})

- Wet-system if:
 - High S-content in coal
 - Gypsum can be sold
 - Landfill cost for product of semi dry process
 - Cost benefit for high flue gas throughput
 - Water resources are sufficient

- Semi dry-system if:
 - Lower desulphurization efficiency is asked for
 - Product has to be landfilled
 - Water resources are insufficient

STEAG International Reference FGD Plants as Owner's Engineer

• Ratcliffe Power Station	UK	4 x 500	MW
• Chemnitz	Germany	120	MW
• Orhaneli Power Plant	Turkey	210	MW
• Mae Moh Power Plant	Thailand	4 x 150	MW
• Yatagan Power Plant	Turkey	3 x 210	MW
• Beijing Power Plant	China	330	MW
• Banshan Power Plant	China	250	MW
• Chongqing Power Plant	China	400	MW
• West Burton Power Station	UK	4 x 500	MW
• Maritza	Bulgaria	4 x 210	MW
• Cottam Power Station	UK	4 x 500	MW
• Pego	Portugal	2 x 300	MW



STEAG Power Stations Services

STEAG can provide unique services as the „Owner’s Engineer“ transferring extensive long-term FDG- and SCR-operating experience to our customers:

- **Optimal process, arrangement and equipment design**
- **Design review**
- **Material and equipment selection**
- **Material handling**
- **Maintenance assistance**
- **Measuring services**
- **SCR catalyst management**
- **Operator training in our plants**



STEAG Experience with different FGD - Solution

STEAG has experience with several FGD Technologies:

- Lurgi Lentjes
- Noell / KRC
- Marubeni/ABB
- FISIA Babcock, Steinmüller
- FLS/MHI
- John Brown
- Hitachi
- AE Austrian Energy
- RWE Solutions
- Alstom
- Ebara

