

REINHOLD ENVIRONMENTAL Ltd.



2011 APC Round Table & Expo Presentation

July 11-12, 2011, in Cleveland, OH / Hosted by FirstEnergy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.

Air Pollution Control Panel

Round Table Panel Discussion:

This panel will discuss the impact of the newly proposed HAPS rule on unit operation, condensable (SO_3/HCl) mitigation strategies, and the potential challenges to existing environmental equipment.

APC Reinhold Environmental Round Table

Panel Members

- Douglas Ritzenthaler – AEP
- Robert Bryne – FMC Corporation
- Joe McCain – Southern Research, Sr. Staff Physicist
- Mike Theil – Nol-Tec
- Mark Thomas - Consultant
- Ron Triscori – Consultant

APC Reinhold Environmental Round Table

Key HAPS rule Emission Targets

- Table 2 to Subpart UUUUU of Part 63 (p. 25126)
 - Emission Limits for Existing Utility Steam Generating Units
- Coal-fired unit designed for: Coal > 8,300 Btu/lb.
 - HCl: 0.0020 lb / MWh
 - SO₂ As a surrogate for HCl - SO₂ limit: 0.20 lb/MMBtu
 - Total Particulate (PM): 0.030 lb/MMBtu or 0.30 lb/MWh
 - Hg 1.0 lb/TBtu or 0.008 lb/GWh


Proposed HAPS Rule

- Impact on existing equipment
 - FGD upgrades for SO₂ capture when used as a surrogate for HCl
 - ESP / Baghouse upgrades for PM
- Addition of New Equipment
 - SDA, NID, Wet FGD
 - Replace existing ESP with baghouse?
- CEMS
 - HCl monitors

Portable DSI System by Nol Tec



Chemistry/ NSR Calculation for Trona Reacting with SO₃



Molecular Weight of Trona = 226 lb/lb mole

Molecular Weight of SO₃ = 80 lb/lb mole

Equation Weight of Trona = 2 lb moles x 226 = 452 lb

Equation Weight of SO₃ = 3 lb moles x 80 = 240 lb

*Assumes no insolubles


$$\text{NSR} = \frac{\text{Moles of Na}_2\text{O injected}}{\text{Moles of SO}_3 \text{ inlet}}$$

Handling Trona Before Injection

1) **Use a Dehumidification system for loading/transloading** preferably at 100 F to avoid moisture pickup and obtain good flowability characteristics.


2) **Keep Trona Well Below 130 Deg F**

Trona calcination mechanism has been proven to occur in stages:



No CO₂ and most of the H₂O is removed forming Wegschideirite (First stage of the reaction), which begins forming at 130 F
Therefore avoid handling trona in a manner which raises the temperature to 130 Deg F

Dehumidification System



Chiller /Condenser

Dehumidifier


Blower

After Cooler

Fabric Filter

Compliance with emission regulations are to be based on total particulate *including condensables*. In the case of fossil-fuel fired utility boilers, H_2SO_4 is the dominant condensable and, in many cases, may dominate the total particulate emissions.

- The Chemkin Homogeneous reaction model can be used to predict the SO_3 concentration at the inlet to the convective section of the boiler.
- Catalytic SO_3 formation with iron as the catalyst begins in the convective pass adding to its concentration.
- Uptake by ash reduces the SO_3 concentration and can proceed concurrently with formation.
- The final SO_3 concentration exiting the boiler is strongly influenced by the oxygen concentration in the convective pass.



Measured boiler exit O₂ and SO₃ concentrations. The boiler was firing a 3.8 % sulfur Eastern bituminous coal.