

REINHOLD ENVIRONMENTAL Ltd.



2011 APC Round Table & Expo Presentation

July 11-12, 2011, in Cleveland, OH / Hosted by FirstEnergy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.

ESP/FF Design Considerations for EGU MACT Compliance

2011 Reinhold APC Round Table

Steve Francis

Cleveland, OH 12 July 2011

ALSTOM

- Regulatory Requirements
- Overall Plant System Design
- Existing PM Collection System Design
- Up-Grading Existing PM Collection System
- Add a New PM Collection System
- Add a New DFGD System
- Conclusions



- Compliance with the new MACT Requirements
 - Meet the new Total PM Emissions Requirements
 - Filterable particulate matter
 - Plus condensed matter including SO₃
 - Meet the new Hg Emissions Requirements
 - Meet the NO_x & SO₂ Requirements



Overall Plant System Design

- Type & age of boiler
- Variations in coals fired
- Boiler design versus operating capacity
- System equipment arrangement (i.e. Boiler, economizer, SCR, APH, ESP, ID Fan, etc.)
- Flue gas temperature, pressure & composition
- Gas path flow distribution arrangement
- Performance of the existing system



Existing PM Collection System

- ESP size & arrangement
 - Hot side
 - Cold side
- ESP design & capacity
 - Age & condition
 - SCA of ESP & type of AVC system
 - Up-grade possibilities?
- Fabric Filter size & arrangement
 - Reverse gas; A/C ratio
 - High ratio; A/C ratio
- FF design & capacity
 - Age & condition
 - Cleaning system design & performance
 - Media selection



- Can the up-graded equipment meet the new requirements?
- Is there space available for the changes required?
- What is the required cost & time for the conversion?
- Is sufficient power and fan capacity available?
- What is the OPEX for the new system?
- Any impacts on existing plant operations (i.e loss of sale of ash)?



Add a New PM Collection System

- Selection of the system design to be added must consider the new regulations
- Is there space available for the new system design?
- How & when can the system be tied into plant operations?
- Increased power & system pressure drop must be addressed
- Ash handling system modifications will be necessary
- What is the OPEX for the new system?
- Be careful with the carbon/ash ratio to avoid problems



Add a New DFGD System

- Considering the issues on the previous slide, adding a DFGD system may be a good choice
- The system can reduce PM, SO₂, SO₃, HCL and HF emissions
- With the addition of KNX and or PAC, Hg emissions requirements can be met
- Some of the risks regarding system operation are eliminated with DFGD systems



- It is important to understand what all of the required emissions from the plant must be before deciding what to do to address PM emissions
- Evaluation of the total plant system regarding size, arrangement and performance will impact the approach to meeting MACT requirements
- Fuel variations, flue gas composition and flow distribution will impact the system design
- Space availability, outage time, tie-in to plant operations could impact the approach to meet the regulations
- Modifications to existing systems versus addition of new equipment must be based on overall systems evaluations
- Adding a DFGD system with means to reduce Hg emissions may be the best choice

www.alstom.com

ALSTOM