

REINHOLD ENVIRONMENTAL Ltd.



2010 APC Round Table & Expo Presentation

July 18-20, 2010, in Concord, NC / Hosted by Duke Energy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



Small Boiler FGD Systems

Presentation to:



APC Round Table

July 20, 2010


- | Regulatory Overview
- | Small Boiler Market Overview
- | Conventional Small Boiler FGD Systems
- | URS Co-Flo™ Small Boiler FGD System
 - ü Design
 - ü Performance
 - ü Schedule

Regulatory Overview

- | URS believes that future regulations will result in further reduction in all major Air Pollutants identified by the EPA or the Administration
 - ü **SO₂** CAIR, NAAQS, CAAA 2010
 - ü **NO_x** CAIR, NAAQS, CAAA 2010
 - ü **PM 2.5** NAAQS
 - ü **Hg** CAMR, CAAA 2010
 - ü **HAPs** New HAPs regulations
 - ü **Ash** New Pending Regulatory Classification
- | By 2020, URS expects that all Coal Fired Power plants will require environmental controls

CAIR is in full operation and will remain in effect until a replacement is put in place

- | Finalized in 2005 and went into effect in 2006
- | Affects 28 states + DC
- | Annual SO₂ and NO_x Phase I requirements in place
 - ü Annual SO₂ cap,
 - û 5.2 million tpy in 2010
 - û 3.9 million tpy in 2015
 - ü Annual NO_x cap
- | Expect CAIR Phase II limits to be replaced by new Transport Rule



- | Introduced July 6, 2010
- | Affects 31 states + DC
- | Expected to go into effect 2012
- | Emission reduction targets by 2014 based on 2005 emission levels
 - ü 71% or 6.3 million tons per year of SO₂
 - û From 10.2 to 4.1 million tons per year
 - ü 52% or 1.4 million tons per year of NO_x

- | Clear Air Act Amendment of 2010 (March) – Proposes the following Reductions
 - ü Reduce SO₂ by 80 Percent
 - û Cut SO₂ emissions by 80 percent (from 7.6 million tons in 2008 to 1.5 million tons in 2018). A 3.5 million ton annual cap would be in force 2012-2014.
 - ü NO_x by 53 Percent,
 - û Cut NO_x emissions by 53 percent (from 3 million tons in 2008 to 1.6 million tons in 2015).
 - ü Hg by 90 Percent
 - û Cut mercury emissions by at least 90 percent no later than 2015.
 - û Mercury emissions would utilize the maximum available control technology (MACT).
- | Establishes nationwide trading systems for SO₂ and NO_x emissions by January 1, 2012.


- | National Ambient Air Quality Standard - NAAQS
 - ü Reduce Ambient SO₂
 - ü From 300 ppb 8 Hr rolling average to 50-100 ppb (depending on attainment and non-attainment status) 1 hr average.
- | Reduce Ambient NO_x
 - ü By nominally 50 percent with similar requirement in averaging
- | NAAQS reductions drive compliance at nearly every stationary source
- | Changes from 8 hr to 1 hr averaging time will drive AQCS system reliability requirements

- I EPA Evaluation of Coal Combustion Byproducts
 - ü Evaluating Coal Ash and FGD Byproduct Classification
 - û CCPs may be classified as hazardous if landfilled
 - û CCPs may be classified as non-hazardous if sold
 - ü Also Evaluating Storage of Ash
 - û Wet storage of ash typical throughout the Industry
 - û Being evaluated in wake of TVA Kingston accident
 - û Industry conversion from wet to dry landfills would be the expected outcome


SO₂ Control Market Overview

Number of Coal-fired Boilers

- | 78 percent of U.S. boilers are less than 400 MWe
- | 760 boilers are less than 400 MWe
- | Boilers below 400 MWe produce 40% of coal-fired generation




Scrubbed Boilers




Conventional Small Boiler SO₂ Control Technologies

- | 1st tier
 - ü Conventional Dry FGD Systems
 - û Lime
 - ü Circulating Dry FGD Systems
 - û Lime
 - ü Wet FGD Systems
 - û Limestone
- | 2nd Tier
 - ü Furnace Injection
 - û Lime or limestone
 - ü Duct Injection
 - û High surface area lime

Furnace Injection




- | Very low capital
- | Low removal
 - ü 30 to 60 percent
- | Poor limestone utilization
- | Slagging issues
- | Heat rate impacts
- | Fly Ash quality




- | Low Capital
- | Moderate removal
 - ü 50 to 70 percent
- | Poor lime utilization
- | Expensive reagent
 - ü High surface area lime
- | Duct deposition and scaling

Circulating Dry FGD – Turbosorp^R




- | Circulating fluid bed scrubber
 - ü Lime based system
 - ü Fluid bed with no rotating parts
 - ü Baghouse
- | 97% SO₂ removal up to 5 lb/MM btu fuel
- | Multi-pollutant control
- | Dry byproduct
- | High vertical profile
- | 10-14 inch pressure drop

Circulating Dry FGD – NID™



- | Circulating fluid bed scrubber
 - ü Lime based system
 - ü Baghouse inlet duct - absorber
 - ü Baghouse
- | 90 – 98% removal on low to high sulfur coals
- | Multi-pollutant control
- | Dry byproduct
- | Very high mass loadings
- | 10-14 inch pressure drop

Wet FGD - FlowPac




- | Circulating wet scrubber
 - ü Limestone based
 - ü Gypsum byproduct
- | Above 99% SO₂ removal
- | High pressure drop
 - ü 12-24 inches
 - ü No recycle pumps

Co-Flo™
FGD System Designed
Specifically for Smaller
Boilers

Small Boiler Characteristics

Forced Draft
Positive
Pressure Boiler




Small
Marginal
ESP

Low
Elevation
Stack
Breach


Small Boiler FGD Wish List

- | No pressure drop
 - ü Avoid balance draft conversion and costly structural reinforcement of boiler and ductwork
- | Multi-pollutant control
 - ü Greater than 98% SO₂ removal
 - ü Greater than 90% Hg⁺ removal
- | Low cost reagent
 - ü Limestone
- | Marketable or disposable byproducts
 - ü Gypsum
 - ü Fly ash
- | Zero liquid discharge
- | Reusable stack
- | Low capital cost
- | Short project schedule


Typical New Scrubber PFD




Co-Flo™ PFD (Patent Pending)




- | Integrated Process Island
 - ü Reagent prep
 - ü Absorber
 - ü Dewatering
- | Integrated Structure
 - ü No free standing buildings
- | Low Profile
 - ü 40 ft




- Conventional recycle pumps and spray headers
- Air blowers for forced oxidation and recycle tank agitation
- No bleed pumps




- | Co-current spray headers
 - ü High velocity
 - ü Pressure rise – no pressure drop
- | BES and typical horizontal mist eliminator






Static + Dynamic Pressure


- I Duct work flexibility
 - ü Straight through
 - ü In and back




- | Reagent prep
 - ü Preground limestone or lime
- | Dewatering



- | Marketable byproducts
 - ü Hydroclone
 - ü Belt filter
- | Disposable byproducts
 - ü Hydroclone
 - ü Pug mill



- | Integrated Process Island
 - ü Limited piping and electrical cable runs
- | Limited rotating equipment
 - ü Full redundancy
- | No process tanks
 - ü One sump
 - ü No free standing tanks and associated equipment



Performance

I Conventional Performance

ü Sulfur Dioxide

- û Low to high sulfur coal
- û Greater than 98 percent producing a gypsum byproduct

ü Pressure drop

- û Absorber – 1 inch pressure rise
- û System – less than one inch pressure drop
- û Higher removal or higher coal sulfur results in higher pressure rise

ü Mercury


- û Greater than 90 percent removal of oxidized mercury

ü Particulate

- û 90 percent measured

Schedule

- | Modular Design
- | Prefabrication of 10' by 40' panels
- | Delivery by truck, rail or barge



I Fast Track Schedule

- ü 24 months total project schedule

- Prefabricated absorber panels

- û Standardized

- I 100, 200, 300 MWe designs

