

REINHOLD ENVIRONMENTAL Ltd.



## **2014 NO<sub>x</sub>-Combustion Round Table & Expo Presentations**

February 10 & 11, 2014, in Charlotte, NC / Hosted by Duke Energy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



# Presentation Topics

- Nebraska Utility Case Example
  - Plant Operation and SCR Overview
  - SCR Performance and Initial Design
  - SCR Operation from 2011 - 2014
  - SCR Improvements
  - Current SCR Operation



# SCR Design and Operational Issues


- Nebraska Utility SCR System Problem Overview
  - Non-Universal Reactor Design
  - High Catalyst Pluggage ( $\approx 90\%$ )
  - Step Change Drop in Catalyst Activity
  - LPA Deposition and Buildup
  - Catalyst Erosion and Mechanical Strength
  - High Ammonia Slip ( $\approx 10 - 14$  ppm slip)
  - Premature Unscheduled Outage Needed to Support Catalyst Change Out Needs

# Nebraska Utility Case Example

- 740 MW Commercial Operation 2009
- 100% PRB Coal Fired
- PC Boiler
- Low NOx Burners
- SCR
- Spray Dry Absorber/Fabric Filter
- Powder Activated Carbon-Injection



# Nebraska Utility SCR Design



- High Dust
- 2+1 Layer Arrangement
- 2 Reactors
- Square Hood

# Original Catalyst Supply (By Others)

Catalyst Type	Honeycomb
NO <sub>x</sub> Reduction	71% (0.22 to 0.064 lb/MMBtu)
SO <sub>2</sub> to SO <sub>3</sub> Conversion Rate	1.0% per Layer (2% for 2 Layers)
Catalyst Pitch	6.9 mm (22 x 22 cell)
Catalyst Inner Wall Thickness	0.6 mm (Thin wall)
Catalyst Length	922 mm
Module Arrangement per Layer	9 x 10
Module Dimension	1889 x 946 x 1207 mm *Non-universal plan dimensions

# Catalyst RFQ For Spare Layer 2010


- Original Supplied Catalyst was Guaranteed for 16,000 hrs
- Fall 2010 RFQ for Spare Layer of Catalyst
- Installation of the Catalyst would occur during the Spring 2011
- Based on Modeling and Testing the Ammonia Slip was approximately 4 – 5 ppm at the time of the Spring Outage

# CERAM Spare Layer Catalyst Supply


- CERAM Wins Competitive Bid to Supply Spare Catalyst Layer
  - Catalyst to be Installed in Spring of 2011 (20,200 hrs)
  - Catalyst Installed into Third “Spare” Level
  - Larger Catalyst Pitch (7.4 mm) Selected by Utility
    - ◆ Based on Pluggage and DP Concerns
- At this Time, CERAM was not Fully Aware of all Potential Issues and Problems Related to the SCR Operations
- CERAM Discovers that Non-Universal Reactor Design Requires Slightly Smaller Catalyst Module Size for Limited Accessibility and Non-Universal Reactor Design

# SCR Plan Arrangement

- Fixed Top Hung Design Catalyst Support Framing Required Special Sized Module Frames
- Design Does Not Utilize Reactor Wall Seals
- 32 mm Clearance Between Catalyst Modules for Seals




Reactor Wall



Hanger Straps


# SCR Module Sizing

- Fixed Catalyst Support Framing  
Required Special Sized Module Frames
  - CERAM Standard Module Sizing  
(960 x 1900 x Height)
  - Nebraska Utility Module Size  
(945 x 1890 x Height)
- Limited Regeneration Options
  - Can Only Regenerate Their Own Catalyst Due to Size Constraints
- Limited Module Height
  - Loading Door Size



# SCR Plan Arrangement & Module Sizing

- Fixed Catalyst Support Framing Required Smaller Sized Module Frames
- No Module Wall Seals



# SCR Module Sizing

- Limited Module Height
  - Loading Door Size



# CERAM Catalyst Management


- Shortly after Catalyst Purchase, Utility Sends RFQ for Catalyst Management Services
- CERAM Wins Competitive Bid
- Catalyst Management Begins with CERAM in Early 2011
  - Reactor Inspections
  - AIG Tuning
  - Data Surveillance and Trending
  - Catalyst Testing and Analysis
  - Manage CATLife<sup>®</sup> Modeling

# CERAM SCR Inspection 2011

- Moderate Catalyst Wall Thinning of Existing 6.9 mm pitch (22 cell) Catalyst (Supplied by Others) Observed in Levels 1 & 2
- Catalyst Pluggage Levels (20,200 hrs)
  - ◆ Level 1 Pluggage was 27%
  - ◆ Level 2 Pluggage was 21%
- CERAM 7.4 mm Pitch Catalyst Installed in Level 3
  - Larger Catalyst Pitch (7.4 mm Pitch 20 Cell Catalyst)
  - Increased Wall Thickness (0.60 → 0.80 mm)
  - Sloped Module Seals Instead of Flat Seals (Improved Ash Shear)
- Existing Catalyst Samples Removed for Testing


# Catalyst Pluggage Tracker

## Nebraska Utility Pluggage History 2011




# AIG Tuning 2011

- AIG tuning performed by CERAM
- Ammonia distribution found to be excellent
  - NOx Distribution +/- 10 ppm



Nebraska Utility Baseline AIG Tuning 2011 Summary			
	Units	'A' Side Corrected Outlet NOx	'B' Side Corrected Outlet NOx
Average Outlet NOx	ppm	53	45
Max Outlet NOx	ppm	60	48
Min Outlet NOx	ppm	49	38
Standard Deviation	ppm	4	3
<b>Target Distribution:</b>			
Points within ±10 ppm		21 of 21	21 of 21
Points within ±5 ppm		19 of 21	20 of 21


# 2011 Catalyst Testing Results



Test Average K/Ko at 16k hrs of 0.72

# 2011 Catalyst Management Planning

**CERAM 7.4 mm  
Catalyst Addition**



**Modeling Predicted Ammonia Slip near 4 – 5 ppm**

# 2011 Design Conditions & Predictions


<b>Nebraska Utility Catalyst Event Prediction</b>	
<b>Parameter</b>	<b>Current Operations Basis</b>
Inlet NO <sub>x</sub> , lb/MBtu	0.20
Outlet NO <sub>x</sub> , lb/MBtu	<b>0.064</b>
Ammonia Slip, ppmvd @ 3% O <sub>2</sub>	2.0
Fuel Burn Rate, MBtu/hr	6,298
Flue Gas Temperature, F	685
Gas Flow Rate, ACFM	3,434,564
<b>Deactivation Basis</b>	<b>Expected Replacement Timing and Season Year</b>
<b>K/K<sub>o</sub>  <sub>16K</sub> = 0.68</b>	<b>58,000 hours (Fall 2015)</b>

# 2011 Ammonia Slip Testing



- Ammonia Slip Testing Conducted in Fall 2011
  - Modeling Predicted 0.5 ppm Slip with New Catalyst Installed in Spring 2011
  - Test Results Showed Slip was near 2 ppm
- First Indication that the Model Result did Not Agree With Reality, but why?
- Catalyst Testing to be Performed during the Next Available Outage in 2012 to Confirm Slip Test Results

# Catalyst Pluggage Tracker



## Nebraska Utility Pluggage History 2012




# 2011 Level 1: A Side





# 2012 Level 1: A Side



# 2011 Level 1: B Side



# 2012 Level 1: B Side




# 2012 Inspection Results

- LPA and Fly Ash Buildup on Covergrates (Small Opening)
- Ash Piles 2 - 5 ft
- Ash Accumulation on Flat Module Seals (Supplied by Others)



# 2012 Inspection Results

- Severe Catalyst Wall Thinning (Levels 1 & 2)
  - Small Fissures and Cracks at the Inlet Face of the Catalyst
  - Internal Cracks Observed with Test Elements
  - Regeneration was not an Option due to Mechanical Condition and Thin Wall Construction of Original Catalyst




# 2012 Inspection and Cleaning

- Not Possible to Clean Thin Walled Honeycomb Catalyst by Other's
  - Air Lance Cleaning Damaged 4 Modules
    - ◆ Cleaning Halted Due to Damage
  - Affected Modules were Covered with a Steel Plate to Prevent Further Damage




# 2012 Catalyst Testing Results



Test Average K/Ko at 16k hrs of 0.51  
(2011 was K/Ko at 16k hrs 0.72)

# 2012 Catalyst Management Plan

Install  
CERAM  
7.4 mm



Step Change  
Levels 1 & 2

# 2012 Catalyst Testing

- Severe Step Change Deactivation Observed in the 1<sup>st</sup> and 2<sup>nd</sup> Level ( $K/K_o|_{16\text{hr}} = 0.51$ )
  - Calcium Sulfate Fouling and Phosphorus Poisoning
  - Low Tungsten Content in Catalyst
  - Thinning of the Catalyst Walls (Pore Structure)
- Step Change was not Observed in the 3<sup>rd</sup> Level of CERAM Catalyst



	Model 2011	Model 2012
<b>Relative Activity (K/Ko)</b>	0.71	0.46
<b>Normalized Relative Activity (K/Ko  <sub>16hr</sub>)</b>	0.72	0.51
<b>Expected Replacement Timing and Season Year</b>	Fall 2017 (2 ppm slip)	Spring 2013 (10 ppm slip)

# 2012 Catalyst Management Planning

- Catalyst Types (Replacing Layer 1 and 2 with Larger Pitch)
  - Catalyst Types
    - ◆ Install 7.4 mm Pitch Honeycomb Catalyst
    - ◆ Install 8.2 mm Pitch Honeycomb Catalyst
    - ◆ Install 5.6 mm Pitch Plate Catalyst
  - Catalyst Install Schedules
    - ◆ Remove both 6.9 mm Pitch Catalyst, Install 1 Layer
    - ◆ Remove both 6.9 mm Pitch Catalyst, Install 2 layers
  - Modified Operating Conditions
    - ◆ Higher Slip
    - ◆ Lower Inlet NOx


# SCR Conditions as of Spring 2013

- CERAM Conducted a Reactor Inspection After 38,800 hrs
  - Level 1 Pluggage: 90% !!!
    - ◆ Mechanical Damage/Erosion Contributed to Pluggage Rates
  - Level 2 Pluggage: 35%
  - Level 3 Pluggage: 20% (Consequence of Layer 1 and 2 Pluggage)
- Ash Piles Ranging from 4 to 9 ft Tall Along AIG Side of the Reactor
- LPA Accumulation on Cover Grates in Level 1




# Catalyst Pluggage Tracker

## Nebraska Utility Pluggage History 2013



# 2012 - 2013 Catalyst SCR Pressure Drop



# Nebraska Utility SCR


## *What Went Wrong?*

- 1) Poor flow Distribution Through the Reactor, LPA Accumulation on Covergrates
- 2) Aggressive Catalyst Design by Other Honeycomb Supplier
  - 6.9 mm Pitch Catalyst (Aggressive for PRB)
  - 43% Catalyst Pluggage (Levels 1 & 2)
- 3) Thin Wall Catalyst (<0.6 mm), Pluggage, and Erosion did not Allow for Regeneration
- 4) Step Change Drop in Catalyst Activity
- 5) 2 Initial Catalyst Layers (2+1 Reactor)
  - Operates as 3+0 With More Frequent Change Outs

**Result is Very High Ammonia Slip and Frequent Catalyst Change Outs**



# SCR Improvements & Solutions

- CERAM Recommended Utility Perform Flow Modeling of the SCR
  - Confirm Areas of Poor Flow in the Reactor
  - Identify Possible Solutions to Reduce Pluggage




# SCR Improvements & Solutions

- Reduce LPA Accumulation within the SCR
  - Baffle Plates Installed at the Economizer Hopper
  - Modeling Predicts 89% LPA Removal (Baseline 54%)
  - Negligible Increase to System Pressure Drop ( $\leq 0.1$  in. w.c.)




# SCR Improvements & Solutions

- Particle Modeling Performed
  - Baseline Yielded 54% Particle Removal
  - Baffle Plate Option 5 Yielded 89% Particle Removal



Baseline



Baffle Plate Option 5

# SCR Improvements & Solutions

- Catalyst Cleaning Planning Guide and Procedure developed by CERAM for the Utility
- Objectives of the Catalyst Cleaning and Procedure Guide:
  - Assist in Determining the Frequency and Magnitude of Catalyst Cleaning Efforts
  - Provide an Efficient Cleaning Procedure to Follow When Cleaning Does Occur
- Cleaning Guide can be Used to Evaluate Short Term Outages (3 – 7 days) and Extended Outages (Planned or Unplanned)

# SCR Improvements & Solutions

- Catalyst Cleaning Guidelines
  - **Outage Duration** – Calculate Expected Time Available for Cleaning
  - **Cleaning Frequency** – Determine Time since Last Thorough Cleaning
  - **Catalyst Cleanliness** – Estimate Catalyst Pluggage based on Pressure Drop
  - **Cleaning Effectiveness** – Estimate Catalyst Pluggage Recovery
  - **Cleaning Costs** – Calculate Catalyst Cleaning Cost
  - **Fan Energy Cost** – Calculate Energy Cost Based on Pluggage / Reactor Pressure Drop

# SCR Improvements & Solutions

- Utility Installed Additional Catalyst Cleaning Devices in 2013
  - Installed Air Cannons / Ash Sweepers in Level 1 (A & B Reactors)
  - Operation Planned to Begin Spring 2014 (if needed)




From Martin Engineering Website

# Catalyst Selection – Geometry and Chemistry

- Catalyst Pitch Evaluation

- Transitioning to Larger Pitch – Reduced Surface Area must be Offset by Reduction in Catalyst Pluggage
- 8.2 mm Pitch Honeycomb has 22% Less Specific Surface Area Compared to 6.9 mm
- 7.4 mm Pitch Honeycomb has 13% Less Specific Surface Area Compared to 6.9 mm
- 5.6 mm Pitch Plate has 36% Less Specific Surface Area Compared to 6.9 mm




# Catalyst Replacement in 2013

- CERAM Wins Competitive Bid to Replace Catalyst in 1<sup>st</sup> and 2<sup>nd</sup> Levels of the SCR
  - CERAM Proposed both 8.2 mm Honeycomb and 5.6 mm Plate
  - Utility Selected 8.2 mm Pitch Honeycomb
  - Catalyst Selection Allows for:
    - ◆ Reduced Pluggage and DP Concerns
    - ◆ Optimized Catalyst Management Modeling
    - ◆ Multiple Regenerations (Wall Thickness  $\geq 0.9$  mm)
    - ◆ Reduced Fan Energy Costs


# CERAM Working with Nebraska Utility to Optimize CMP

- Goal was to Develop Long Term Catalyst Management Plan to fit Desired Outage Schedule
  - Replace One Layer Every 2 Years
- Transition to Larger Catalyst Pitch
  - 8.2 mm CERAM Replaced Original 6.9 mm First Layer in Spring 2013
  - 8.2 mm CERAM Replaced Original 6.9 mm Second Layer in Spring 2013
  - Replace Third Layer in Spring 2015
- Future 2 Year Replacement Cycle is Achievable

# Status Quo CMP – Using Original Catalyst Design



# Optimized CMP – 2 Year Replacement Cycles



4 - 5 ppm Slip at 20,200 hrs

Utilizing 8.2 mm Pitch Catalyst Allows for 2 Year Replacement Cycle


# Catalyst Management NPV

- Economic Comparison Between Installing 6.9 or 8.2 mm Pitch Honeycomb Catalyst
- 10-Year NPV Analysis
  - NPV Cost Savings of \$8.9 Million dollars (39%)
  - \$2.2 Million in Fan Energy Costs Savings (Lower Pressure Drop)
  - \$6.8 Million in Catalyst Related Expenditures Savings (Includes In / Out Costs)

<b>Catalyst Economic Comparison: Nebraska Utility</b>		
	<b>Install 6.9 mm pitch catalyst in Levels 1 &amp; 2</b>	<b>Install 8.2 mm pitch catalyst in Levels 1 &amp; 2</b>
<b>Catalyst Related Expenditures</b>	\$16.54 Million	\$ 9.79 Million
<b>Fan Energy Costs for Reactor Pressure Drop</b>	\$ 6.46 Million	\$ 4.28 Million
<b>Total Net Present Value of Plan (2013 to 2022)</b>	\$ 23 Million	\$ 14.07 Million


# Current SCR Operation

- Reactor Inspection Performed in January 2014
  - Level 1 Pluggage: 6%, 6,000 hrs
  - Level 2 Pluggage: 7%, 6,000 hrs
  - Level 3 Pluggage: 20%, 25,000 hrs
    - ◆ Residual from Shadowing Effects of Old Catalyst
- Minor Popcorn Ash Accumulation Found (Baffles Effective)





# 2014 Catalyst Pluggage Tracker

## Nebraska Utility Pluggage History 2014





# 2014 Reactor Inspection: Level 1 (A Side)

Nebraska Utility  
A Side - First Catalyst Level (8.2 mm pitch)  
January 11, 2014





# 2014 Reactor Inspection: Level 2 (A Side)

Nebraska Utility  
A Side - Second Catalyst Level (8.2 mm pitch)  
January 11, 2014



# 2014 Reactor Inspection: Level 3 (A Side)

Nebraska Utility  
A Side - Third Catalyst Level (7.4 mm pitch)  
January 11, 2014



# 2014 SCR Reactor Inspection



# Potential Further SCR Improvements

- Air Cannons/Ash Sweepers May Not be Needed if Ash Piles do Not Develop
- Reviewing Options to Upgrade Sonic Horns
  - Mega/Magnum Horns
- Review Plans to Mount the Sonic Horns Flush with the Internal Reactor Wall
- Investigate Dry Ice Cleaning Procedures During Long Outages to Remove Residual 3<sup>rd</sup> Level Pluggage
- Monitor and Assess Pluggage during Short Outages to Determine if Further Modifications are Needed

# Summary

- Even the Worst SCR Issues can be Overcome
- Pitch Selection, Catalyst Quality, and Outage Cleaning Procedures can Help to Reduce Ash Accumulation and Pluggage
- Catalyst Management Plans Change Continuously and Are Based on the Following:
  - Unit and SCR Operations
  - Catalyst Deactivation Results and Trends
  - Reactor Inspection Results
- Thin Walled Catalyst Limits Long Term Use and Regeneration Options
- CERAM's Catalyst Management Program is Effective in Reducing Risk, Avoiding Surprises, and Limiting SCR Related Costs

*Thank You!*

*Questions?*

**Walter Bembry and Dr. Greg Holscher  
IBIDEN CERAM Environmental, Inc.**

**walter.bembry@ceram-usa.com**

**greg.holscher@ceram-usa.com**

**+1 913-239-9896**

**CERAM**

**IBIDEN**

