

REINHOLD ENVIRONMENTAL Ltd.



2017 NO_x-Combustion-CCR Round Table Presentation

February 27 & 28, 2017, in Cleveland, OH / Hosted by FirstEnergy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



Update on Experience and Applications with Enhanced Gas CoFiring


Presented by: Cal Lockert & Tim McCreary

Date: February 27, 2017



Enhanced Gas CoFiring






Dual-Use of Natural Gas

1. FLGR Requires 5% - 7% Natural Gas in the Upper Furnace for NO_x Control
2. Cofiring places volumes of NG at the igniter, or air bucket, location from 10% of HI (NFPA Class 1) to 30%

Based on Load and Operating Conditions, the gas volume at each location can be adjusted




Maximizes Gas flow while maintaining heat proximity to the furnace walls

Cofire gas comes from a higher area secondary annulus


FLGR For Dual Use Gas




Pressure & Flow Control can be adjusted to properly marry gas injection depth/velocity with NOx presence



Update on CoFiring




- **465 MW Nominal/Wall-Fired Unit**
 - 30 Burners based on 5 mills – 3 front wall/2 back wall
- **Unit burns 100% Illinois Basin Coal**
 - Natural Gas Igniters
 - Landfill Gas use is variable
 - Can reach full load with 3 mills + Gas
- **Variables:**
 - Mill Count & Configuration
 - Use of Natural Gas
 - Use of Landfill Gas




- High Volume of Gas at Low Load relieves NFPA worries re: two mill operation
- High Volume Gas Dilutes SO₃ at SCR inlet relieving concerns over SCR MOT

Mill Bias/Gas Observation Plot





- This Mill Configuration is the most common for this plant at Full Load.
- Utilization of only 9% natural gas (igniter level, no FLGR) allows deep biasing of coal input to the bottom mills and a significant drop in unit NOx

Update on FLGR



- **Natural Gas is injected via a series of injectors that are designed to create Micro-Swirls in identified higher NO_x zones,**
- **Essentially:**
 - $\text{CH}_4 + \text{NO}_x = \text{N}_2 + \text{H}_2\text{O} + \text{CO}$
- **The N₂ and H₂O parts are simple, the CO reacts with Oxygen in the flue gas to become CO₂ through the backpass of the boiler.**
- **The limiting factor on the amount of Natural Gas used, and the resulting NO_x reduction, is the mixing and residence time required to complete the CO:CO₂ reaction**

Modern Boiler – LNB/OFA




Full Load/3 Mill/2,3,5 FLGR




Initial NOx = 0.230 Lb./mmBTU
FLGR NOx = 0.19 Lb./mmBTU
Reduction = 17%

4 Mill Operation/2,3,4,5




Initial NOx = 0.270 Lb./mmBTU
FLGR NOx = 0.21 Lb./mmBTU
Reduction = 22%


Furnace Stoichiometry Dependence



NOx vs LF Stoic by Stoic




LM37 NOx vs. LF Stoic



"M"	0.109218	0.219442	
"B"	0.136171	-0.009664	
LF	FLGR OFF	FLGR ON	Nox
Stoichiometry	NOx Rate	NOx Rate	Reduction
0.95	0.240	0.199	17.1%
0.96	0.241	0.201	16.6%
0.97	0.242	0.203	16.1%
0.98	0.243	0.205	15.5%
0.99	0.244	0.208	15.0%
1.00	0.245	0.210	14.5%
1.01	0.246	0.212	14.0%
1.02	0.248	0.214	13.5%
1.03	0.249	0.216	13.0%
1.04	0.250	0.219	12.5%
1.05	0.251	0.221	12.0%


LM11 NOx vs. LF Stoic



"M" 0.096602 0.078677
 "B" 0.075189 0.081713

LF Stoichiometry	FLGR OFF NOx Rate	FLGR ON NOx Rate	Nox Reduction
1.40	0.210	0.192	8.8%
1.41	0.211	0.193	8.9%
1.42	0.212	0.193	8.9%
1.43	0.213	0.194	9.0%
1.44	0.214	0.195	9.0%
1.45	0.215	0.196	9.0%
1.46	0.216	0.197	9.1%
1.47	0.217	0.197	9.1%
1.48	0.218	0.198	9.2%
1.49	0.219	0.199	9.2%
1.50	0.220	0.200	9.3%
1.51	0.221	0.201	9.3%
1.52	0.222	0.201	9.3%
1.53	0.223	0.202	9.4%
1.54	0.224	0.203	9.4%
1.55	0.225	0.204	9.5%
1.56	0.226	0.204	9.5%
1.57	0.227	0.205	9.5%
1.58	0.228	0.206	9.6%
1.59	0.229	0.207	9.6%
1.60	0.230	0.208	9.6%
1.61	0.231	0.208	9.7%
1.62	0.232	0.209	9.7%
1.63	0.233	0.210	9.8%
1.64	0.234	0.211	9.8%
1.65	0.235	0.212	9.8%
1.66	0.236	0.212	9.9%
1.67	0.237	0.213	9.9%
1.68	0.237	0.214	9.9%
1.69	0.238	0.215	10.0%
1.70	0.239	0.215	10.0%

LM38 NOx vs. LF Stoic



CO in Compliance/IGN Gass OFF

"M" 0.754909 0.196108
 "B" -0.495382 -0.017195


LF	FLGR OFF	FLGR ON	Nox
Stoichiometry	NOx Rate	NOx Rate	Reduction
0.95	0.222	0.169	23.8%
0.96	0.229	0.171	25.4%
0.97	0.237	0.173	27.0%
0.98	0.244	0.175	28.4%
0.99	0.252	0.177	29.8%
1.00	0.260	0.179	31.1%
1.01	0.267	0.181	32.3%
1.02	0.275	0.183	33.4%
1.03	0.282	0.185	34.5%
1.04	0.290	0.187	35.5%
1.05	0.297	0.189	36.5%

All Data

"M" 0.72097 0.20945
 "B" -0.461663 -0.017635


LF	FLGR OFF	FLGR ON	Nox
Stoichiometry	NOx Rate	NOx Rate	Reduction
0.95	0.223	0.181	18.8%
0.96	0.230	0.183	20.4%
0.97	0.238	0.186	21.9%
0.98	0.245	0.188	23.4%
0.99	0.252	0.190	24.7%
1.00	0.259	0.192	26.0%
1.01	0.267	0.194	27.2%
1.02	0.274	0.196	28.4%
1.03	0.281	0.198	29.5%
1.04	0.288	0.200	30.5%
1.05	0.295	0.202	31.5%

LM39 NOx vs. LF Stoic




LF Stoichiometry	FLGR OFF NOx Rate	FLGR ON NOx Rate	Nox Reduction
"M"	0.243576	0.076699	
"B"	0.007988	0.151436	
0.95	0.239	0.224	6.3%
0.96	0.242	0.225	6.9%
0.97	0.244	0.226	7.5%
0.98	0.247	0.227	8.1%
0.99	0.249	0.227	8.7%
1.00	0.252	0.228	9.3%
1.01	0.254	0.229	9.9%
1.02	0.256	0.230	10.4%
1.03	0.259	0.230	11.0%
1.04	0.261	0.231	11.5%
1.05	0.264	0.232	12.0%

NOx vs LF Stoic by Stoic w/Inj Codes



Same approach but with FLGR “ON” data segregated by Injector Codes and FLGR Flow Rate below 200 SCFM eliminated (< 30 data points)

NOx v LF Stoic by Injector Code




FLGR Injector Setup Codes




- 1** Side Walls: Long, Straight, **7.5% Flow** & Long, **22.5° to Front Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **9% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 2** Side Walls: Long, Straight, **9% Flow** & Long, **45° to Front Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **7.5% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 3** Side Walls: Long, Straight, **9% Flow** & Long, **45° to Front Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **9% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 4** Side Walls: Long, Straight, **7.5% Flow** & Long, **45° to Front Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **9% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 5** Side Walls: Long, Straight, **7.5% Flow** & Long, **22.5° to Rear Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **9% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 6** Side Walls: Long, Straight, **7.5% Flow** & Long, **45° to Rear Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **9% Flow** & Short, 45° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow
- 7** Side Walls: Long, Straight, **9% Flow** & Long, **45° to Rear Wall**, 7.5% Flow
Front Wall Corners: Short, Straight, **7.5% Flow** & Short, 22.5° to Center, 9% Flow
Center - Short, Straight 12% Flow - Short 45° to edge, 11% Flow

NOx vs. LFS w/Injector Codes



Yellow and Blue Codes hold the most promise for the next round of testing

LFS vs NOx w/Avg. LF Stoic



Performance must be normalized to current Lower Furnace Stoichiometry conditions.

Normalized LFS vs. FLGR NOx




State	FLGR OFF	INJ Code 1	INJ Code 2	INJ Code 3	INJ Code 4	INJ Code 5	INJ Code 6	INJ Code 7
"M"	0.109218	0.528980	0.352819	0.450597	0.473520	0.203632	0.265832	0.390200
"B"	0.136171	-0.341586	-0.154459	-0.260822	-0.281615	0.003402	-0.054802	-0.178634

LFS	FLGR OFF	INJ Code 1	INJ Code 2	INJ Code 3	INJ Code 4	INJ Code 5	INJ Code 6	INJ Code 7
0.95	0.240	0.161	0.181	0.167	0.168	0.197	0.198	0.192
0.96	0.241	0.166	0.184	0.172	0.173	0.199	0.200	0.196
0.97	0.242	0.172	0.188	0.176	0.178	0.201	0.203	0.200
0.98	0.243	0.177	0.191	0.181	0.182	0.203	0.206	0.204
0.99	0.244	0.182	0.195	0.185	0.187	0.205	0.208	0.208
1.00	0.245	0.187	0.198	0.190	0.192	0.207	0.211	0.212
1.01	0.246	0.193	0.202	0.194	0.197	0.209	0.214	0.215
1.02	0.248	0.198	0.205	0.199	0.201	0.211	0.216	0.219
1.03	0.249	0.203	0.209	0.203	0.206	0.213	0.219	0.223
1.04	0.250	0.209	0.212	0.208	0.211	0.215	0.222	0.227
1.05	0.251	0.214	0.216	0.212	0.216	0.217	0.224	0.231
1.06	0.252	0.219	0.220	0.217	0.220	0.219	0.227	0.235
1.07	0.253	0.224	0.223	0.221	0.225	0.221	0.230	0.239
1.08	0.254	0.230	0.227	0.226	0.230	0.223	0.232	0.243
1.09	0.255	0.235	0.230	0.230	0.235	0.225	0.235	0.247
1.10	0.256	0.240	0.234	0.235	0.239	0.227	0.238	0.251
0.99	0.245	0.184	0.196	0.187	0.189	0.206	0.209	0.209
1.06	0.251	0.216	0.218	0.215	0.218	0.218	0.226	0.233
Normalized Redux @ 0.99		24.7%	19.8%	23.6%	22.7%	15.9%	14.4%	14.5%
Normalized Redux @ 1.055		13.9%	13.4%	14.7%	13.3%	13.2%	10.2%	7.3%

- 1. Maintenance of ORIGINAL Furnace Air/Fuel Stoichiometry is critical when moving FLGR gas into the upper furnace,**
- 2. Gas Usage in the Upper Mill Igniters can help bias coal lower and improve NO_x**
- 3. Dual use of gas in upper AND lower furnace at different times can provide significant Unit Turndown, NO_x, Particulate, Hg, SO₂ and CO₂ benefits for the single cost of the coal/gas price differential**

Next Steps


(OR) WHAT IS THIS GOOD FOR?




- **350 MW, Subbituminous Fuel, NG Ignition**
- **No SCR**
- **No FGD**
- **Cold Side ESP for Particulate Control**

- **How do you reduce SO₂ 85% without major capital expense?**

Current Operations



Comparison of Mississippi Lime Hydrated Lime DSI - SO₂ Removal




Traditional DSI FF Solution

754 tons/yr.
– SO₂ (80%)

General & Straight Forward

870,000 tons/yr.
– Coal

58,000 tons/yr. – Ash +
DSI (32,000 tons)




Traditional DSI ESP Solution

754 tons/yr.
– SO₂ (80%)

Difficult & ESP Dependent

870,000 million
tons/yr. - Coal

58,000 tons/yr. – Ash +
DSI (32,000 tons)




- **Add 30% Gas Cofire through the Igniter/Burner location**
- **Only operate Gas at loads above Minimum Range**

529 tons/yr.
– SO₂ (86%)

General & Straight Forward

704,000 tons/yr.
– Coal

45,000 tons/yr. –
Ash + DSI




Value Depends
on Coal/Gas \$
Differential

529 tons/yr.
– SO₂ (86%)

Net Zero Particulate

704,000 tons/yr.
– Coal

47,000 tons/yr. –
Ash + DSI (?)





ENVIRONMENTAL BENEFITS

	Historical Total	EGC Total	Benefit	% Reduction
SO ₂ -EGC	3,777	3,061	716	19.0%
SO ₂ -DSI	3,061	682	2,380	77.7%
DSI Required (NSR/Tons)		5.78	20,465	
Outlet NO _x	1,143	1,143	-	0.0%
SCR Inlet NO _x	1,143	985	159	13.9%
Mercury				
Particulate	26,203	42,758.08	(16,555)	-63.2%
CO ₂	1,620,858	1,522,608	98,250	6.1%
Coal (mmBTU)	15,476,902	12,531,587	2,945,316	19.0%
Coal (tons)	870,023	704,454	165,569	19.0%

MEASUREABLE SAVINGS

Oil/Gas - Ignition/Stabilization Conversion		0 \$/yr
Non-Min Load Coal/Gas Cost Penalty		-3,877,575 \$/yr
MSL Reduction	93	0 \$/yr
Pulverizer Operating Cost		58,405 \$/yr
SCR Operating Cost		0 \$/yr
Fly Ash Disposal Avoidance		97,764 \$/yr
FGD Operating Cost		0 \$/yr
DSI-SO ₂		-5,116,350 \$/yr
DSI-HCl		0 \$/yr
DSI-SO ₃		0 \$/yr
Coal Yard Parasitic Cost		3,826 \$/yr
TOTAL CALCULATED SAVINGS		-8,833,931 \$/yr

Full Range Gas/DSI Solution




475 tons/yr.
– SO₂ (88%)

General & Straight Forward

503,000 tons/yr.
– Coal

29,000 tons/yr. –
Ash + DSI




Value Depends
on Coal/Gas \$
Differential

475 tons/yr.
– SO₂ (88%)

Net Zero Particulate

503,000 tons/yr.
– Coal

29,000 tons/yr. –
Ash + DSI (?)





ENVIRONMENTAL BENEFITS

	Historical Total	EGC Total	Benefit	% Reduction
SO2-EGC	3,777	2,209	1,568	41.5%
SO2-DSI	2,209	835	1,374	62.2%
DSI Required (NSR/Tons)		3.95	10,071	
Outlet NOx	1,143	1,143	-	0.0%
SCR Inlet NOx	1,143	849	295	25.8%
Mercury				
Particulate	26,203	25,989.97	213	0.8%
CO2	1,620,858	1,221,841	399,017	24.6%
Coal (mmBTU)	15,476,902	8,954,727	6,522,175	42.1%
Coal (tons)	870,023	503,383	366,639	42.1%

MEASUREABLE SAVINGS

Oil/Gas - Ignition/Stabilization Conversion		0 \$/yr
Non-Min Load Coal/Gas Cost Penalty		-3,877,575 \$/yr
MSL Reduction	93	8,863,670 \$/yr
Pulverizer Operating Cost		129,641 \$/yr
SCR Operating Cost		0 \$/yr
Fly Ash Disposal Avoidance		257,098 \$/yr
FGD Operating Cost		0 \$/yr
DSI-SO2		-2,517,663 \$/yr
DSI-HCl		0 \$/yr
DSI-SO3		0 \$/yr
Coal Yard Parasitic Cost		3,826 \$/yr
TOTAL CALCULATED SAVINGS		2,858,996 \$/yr

Move Gas to FLGR Above Min Load



ENVIRONMENTAL BENEFITS

	Historical Total	EGC Total	Benefit	% Reduction
SO ₂ -EGC	3,777	2,231	1,547	40.9%
SO ₂ -DSI	2,231	825	1,406	63.0%
DSI Required (NSR/Tons)		4.02	10,359	
Outlet NO _x	1,143	1,143	-	0.0%
SCR Inlet NO _x	1,143	809	335	29.3%
Mercury				
Particulate	26,203	26,439.25	(236)	-0.9%
CO ₂	1,620,858	1,226,227	394,631	24.3%
Coal (mmBTU)	15,476,902	9,045,079	6,431,824	41.6%
Coal (tons)	870,023	508,462	361,560	41.6%

MEASUREABLE SAVINGS

Oil/Gas - Ignition/Stabilization Conversion		0 \$/yr
Non-Min Load Coal/Gas Cost Penalty		-3,852,107 \$/yr
MSL Reduction	93	8,863,670 \$/yr
Pulverizer Operating Cost		127,845 \$/yr
SCR Operating Cost		0 \$/yr
Fly Ash Disposal Avoidance		253,080 \$/yr
FGD Operating Cost		0 \$/yr
DSI-SO ₂		-2,589,803 \$/yr
DSI-HCl		0 \$/yr
DSI-SO ₃		0 \$/yr
Coal Yard Parasitic Cost		3,801 \$/yr
TOTAL CALCULATED SAVINGS		2,806,486 \$/yr

- **Gas Cofiring provides a stable, reliable fuel flexibility option,**
- **Gas CoFiring provides multiple benefits through Minimum Load Reduction potential**
- **Gas CoFiring provides multiple environmental co-benefits at no additional cost**

- **Current DSI Technology can support future requirements for SO₂ Reduction on units equipped with Fabric Filters,**
- **Current DSI Technology with Gas CoFiring can support future requirements for SO₂ Reduction on units equipped with all types of Particulate Removal Eqpt.**



Enhanced Gas Cofiring Experience at Orlando Utilities

Thank you

Presented by: Cal Lockert & Tim McCreary

Date: February 27, 2017

