

REINHOLD ENVIRONMENTAL®




2025 Reinhold/PCUG Round Table Presentation

Hosted by AEP and Buckeye Power

in The Hilton Columbus Polaris Hotel, Columbus, OH

on June 23-24, 2025

All presentations posted on this website are copyrighted by **REINHOLD ENVIRONMENTAL®** (RE). Any unauthorized attempts to print, to download, to modify, to incorporate into other presentations, to link to other websites or to obtain copies for any other uses than the training of attendees to RE Conferences is expressly prohibited unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials in this library which were presented and/or created by persons who were not employees or subcontractors of RE.



Gas Co-Firing O&M – Good and the Bad

2025 Reinhold Environmental Round Table Conference – 6/23/25

Introduction
Panelist
Design Considerations
Operational Experience

Agenda



Gas Co-Firing O&M – Good and the Bad

Introduction

Duke Energy Gas Co-firing Summary

	Cliffside 5	Cliffside 6	Belews Creek 1 & 2	Marshall 1 & 2	Marshall 3 & 4
Boiler OEM	CE	Hitachi	B&W	CE	CE
Boiler Style	4 corner Sub-Critical	Wall Fired Super-Critical	Wall Fired Super-Critical	8 corner Sub-Critical	8 corner Super-Critical
Commercial	1972	2012	1975	1965 & 1966	1969 & 1970
Capacity MWg	600	905	1170	400	700
AQCS Equipment	SCR, ESP, WFGD	SCR, SDA, FF, WFGD	SCR, ESP, WFGD	SNCR, ESP, WFGD	SCR (3) SNCR (4), ESP, WFGD
# Coal Burners	24	30	80	40	48
Co-fire Ratio	10-40%	100%	50%	10-40%	50%
# Gas Burners	8	30	32	16	16
On site CapEx	\$54M		\$117M	\$101M	
Pipeline	Dominion (7 mile 16-inch)		PNG (10-mile 24-inch)	PNG (20 miles 20-inch)	

Duke Energy Co-Firing Program Results

- All converted units achieved burner design output, boiler steam temperatures, and emissions targets.
- Lower min loads and higher ramp rates achieved.

Site	Unit Output (MWg)	% Gas	CO Target (lb/mmbtu)	CO Result (lb/mmbtu)	NOx Target (lb/mmbtu) @ SCR Inlet	NOx Result (lb/mmbtu) @ SCR Inlet	VOC Target (lb/mmbtu)	VOC Result (lb/mmbtu)	Coal Ramp Rate (MW/min)	Co-Fire Ramp Rate Result (MW/min)	Coal Min Load (MW)	Co-Fire Min Load (MW)
Cliffside 5	600	40%	0.08	0.015	0.25	0.164	N/A	N/A	8	10	150	100
Cliffside 6	905	100%	0.037	0.03	0.25	0.109	0.0023	0.0019	8	15	350	250
Belews 1 / 2	1170	50%	1.05	0.002 / 0.069	0.517	0.499 / 0.498	0.004	0 / 0.0002	6	25	300	300
	585	100%	0.04	0.001 / 0.002	0.4	0.40 / 0.398	0.0025	0.0004 / 0.0002				
Marshall 3 / 4	700	50%	0.07	0.0096 / 0.087	0.32	0.19 / 0.176	0.0025	0.0008 / 0.0009	5	20	280	150
	385	100%	0.08	0.0073 / 0.0042	0.24	0.161 / 0.148	0.0055	0.001 / 0.0011				
Marshall 1 / 2	400	40%	0.06	0.0037	0.29	0.24 / 0.204	0.0025	0 / 0.0006	4	8	150	70
	160	100%	0.08		0.22	0.167 / 0.088		0 / 0				

Panel Chair – Chad Donner – Duke Energy

Ann Palmer – Southern Company

John Brotherton – Duke Energy

Randy Bullock – Southern Company


Joe Bittinger – American Electric Power

Panelist

Design Consideration Questions

Design Configuration Questions – Firing System

- Gas heating vs. insulation?
- Fuel control skids - Level or boiler control?
- Burners – New vs retrofit?
- Igniters – HESI vs separate igniter train?
- Burner cooling – Passive vs. active?
- Interferences – 3D laser scan; boiler growth; vents
- Controls – Gas controls, boiler controls mods, implosion protection




Design Configuration Questions – Auxiliary Systems

- Gas leak detection - Area vs. point or both?
- N2 purge systems - Sweep vs. pressure?
 - NFPA 85 – Purge into & out of service
- CO monitoring?
- Scanner cooling air improvements?
- Boiler area ventilation – HCA NFPA 70 / NFPA 497



Design Configuration Questions – AQCS




- SCR
 - Low load operation / cutoff
 - NH₃ injection turndown
 - Dilution air supply
 - MoT
- ESP
 - SO₃ injection turndown
 - Field operation / cutoff
- SDA-Baghouse
 - Slurry feed control
 - Baghouse bypass
- WFGD
 - Slurry temperature
 - Purge control
 - Hg re-emission control



Operational Experience Questions

Operational Experience Questions – Burners / Flex Hoses

- Scanner issues
 - Flame discrimination?
 - Overheating / line of sight?
- Burner Overheating
 - Windbox combustion?
- Flex hose corrosion?
- Burner operation
 - Bring all burners up/down together?
 - Maintain mill group control?



Operational Experience Questions – AQCS Equipment

- Reduced MOT on SCR Operation to 485F → Generation Flexibility Benefit?
- Suspected SDA Approach Temp Issues w/ Change to Higher Moisture Fuel → SDA Buildup and Baghouse Bag Life Issues?
- Higher WFGD pH on gas operation → Benefit?
- Calcium carbonate formation & plating → Purge More Frequently?
- Hg Re-Emission → Purge More Frequently?
- Ramp Rate Issues w/ WFGD While Co-Firing → Periods of Higher SO₂ Emissions Until Reagent Feed Catches Up?
- Wastewater Nitrate Issues with Gas → Purge More Frequently?
- Steady O&M Culture Shift with “Easy” Gas → Coal Equipment is Treated as Secondary and not Maintained as Essential to Operation
“Operational Amnesia”?
- Gas Dispatch Philosophy → Fuel Flexibility Opportunity?





