

REINHOLD ENVIRONMENTAL Ltd.



2016 NO_x-Combustion-CCR Round Table Presentation

February 1 & 2, 2016, in Orlando, FL / Hosted by OUC

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



Enhanced Gas Cofiring Update on Stanton 1 Installations

Presented by: Cal Lockert/Breen Energy

February 1, 2016



Now plants must also consider this:


Technical Support Document (TSD) for
Carbon Pollution Guidelines for Existing Power Plants:
Emission Guidelines for Greenhouse Gas Emissions from Existing Stationary Sources:
Electric Utility Generating Units

Docket ID No. EPA-HQ-OAR-2013-0602

GHG Abatement Measures

U.S. Environmental Protection Agency
Office of Air and Radiation

June 10, 2014




Economy Considerations

LOAD CYCLING




Typical Load Cycling Curve



In the presence of solar and wind supply, coal plants are being forced to cycle more dramatically than in the past. All emissions are affected by load transition and unstable firing conditions.

Minimum Load Considerations





Source: EPA Acid Rain Database

Cycling has a major effect on total system dispatch effectiveness. Allowing the coal plant to achieve a much lower minimum load can have dramatic system wide cost and emissions implications.

Enhanced Gas CoFiring


THE BEST OF BOTH WORLDS






The walls and Upper Heat transfer surfaces are designed to accept heat from high emissivity coal particles

Simply re-powering with natural gas has inherent limitations due to the need for different heat transfer surfaces



Gas CoFiring marries natural gas and coal at each burner, injected through a modified igniter.

It also adds a portion of the total heat input as gas in the upper furnace. This is known as Fuel Lean Gas Reburn.



The Goal is to get up to 35% of the total heat input converted from coal to gas.

With 25% - 30% of that coming at the igniter location and 5% - 10% coming at the FLGR location.

Dual Orifice CoFire Igniter






A typical NFPA Class 1 Igniter:

- **10% of the Heat Input of the associated burner,**
- **Single, fixed size fuel spud,**
- **Single, fixed flow air supply**

Providing Higher Gas Volume:

- **Requires higher gas inlet pressure,**
- **Increases gas igniter flame velocity and penetration**

25% Heat Input Igniter





Providing 25% of the Heat to the boiler through a Class 1 igniter will extend the ignition flame into the center of the furnace.

This will have the effect of driving Furnace Exit temperatures UP, but keeping wall steam generation LOW.

Resizing the igniter for 25% standard throughput will make it unstable at low throughputs

Dual Orifice Design

Maximizes Gas flow while maintaining heat proximity to the furnace walls



Cofire gas comes from a higher area secondary annulus



System Requires:


- 80 CFM Forced Combustion Air/Igniter
 - Isolation Valve between Core and CoFire sides
 - Pressure Control on the Core side
-
- Additionally we remotely monitored:
- Gas Pressure
 - Air Pressure
 - Core Flame Stability

Fuel Lean Gas Reburn


COAL DISPLACEMENT WITH NO_x REDUCTION



FLGR - Reactions





CH Radicals Reduce
NO_x to N₂



Turbulent Gas Eddy Entraines NO_x

- Natural Gas Injected in Upper Furnace in amount sub stoichiometric to total flue gas oxygen,
- Localized gas pockets create fuel RICH zones:
 - $\text{CH}_x + \text{NO}_x \rightarrow \cdot\text{CN} + \cdot\text{NH}_2 + \text{H}_2\text{O}$
 - $\text{NO}_x + \cdot\text{NH}_2 \rightarrow \text{N}_2 + \text{H}_2\text{O}$
 - $\text{NO}_x + \cdot\text{CN} \rightarrow \text{N}_2 + \text{CO}$
 - $\text{NO}_x + \text{CO} \rightarrow \text{N}_2 + \text{CO}_2$
- Upon re-entrance into O₂ rich zones, CO completes to CO₂
- When passing the 1750 F temperature zone, NH_i radicals provide a secondary SNCR action

Historical Data On NOx Removal




13 System were deployed between 1998 – 2001.

On average a 5% - 7% Gas Heat Input realized a 25% - 30% reduction in NOx prior to the current SCR location


Experience & Lessons Learned

FLGR/COFIRE - STANTON






Boiler Elevations



FLGR Control Screen




Gas Control Skid





Rear Wall Piping



Original Injectors – 8th Floor





- **Better aspect ratio**
- **Lower heat xfer**
- **Less surface area for oxidation**
- **Better for producing fuel-rich eddies**
- **Directional control**

10th Floor Injectors



Actual execution of the implementation OUC's perspective:

- **Engineering of Hardware and functionality worked as planned**
 - **DBB valves lead times longer than quoted**
- **Software Implementation took a little longer than planned, but minimal operator interaction was needed when completed**
- **Basically a Turn-on <-> Turn-off system**

What did you have to do to support installation?

- **Provide a part-time Facilitator/Coordinator for overseeing safety, equipment/hardware deliveries, in-house support and quality control.**
- **Instrument & Electrical Technicians to pull wire, terminate, and perform the software addition/modification to the DCS, also start-up support.**


What did you have to do to help train the operators?

- **BREEN Provided training to all operational shifts before commissioning and during start-up/testing ph**
- **BREEN provided “User’s Manual”**
- **Did preliminary HVT probing to assure we meet Code for FLGR (concerns with adding natural gas downstream of igniters).**


What did you have to do to re-tune the boiler in response to the reallocated fuel makeup and location?

- **With 10% of total fuel was coming from FLGR, three mill operation was only needed to make full load on steam unit.**
 - OFA settings had to change to different mill configurations to maintain sub-stoichiometric conditions
 - Boiler Master was adding more air to coal burners when FLGR was in service, had to reduce O₂ trim


Control Screen



Main Air





OFA Control Screen



Modeling vs. Actual



Overall FLGR Geometry



Comparison between Baseline and Corresponding FLGR Case



- Same Firing Rate
- Same excess O₂ level (wet) in the Flue gas
- Same Lower Furnace (excluding OFA) and Burner in-service Stoichiometric Ratio
- Maintain same gas co-firing heat input through the burner igniters at low load

Overall Model Inputs

(Full Load)



	Baseline Full Load	FLGR Full Load
Furnace Gross Load (MW)	460	460
Gross Heat Rate (Btu/hr/KW)	9262.9	9262.9
Total Firing Rate (MMBtu/hr)	4260.9	4260.9
Total Natural Gas Firing Rate (MMBtu/hr)	0.0	319.6
Low Furnace Natural Gas Firing Rate (MMBtu/hr)	N/A	0.0
FLGR Natural Gas Firing Rate (MMBtu/hr)	N/A	319.6
FLGR in the Total Firing Rate (%)		7.5%
Front wall FLGR Natural Gas Firing Rate (MMBtu/hr)		159.8
Rear wall FLGR Natural Gas Firing Rate (MMBtu/hr)		159.8
Side wall FLGR Natural Gas Firing Rate (MMBtu/hr)		0.0
Natural Gas HHV (Btu/lb)	N/A	22823.6
Total Natural Flow Rate (Klb/hr)		14.002
Coal Firing Rate (MMBtu/hr)	4,260.9	3,941.4
Coal Type	IB-Sugar	IB-Sugar
Coal HHV (Btu/lb) as received	11,731	11,731
Coal Flow Rate (klb/hr)	363.220	335.979
Excess O ₂ in Flue Gas (% , wet)	3.56	3.56
Excess O ₂ in Flue Gas (% , dry)	3.91	3.93
Total Combustion Air (TCA) Flow (klb/hr)	3,935.14	3,925.96
Furnace Stoichiometric Ratio	1.223	1.224


	Baseline Full Load	FLGR Full Load
Mill in Service (Burner row in service)	1, 2, 3, 5	1, 2, 3, 5
Natural Gas Ignitor in Mill row	N/A	N/A
Number of Burners in Services	24	24
Mill Out of Service (Burner row out of service)	4	4
Number of Burners Out of Services	6	6
Total Natural Gas Ignitor in Service	N/A	N/A
In Service Burners		
In service Burner Stoichiometric Ratio	0.96	0.96
In service Burner Primary Air/Coal Ratio	1.87	1.87
Total In Service Burner Primary Air Flow (klb/hr)	680.00	629.00
Total In Service Burner Secondary Air Flow (klb/hr)	2400.00	2220.00
Out of Service Burners		
Total out of Service Burner Primary Air Flow (klb/hr)	0.0	0.0
Total out of Service Burner Secondary Air Flow (klb/hr)	90.00	83.25
Secondary Air Flow (klb/hr) per Out of Service Burner	15.00	13.88
Upper Wing Ports Air Flow (klb/hr)	165.14	152.76
Lower Furnace Stoichiometric Ratio	1.037	1.037
OFA Flow (klb/hr)	600.00	840.95
OFA Flow (klb/hr) per port	50.00	70.08
Primary Air Temperature (°F)	180	180
Secondary Air/OFA Temperature (°F)	584	584

Notes:

For High Load , when coal firing rate is reduced, air to the service burner, out of service burner and wing port is reduced proportionally to keep burner in service and low furnace SR same as Baseline

Overall Baseline Results

	High Load Baseline	Mid Load Baseline	Low Load Baseline
Nose Horizontal Plane			
Gas Temperature (° F)	2336	2234	1630
CO Concentration (ppmvw)	8905	7868	< 1
O ₂ Concentration (wet%)	4.52	4.78	7.50
NO _x Concentration (ppmvw)	151	147	166
Model Exit Plane			
Gas Temperature (° F)	1943	1834	1329
CO Concentration (ppmvw)	792	24	< 1
O ₂ Concentration (wet%)	3.65	4.01	7.50
NO _x Concentration (ppmvw)	153	153	172
NO _x Emission (lb/MMBtu)	0.244	0.249	0.351
Unburned Carbon in Fly Ash	5.7%	1.6%	< 0.1%



- **Injection Velocity**
- **# of Injectors in service**
- **Gas distribution between Front Wall / Rear Wall / Side Walls**




Overview of FLGR Results




Case	# FW/RW/RSW/LSW Injectors	Size FW/RW Inj. (H x W)	Size SW Inj. (HxW)	FLGR Vel (fps)	Gas Heat Input (%)	NOx Reduction (%)	Comments
FLGR1	14 / 14 / 0 / 0	4.06 x 0.25	NA	460	7.5	12.4	Relatively poor gas penetration
FLGR2	14 / 14 / 0 / 0	4.06 x 0.25	NA	460	7.5	12.9	Relatively poor gas penetration. Slightly better Nox reduction with 20° down tilt on injectors in this case compared with no tilt in FLGR1.
FLGR3	14 / 14 / 0 / 0	3.06 x 0.25	NA	814	10	27.8	Improved NOx reduction due to increased gas heat input combined with increased penetration.
FLGR4a	7 / 7 / 0 / 0	4.06 x 0.25	NA	920	7.5	21.2	Improved NOx reduction compared to FLGR2 due to improved gas penetration and increased NOx reduction in burner zone due to indirect influence of high FLGR momentum on burner zone fluid mechanics.
FLGR4b	7 / 7 / 4 / 4	2.97 x 0.25	1.89 x 0.25	920	7.5	22.1	Slight improvement over FLGR4a



Average NO_x Concentration Versus Elevation




Average NOx Concentration Versus Elevation



Impact of increased FLGR velocity and increased FLGR mass flow in FLGR 3 vs. FLGR 2 is seen more clearly near the front wall than near the rear wall.


Elevation 209 (Bottom of nose arch)

NOx (ppmw)	Baseline	FLGR2	FLGR3
Average	152	132	115
Front	187	160	133
Rear	106	94	92



Comparison of Tests with Predictions

1 Mill Out of Service



* REI CFD predictions showed very limited NOx reduction would be achieved (up to 7.6%), if the burner zone SR is not maintained when FLGR is put into service


Test results showed no NOx reduction is achieved when burner SR is not maintained when FLGR is put into service

** FLGR test results are consistent with REI predictions based on BES originally specified inlet velocity of 460 fps

*** CFD results showed improved FLGR performance with increasing injector velocity, which was not observed in the tests

OUC Stanton – ZGR Plan


Placement of FLGR Injectors to Penetrate into Regions Expected to be High NOx




Gas in the OFA air columns is wasted as far as NOx reduction, and may even form NOx

Boiler Baseline testing


OUC Stanton Unit 1, 8/15/15 1045-1057, Test 01
453 mw, 4 mill 1-100s, 3.40%O₂sp, Baseline, Norm OFA **B1,3 leak?**
3.85%dry (3.61 S/4.10 N) Econ Grid O₂



239 ppm / 251 ppmc / 0.208 #MBtu Average Grid CO




186 ppmc / 0.253 #/MBtu Grid Corrected NO_x




- Uniform NO_x observed across the boiler
- No pockets of High CO/O₂ or NO_x
- Initial gas injection testing revealed gas burnout with no Reburn effect
- Conditions look conducive for a traditional FLGR

New injection elevation

New injection elevation
Expected flue gas temperature ~ 2400 DegF



Front/Rear FLGR Injectors



FLGR 3 3 3 10% and FLGR
3 3 3 10% 30 40 30
 Nine 2" Sched 10 pipe injectors

FLGR Fuel Velocity
585 ft/sec



FLGR Fuel Velocity
708 ft/sec

Straight injector open area 3.65 in²/injector, Other 3.14 in²/injector

Side injector: Open area 2.46 in²/injector
 Middle injectors: Straight injector open area 3.65 in²/injector, Other 3.14 in²/injector

All injectors have no vertical velocity component

This two injectors have vertical velocity component to achieve 70° lateral



FLGR 3 3 3 10%

FLGR 3 3 3 10% 30 40 30

Overall Model Inputs

Full Load



	Baseline Full Load	FLGR3_3_3_10% and FLGR3_3_3_10%_30_40_30
Furnace Gross Load (MW)	460	460
Gross Heat Rate (Btu/hr/KW)	9262.9	9262.9
Total Firing Rate (MMBtu/hr)	4260.9	4260.9
Total Natural Gas Firing Rate (MMBtu/hr)	0.0	426.1
Low Furnace Natural Gas Firing Rate (MMBtu/hr)	N/A	0.0
FLGR Natural Gas Firing Rate (MMBtu/hr)	N/A	426.1
FLGR in the Total Firing Rate (%)		10.0%
Front wall FLGR Natural Gas Firing Rate (MMBtu/hr)		426.1
Rear wall FLGR Natural Gas Firing Rate (MMBtu/hr)		N/A
Side wall FLGR Natural Gas Firing Rate (MMBtu/hr)		N/A
Natural Gas HHV (Btu/lb)	N/A	22823.6
Total Natural Flow Rate (Klb/hr)		18.669
Coal Firing Rate (MMBtu/hr)	4,260.9	3,834.8
Coal Type	IB-Sugar	IB-Sugar
Coal HHV (Btu/lb) as received	11,731	11,731
Coal Flow Rate (klb/hr)	363.220	326.898
Excess O ₂ in Flue Gas (% wet)	3.56	3.56
Excess O ₂ in Flue Gas (% dry)	3.91	3.94
Total Combustion Air (TCA) Flow (klb/hr)	3,935.14	3,923.16
Furnace Stoichiometric Ratio	1.223	1.224


	Baseline Full Load	FLGR3_3_3_10% and FLGR3_3_3_10%_30_40_30
Mill in Service (Burner row in service)	1, 2, 3, 5	1, 2, 3, 5
Natural Gas Ignitor in Mill row	N/A	N/A
Number of Burners in Services	24	24
Mill Out of Service (Burner row out of service)	4	4
Number of Burners Out of Services	6	6
Total Natural Gas Ignitor in Service	N/A	N/A
In Service Burners		
In service Burner Stoichiometric Ratio	0.96	0.96
In service Burner Primary Air/Coal Ratio	1.87	1.87
Total In Service Burner Primary Air Flow (klb/hr)	680.00	612.00
Total In Service Burner Secondary Air Flow (klb/hr)	2400.00	2160.00
Out of Service Burners		
Total out of Service Burner Primary Air Flow (klb/hr)	0.0	0.0
Total out of Service Burner Secondary Air Flow (klb/hr)	90.00	81.00
Secondary Air Flow (klb/hr) per Out of Service Burner	15.00	13.50
Upper Wing Ports Air Flow (klb/hr)	165.14	148.63
Lower Furnace Stoichiometric Ratio	1.037	1.037
OFA Flow (klb/hr)	600.00	921.53
OFA Flow (klb/hr) per port	50.00	76.79
Primary Air Temperature (°F)	180	180
Secondary Air/OFA Temperature (°F)	584	584

Notes:
 For High Load, when coal firing rate is reduced, air to the in-service burners, out of service burners, and wing ports is reduced proportionally to keep lower furnace SR same as Baseline

Notes:
 FLGR 3_4_3, FLGR 3_3_3_10%_30_40_30 and FLGR 3_3_3_10%; FLGR Natural gas injector direction and gas velocity magnitude see slide 8


Overall Results

	High Load Baseline	High Load FLGR 3_3_3_10%	High Load FLGR 3_3_3_10%_30_40_30
Nose Horizontal Plane			
Gas Temperature (° F)	2336	2281	2287
CO Concentration (ppmvw)	8905	8110	8209
O ₂ Concentration (wet%)	4.52	5.05	4.94
NO _x Concentration (ppmvw)	151	133	131
Model Exit Plane			
Gas Temperature (° F)	1943	1913	1912
CO Concentration (ppmvw)	792	2668	1734
O ₂ Concentration (wet%)	3.65	3.94	3.78
NO _x Concentration (ppmvw)	153	120	119
NO _x Emission (lb/MMBtu)	0.244	0.189	0.188
Total NO _x Reduction	N/A	22.3%	22.9%
NO _x Reduction due to Coal Replacement with Natural gas	N/A	6.9%	8.5%
NO _x Reduction due to FLGR Chemistry	N/A	15.4%	14.4%
Unburned Carbon in Fly Ash	5.7%	2.6%	2.4%




Lower Furnace SR – O2 Probes

OUC Stanton Unit 1 Burner and OFA Port Econ Duct Overlay (12/08), Assuming Plug Flow




OUC Stanton Unit 1 Burner Approximate O2 Probe Location Relative to Grid Probes




10th Floor Result Analysis




3 Mill/Landfill Gas Off/HV Inj.



4 Mill – MC2 – All LFG Codes/Mxd Inj.



4 Mill MC6 All LFG Codes/Mxd. Inj.





Data Summary – High Load

	AVG NO FLGR	AVG Full FLGR Orig Inj	AVG Full FLGR HV Inj	AVG Full FLGR SHV Inj	FLGR Impact Orig Inj	FLGR Impact HV Inj	FLGR Impact SHV Inj
2B-SD-HL-3M-MC1-IC2-LC0	0.235		0.199			15.2%	
2B-SD-HL-3M-MC1-IC2-LC3	0.248			0.216			12.8%
2B-SD-HL-3M-MC1-IC2-LC4	0.240			0.220			8.4%
2B-SD-HL-3M-MC1-IC2-LC5	0.232			0.196			15.8%
2B-SD-HL-3M-MC1-IC2-LC6	0.234			0.190			18.9%
3A-SD-HL-4M-MC2-IC0-LC0	0.267		0.211			21.1%	
3A-SD-HL-4M-MC2-IC0-LC3	0.250		0.217			13.2%	
3A-SD-HL-4M-MC2-IC0-LC5	0.250			0.226			9.3%
3A-SD-HL-4M-MC6-IC0-LC0	0.259	0.237	0.227		8.5%	12.4%	
3A-SD-HL-4M-MC6-IC0-LC3	0.263		0.227	0.242		13.9%	7.9%


CoFire Igniter Update




The Device



Exploded Internals



Side View




- | | |
|--|--|
| 1. Power head | 6. Combustion / Cooling air tube |
| 1.1 Ionization flame monitor with flame signal converter | 7. Intermediate electrode support rings |
| 1.2 Spark transformers | 8. Electrical connecting rods |
| 1.3 Electrical plug | 9. Igniter gas tube |
| 1.4 Allen screw | 10. Final electrode support ring with three ceramic insulators |
| 2. Igniter gas manifold | 11. Pilot gas connector |
| 2.1 Igniter gas pressure test nipple | 11.1 Gas pilot ports (6) |
| 3. Igniter gas inlet port | 12. Ignition electrodes |
| 4. Gas co-fire manifold | 13. Flame rod (reverse side) |
| 4.1 Gas pressure test nipple | 14. Combustion / Cooling air inlet port |
| 4.2 Gas co-fire tube | 15. Mixing chamber |
| 5. Combustion / Cooling air manifold | 16. Mounting flange |
| 5.1 Combustion / Cooling air pressure test nipple | 17. Main gas outlet port |


BREEN Outside Demonstration



IR of outside demonstration



BREEN Co-fire guns in-service





Existing Forney Gas Igniter



Landfill Gas Injectors



Overheated Tip of BREEN Igniter



New Inconel Tip



After 1 year in-service approximately
75% of the time



Close up after 1 year



11.06.2015

Igniter without outer tip



Summary & Conclusions



- **FLGR is a Work-In-Progress but encouraging**
- **Gas Cofire Igniter is proving to be a reliable and inexpensive method for bringing increased, and variable, levels of natural gas to Coal Fired Combustion**
- **Thanks to OUC Staff:**
 - Jim Czarniecki
 - Tony Engelmeyer
 - Matt Blankner
 - Wade Gillingham
 - Rob McCarty

Questions?

