

# REINHOLD ENVIRONMENTAL®



## **2023 Reinhold/PCUG Round Table Presentation**

Cohosted by Duke Energy and Vistra in The Westin Hotel,  
Cincinnati, OH on June 26-27, 2023

All presentations posted on this website are copyrighted by **REINHOLD ENVIRONMENTAL®** (RE). Any unauthorized attempts to print, to download, to modify, to incorporate into other presentations, to link to other websites or to obtain copies for any other uses than the training of attendees to RE Conferences is expressly prohibited unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials in this library which were presented and/or created by persons who were not employees or subcontractors of RE.

# Novel Approaches to ELG Compliance

Overview of Proposed ELG Amendment and Options to  
achieve Zero Liquid Discharge

Claire Schmit, PE

2023 Reinhold/PCUG Conference, Cincinnati, OH  
Workshop 5, 9:15-11:15 June 26, 2023

---

## Acronyms

**BAT – Best Available Technology economically achievable**

**BATW – Bottom Ash Transport Water**

**BPJ – Best Professional Judgement**

**CCR/CCP – Coal Combustion Residuals / Products**

**ELG – Steam Electric Power Effluent Limitations Guidelines**

**FATW – Fly Ash Transport Water**

**HRR – High Recycle Rate closed loop BATW**


**LRTR – Low hydraulic Residence Time Reduction biological treatment**

**LVW – Low Volume Waste**

**VIP – Voluntary Incentive Program**

**ZLD – Zero Liquid Discharge**

# Effluent Limitation Guidelines : Regulatory Timeline



## Effluent Limitation Guidelines : Content Progression

**2015**

Numeric limits for Hg, Se, As, NO<sub>2</sub>/NO<sub>3</sub> in FGD WW, FA / BA TW, Hg control WW

BAT = Phys/Chem + Anoxic/Anaerobic Fixed Film Bio

Existing & Legacy CCR leachate excluded after litigation

**2020**

Revised numeric limits for direct discharge

FGD BAT for direct discharge to Phys/Chem + LRTR (biological treat) + ultrafiltration

BATW BAT to HRR with 10% discharge

Revised EPA Voluntary Incentives Program

- Membrane separation and zero liquid discharge (ZLD)
- Numeric limits for total dissolved solids and bromide

## Effluent Limitation Guidelines : Content Progression

### 2023 (proposed)

Revised requirements for FGD wastewater and BA transport water / Included limits on CCR leachate from existing and legacy sources

- No change if coal use ends by 2028
- ZLD for FGD WW (BAT = phys/chem + membrane)
- ZLD for BA transport (BAT = dry handling/ closed-loop)
- Hg and As limits for CCR leachate
- High flow / low utilization sub-categorizations removed
- 'Early adopters' with 2032 shutdown – no ZLD required
- VIP Membrane + ZLD Adopters compliant by 12/31/2028
- Compliance NLT 12/31/2029

## ELG for FGD Wastewater

Early adopter with Biological or ZVI treatment by date of new revision and planned closure by 2032 may discharge with noted limits.

Table 6 to Paragraph (g)(2)(iii)

Pollutant or pollutant property	BAT Effluent Limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
Arsenic, total ( $\mu\text{g/L}$ )	18	8
Mercury, total ( $\mu\text{g/L}$ )	103	34
Selenium, total ( $\mu\text{g/L}$ )	70	29
Nitrate/nitrite as N (mg/L)	4	3

---

## ELG for BA Transport Water

Early adopters with permitted HRR BA Handling system that close by 2032 can continue to discharge 10% wetted volume for:

- Storm surge events,
- Water balance for other non-BATW streams,
- Water chemistry,
- Maintenance events.

## ELG for CCR Leachate

CCR Leachate includes:

- Surface impoundment (active/or inactive) decant wastewater
  - Water above CCR in impoundment that does not cause re-suspension when removed
- Surface impoundment (active/or inactive) dewatering wastewater
  - Contact water in impoundment or re-suspends CCR when removed

BAT = phys/chem precipitation

Table 9 to Paragraph (1)

Pollutant or pollutant property	BAT Effluent Limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
Arsenic, total ( $\mu\text{g/L}$ )	11	8
Mercury, total ( $\mu\text{g/L}$ )	788	356

## ELG for Legacy Wastewater

Legacy Wastewater = FGD WW, BA Transport Water, FA Transport Water, CRL, gasification WW, or FGMC wastewater generated before 2015 / 2020 rules

No BAT established – BPJ by states

Table 9 to Paragraph (1)

Pollutant or pollutant property	BAT Effluent Limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
Arsenic, total (µg/L)	11	8
Mercury, total (µg/L)	788	356

# Pathways to Compliance BATW



## Traditional BATW ZLD or HRR Options

### Open Loop Conversions

Submerged Flight Conveyor

Remote Submerged Flight Conveyor

Dry Conversion / Pneumatic Conveying



## Holistic Approach to ZLD - 4Rs

**Reduce:** Reduce pump seal water, segregate seal water, modify wash down duration/ frequency, or adjust system setpoints to reduce wastewater volumes or concentrations

**Reuse:** Collect decanted sludge water for reuse, return BATW purge as makeup to FGD system

**Reconfigure:** Employ mechanical seals, implement sludge water clarification system


**Retrofit:** Install ash dewatering basin with sludge recycle, or implement in-duct wastewater evaporation system




## Hydrobin System Reconfiguration

### Reduce, Reconfigure, Recycle

- Traditional hydrobin system for BA regularly overflowed BA into LVW sumps
- Low volume waste impacted for ELG compliance
- BA Disposal in CCR compliant pond



# BA Sluice Recycle PFD




## BATW Reconfiguration

### Reduce, Reconfigure, Recycle

- 1200-MW coal fired plant with pond-based, open-loop slag removal
- Compliance with CCR and ELG required
- Physical limitations precluded under boiler SFC

#### SOLUTION:

- Water balance tightening plus Concrete Dewatering Tank (CDT)
- Continuous flow system with online excavation of ash and sludge water recycle
- Provision for temperature adjustment




## Concrete Dewatering Basin






# Pathways to Compliance FGD WW

# Traditional FGD WW ZLD Options



## End of Pipe Solutions

- Membrane Treatment – proposed BAT
- Brine Concentrators
- Spray Dryers
- Evaporation Ponds
- Deep Well Injection



## Holistic Approach to ZLD - 4Rs

**Reduce:** Modify pump seals, modify wash sequences, or adjust dewatering system setpoints to reduce wastewater volumes or concentrations.

**Reuse:** Modify plant water balance to recycle process water as a source of makeup water, wash water, or flush water.

**Reconfigure:** Utilize materials of construction to permit operation at higher chloride concentrations, modify FGD chemistry to produce wetter product for disposal.

**Retrofit:** Stabilize wastewater for landfill disposal, install ash dewatering basin with sluice recycle, or implement in-duct wastewater evaporation system.



## Utilize Materials of Construction

### Reduce, Reconfigure, Recycle

- Station with 3 units: 1 large, 2 smaller ~ 1600 MW total
- Larger unit designed to purge ~200 gpm through WWTS to outfall
- WWTS required extensive upgrade for ELG compliance
- FGD MOC's included Stebbins Tile, PVC/FRP, C276/Hastelloy, Rubber Lined Pumps

### SOLUTION


Plant wide water balance and sensitivity analysis

Revealed chlorides could be cycled up in larger unit to reduce purge rate

Smaller stream could be used as makeup to smaller units

Chlorides co-disposed in existing solids blending system.

## Purge rate versus FGD chloride concentrations



Common FGD MOCs	Practical Cl Limits
316L	<10,000 ppm
317L	<15,000 ppm
2205	<25,000 ppm
FRP/Stebbins	>25,000 ppm

## Process Troubleshooting & Modifications

### Reduce FGD Wastewater

- 1400 MW station – LSFO operation
- FGD system produced excessive gypsum fines causing high moisture in gypsum and high-volume wastewater purge rate
- Fines determined to be caused by potential crystal modifier in limestone reagent

#### SOLUTION:


- Changed source of limestone reagent
- Reduced WW purge by 10x
- Gypsum product met moisture spec



## Reagent Conversion & Co-disposal

### Reduce, Reconfigure


- Station with 2 units: 1080 MW total
- 150 gpm LSFO FGD chloride purge
- Minimal gypsum sales; Fly ash co-disposed with unsold gypsum in landfill



## In-Duct Wastewater Evaporation



### Reduce, Reconfigure

- Station with 2 units: 1 large, 1 small ~ 517MW total
- FGD and BA transport water collected in settling pond with outfall to river
- Pond not compliant with CCR; outfall not compliant with ELG



## In-Duct Wastewater Evaporation

- Lower cost, simpler alternative to SDE for streams < 25 gpm
- FGD purge stream injected into flue gas between economizer and particulate control device
- Wastewater evaporates – TDS forms particulates for capture downstream



---

## Conclusion

- **ZLD is proposed to be BAT for FGD and BA WW no later than 2029**
- **Existing, previously compliant systems may require upgrades to retain compliance**
- **Water balance tightening necessary to lower wastewater flows and lower the cost of compliance**
- **Alternative, economic approaches to ZLD exist and can be used to help extend the life of plants**