

REINHOLD ENVIRONMENTAL Ltd.



**2015 APC Round Table
& Expo Presentation**

July 13 & 14, 2015, in Atlanta, GA / Hosted by Southern Company

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.

Reduction of Carbon Dioxide Emissions from Existing Coal- Fired Boilers

Presented by

Tony Licata

Licata Energy & Environmental Consultants, Inc.

James Staudt, PhD

Andover Technologies Partners


CO₂ Reduction through heat rate improvements

- EPA suggests average 6% improvement in heat rate of coal fired plants is achievable EPA indicates that the average heat rate of the ten year period between 2002 and 2012 for the over 800 units that the data was based on varied between 9,924 Btu/kWh and 9,643 Btu/kWh for an 11 year average of 9,754 Btu/kWh.
- Statistical analysis based on gross heat rate, ambient temperature and hourly average load expressed as a percent of maximum.

Reality

- EPA did not consider any technical aspects of the facility, or if any characteristics changed over the 11 year period of time, including changes in operating mode (switching from base load to cycling), retrofits (installation of low NOx burners, SCRs, or FGD), or if the facility changed coals over this period, or any characteristics of the fuel for that matter. EPA also did not compare units against one another or do any sort of sub-categorization
- Hire a statistician to tell you what you want to hear.

Impact of FGD Installations on Heat Rate



Impact of Boiler Type & Coal vs. HR


	Subcritical HR		Supercritical HR	
	Bituminous	Subbituminous	Bituminous	Subbituminous
100-200 MW	10,663	11,051		
200-500 MW	10,470	10,642	10,364	
500+ MW	10,121	10,374	9,868	10,582
Lignite	11,091			


Heating Values of Coals in Electric Generation

Year	2008	2009	2010	2011	2012	2013
All coals	9,918	9,878	9,817	9,738	9,650	9,675
Lignite	6,495	6,427	6,474	6,513	6,479	6,509
Subbituminous	8,699	8,698	8,693	8,699	8,721	8,753
Bituminous	11,970	11,951	11,952	11,886	11,813	11,722


year	Annual Capacity Factor	Annual Heat Rate Btu/kWhr.	Tested Heat Rate Btu/kWhr.
2002	69.98%	10,314	
2003	71.98%	10,297	
2004	72.15%	10,331	
2005	73.32%	10,373	
2006	72.61%	10,351	
2007	73.60%	10,375	10,158
2008	72.35%	10,378	10,138
2009	63.78%	10,414	10,150
2010	66.78%	10,415	10,142
2011	62.30%	10,444	10,128
2012	55.81%	10,498	10,107

Diff Annual HR - Test HR





EGU - Tons Coal Burned Per Year



Impact of Coal Rank on Heat Rate

