

REINHOLD ENVIRONMENTAL Ltd.



**2015 APC Round Table
& Expo Presentation**

July 13 & 14, 2015, in Atlanta, GA / Hosted by Southern Company

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.

Ultra-Low FGD Emissions APC Roundtable 2015

**July 14th, 2015
Presented By:
Morgan French**




MITSUBISHI HITACHI POWER SYSTEMS AMERICAS, INC.

US Coal Market Place




- 1,249 Coal Units in Operation as of January 2015
 - 329,552 MW Operating Nameplate Capacity
- 966 Coal Units in Operation past 2023
 - 272,643 MW Operating Nameplate Capacity
- 472 Coal Units are treated by an FGD system
 - 187,547 MW Operating Nameplate Capacity
- Average SO₂ rate .214 lbs/mmBTU
 - All FGD
- 45 Units in the United States report lower than .04 lbs/mmBTU SO₂ rates
 - 39 out of 45 of those units had an FGD Installed after 2005
 - This is a clear indication of a correlation between FGD install date and performance
- 569 Plants have no FGD installed
 - 241 Have Documented SO₂ Removal Ratings
 - 192 of those exceed .4 lbs/mmBTU SO₂ rate
- MHPSA Long Term Analysis shows that 27 GW of FGD projects will take place by 2023
- This demand for SO₂ mitigation will result in \$13.8 Billion dollars in AQCS projects by 2023

AQCS Market Drivers



Continued Regulation Uncertainty is Impacting Utilities' Decisions Regarding Future Capital Investments for Emission Control Projects


Environmental Regulations Impacting US Coal Fleet



Advanced Coal Technologies: A U.S. Environmental Success Story





Emissions Rate Declines 90% Since 1970 As Coal Use Rises 170%



Source: U.S. Energy Information Administration (EIA) 2014 Annual Energy Outlook, 2013; EIA Annual Energy Review, 2012; U.S. Department of Agriculture, 2013; U.S. National Energy Technology Laboratory, 2012; U.S. Environmental Protection Agency, "Clean Air Markets," 2013.

40 Years of FGD Experience



Streamlined design for high efficiency and low power consumption

Wet FGD Systems – Market Leading Design Features


Wet FGD Design Features:

High Velocity Design reduces
absorber size

High Spray Flux Minimizes
Velocity Variation

High Spray Flux Maximizes
Gas-Liquid Contact

Higher Spray Density Near
Absorber Wall Increases Spray
Coverage and Eliminates
Sneakage



Streamlined design for high efficiency and low power consumption

Single Stage Wet FGD to Enable SO₂ Capture




Requirement for flue gas
“single digit “ SO₂
(less than 10ppm)


- CFD guided design
with ANSWER
(In-house 3-D software)

- Modification of spray
arrangement


- Conditions
650MWe plant
Flow rate : 2 Mm³N/h
inlet SO₂ : 2000 ppm



High Gas Velocity Scrubber Tower Design



Enhanced Surface Mixing
Increases Pollutant Removal



Efficient removal of pollutants and compact scrubber size

Reaction Tank Design



- In-Situ Forced Oxidation Employs Side-Entering Agitators and Air Lances
- Reaction Tank Solids Residence Time Ensures Good Crystal Growth.



- High Solids For Enhanced SO₂ Removal and Better Dewatering

Wet FGD Experience



- 75 Worldwide Installations (Open Spray Tower)
- 30,500 MW
- All Common Utility Fuels
- Inlet SO₂ Concentrations from 500 to 4,000 ppm
- Absorber Capacities to 1,050 MW
- Absorber Sizes to 69 ft
- All Common Absorber Materials
- 30 Years of Commercial Grade Gypsum

Ameren Sioux
2 x 535 MWe



Ameren Coffeen
389 MWe and 617 MWe



**The Ameren Coffeen Wet FGD was recognized as the
cleanest SO₂ Coal Plant in the US in 2013**



- Dynegy Duck Creek - FGD
- Dynegy Coffeen FGD
- Ameren Sioux- FGD
- Minnesota Power Boswell – SCR and FGD
- KCP&L LaCygne – SCR and FGD – 2015 Start-up



DUCK CREEK UNIT 1



PROJECT BACKGROUND



Basic Design Criteria – Duck Creek

• Absorber MW	465
• Coal Type	Bituminous
• Sulfur Content (%)	3.41
• Inlet SO ₂ Conc (ppmd – 3% O ₂)	3,325
• Inlet SO ₃ Conc (ppmd – 3% O ₂)	15 – 23
• Inlet Dust (lb/106 Btu)	0.109
• Gas Flow Rate (acfm)	1,485,900
• Inlet Temp. (deg. F)	305



RESULTS OF PERFORMANCE TESTS AT DUCK CREEK

<u>Parameter</u>	<u>Guarantee</u>	<u>Test Result</u>
• Particulate Emissions	≤ 0.015 lb/MMBtu	0.0045 lb/MMBtu
• SO ₂ Removal	$\geq 99\%$ Removal	99.83% Removal
• SO ₂ Emissions	≤ 0.064 lb/MMBtu	0.0038 lb/MMBtu
• SO ₃ Removal	$\geq 60\%$ Removal	72.1% Removal
• Mercury Removal	$\geq 90\%$ Removal of Oxidized Mercury	99.0% Removal

Dynegy Coffeen 1 & 2




<u>Parameter</u>	<u>Guarantee</u>	<u>Test Result</u>
• Particulate Emissions	≤ 0.015 lb/MMBtu	0.0047 lb/MMBtu
• SO ₂ Removal	≥ 99% Removal	99.95% Removal
• SO ₃ Removal	≥ 60% Removal	67.45% Removal
• Mercury Removal	≥ 90% Removal of Oxidized Mercury	84.35% Removal (Note)

2013 Top 5 Cleanest Coal Plants - SO ₂				
Power Plant	Holding Company	State	Operating Capacity (MW)	SO ₂ (lbs/MWh)
Coffeen	Dynegy, Inc.	IL	915	0.05
Iatan	Great Plains Energy	MO	1,586	0.05
South Oak Creek	Wisconsin Energy Corporation	WI	976	0.06
James H. Miller, Jr.	Southern Co.	AL	2,675	0.08
Virginia City Hybrid Energy Center	Dominion Resources, Inc.	VA	614	0.08
U.S. Average				4.00

Dynegy's Coffeen Plant: Lowest SO₂ Emission Rate of Major U.S. Coal Plants



Coffeen's SO₂ Emissions Rate 99% Less Than U.S. Average



Coffeen Plant



A 915-megawatt, generating plant in Montgomery County, IL

Scrubber supplied by Mitsubishi Hitachi Power Systems



SIoux UNITS 1 & 2



PROJECT BACKGROUND



Basic Design Criteria – Sioux 1 & 2

• Absorber MW	535
• Coal Type	Bituminous/PRB
• Sulfur Content (%)	2.15
• Inlet SO ₂ Conc (ppmd – 3% O ₂)	2,048
• Inlet SO ₃ Conc (ppmd – 3% O ₂)	14 – 17
• Inlet Dust (lb/106 Btu)	0.07
• Gas Flow Rate (acfm)	1,915,000
• Inlet Temp. (deg. F)	340



RESULTS OF PERFORMANCE TESTS AT SIOUX

<u>Parameter</u>	<u>Guarantee</u>	<u>Test Result</u>
• Particulate Emissions	≤ 0.015 lb/MMBtu	0.0062 lb/MMBtu
• SO ₂ Removal	$\geq 99\%$ Removal	99.65% Removal
• SO ₂ Emissions	≤ 0.04 lb/MMBtu	0.005 lb/MMBtu
• SO ₃ Removal	$\geq 60\%$ Removal	72.25% Removal
• Mercury Removal	$\geq 90\%$ Removal of Oxidized Mercury	98.7% Removal


Boswell – Cohasset, MN



Boswell FGD Performance



SO₂ Removal vs. Time



KCP&L LaCygne



Now operational, our newest installation at KCP&L La Cygne is meeting all emission guarantees

High Flux, Variable Density Spray Arrangement



- High Spray Flux Minimizes Velocity Variation
- High Spray Flux Maximizes Gas-Liquid Contact
- Higher Nozzle Density Near Absorber Wall Increases Spray Coverage and Eliminates Sneakage
- Progressive Flux Density Moves Gas Away From the Absorber Wall Toward the Center



Possible performance issues



- Nozzle Pluggage
 - Deposit build up
 - Fouling
- Improper grinding of the limestone
- Inlet Pluggage (low load)
- Solids Level
- pH



- Integral Chimneys for Tight Site Retrofits
 - Compact Absorber for Small Unit Retrofits
- Mercury Capture
 - SCR Co-Benefit
- Advanced Venturi Scrubber

2020


2015

2010

Integral Chimneys for Tight Sites




Process of Hg Removal by SCR + FGD




SCR Catalyst is a key component for mercury oxidation

TRAC[®] - Mercury Oxidation Catalyst




TRAC[®] Has Higher Hg Oxidation & Maintains Low SO₂ Conversion

TRAC[®] Reaction Model



Conventional SCR

NH_3 Active site for DeNOx



TRAC

α Component Can Inhibit SO_2 Conversion Rate and Enhance Hg Oxidation Performance.


Relative Performance of TRAC[®]



1st High Mercury Oxidation


2nd High DeNOx Performance

3rd Low SO₂ to SO₃ Conversion



Above Chart Represents Typical Results



SCR + FGD Co-Benefit with TRAC[®] Catalyst



SCR catalyst is a key component for mercury oxidation



Mercury Removal Across Wet FGD



**Oxidized and particulate mercury is effectively removed in WFGD
Effective additives are being developed for controlling re-emissions**

Origin of the EAD™ Scrubber




EAD Pilot Plant (1986, Gardanne, France)


- Patented
- Developed in the 1980s
- The Original *Enhanced All Dry* Process
- External Solids Humidification
- Simple, Flexible

EAD is the original CDS Technology developed in the 1980s

EAD™ Simplified



EAD™ Basic Principle



The EAD Scrubber is a Transport (Entrained Flow) Reactor


Coupled To

A Low Air-To-Cloth Ratio Fabric Filter

And


An External Solids Recycle and Humidification System.

Venturi Absorber



- Entrained flow - no fluidized bed to maintain
- Venturi nozzle – turbulence / mixing
- Very high apparent stoichiometry due to solids recycle
- Energy recovery section – low pressure drop
- No internals to plug or erode
- Lime injected independent of solids recycle for fast response
- No water injection in absorber

EAD™ Basic Principle



- Reaction takes place in an entrained flow absorber
- Water added to the surface of the recycled solids:
 - Cools the flue gases to the ideal reaction temperature
 - Lowers the hydrated lime surface temperature
 - Increases the humidity at the point of reaction
- This provides optimum conditions for reaction of the hydrated lime with acid gases.



Questions??