


REINHOLD ENVIRONMENTAL Ltd.



2015 NO_x-Combustion Round Table & Expo Presentations

February 23 & 24, 2015, in Richmond, VA / Hosted by Dominion

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



Plant Optimization for Increased Efficiency

Matt Dooley

Alstom Power

23 Feb 2015

ALSTOM
Shaping the future

Agenda

- Objective
- Brief Introduction to **ALSTOM** Asset Optimization Group
 - Reliability
 - Energy Efficiency Thermal Performance
- Background on CO2 Emissions
- Impact of Carbon Regulation on Plant Profitability
- Energy Efficiency Improvement Process
- New Technologies for Energy Efficiency
- Improving the Measurement of CO2 Emissions




Objective

- It should be obvious that improved energy efficiency will result in less fuel being burned to produce power at a lower cost, but also produce less emissions of all types. Energy efficiency is a win-win for everybody.
- The objective of this presentation is to explain Alstom's approach to improving the profitability of a power generation facility through improved reliability and increased energy efficiency.

ALSTOM Power Plant Optimization

Fleet → Plant → System → Component

- Performance Improvement
 - Efficiency
 - Heat Rate/Retrofits
 - Capacity/Parasitic Load
 - OPR Power Block/Cold End/Plant Systems
 - Flexibility
 - Fuel/Cycling
 - Regulatory
 - Emissions/Closed Cooling/Water Usage
- Reliability/Availability
 - Revenue Maximization
 - Maintenance/Outage Spend Optimization



Integration of Key Capabilities



O&M Experience







Plant Design




Product Knowledge

Customer



Process Overview

The processes are integrated, and they share and exchange the same data for accuracy and standardization



RELIABILITY

WPCA 22Jan 2014 Slide 6

© ALSTOM 2013. All rights reserved. Information contained in this document is indicative only. No representation or warranty is given or should be relied on that it is complete or correct or will apply to any particular project. This will depend on the technical and commercial circumstances. It is provided without liability and is subject to change without notice. Reproduction, use or disclosure to third parties, without express written authority, is strictly prohibited.

PRA Based Reliability Assessment Program

OBJECTIVE: Create a dynamic decision model that...

- Integrates the data from the existing Customers databases
- Predicts where and when failures may occur - Fleet/Plant/Unit
- Quantifies the impact on Operations, **Maintenance and O&M budgets**
- Provides “real time” input for integrated plans and actions at: all levels (plant/planning/super management)

Example of Application

- Mid-West Utility 4 x 600 MW Coal-Fired Plant

- Modeling and Data Statistics:

- | | |
|------------------------------|--------|
| • Number of Systems Modeled | 12 |
| • Total Number of Components | 65 |
| • CMMS Events Analyzed | 53,744 |
| • NERC Events Analyzed | 2,789 |

- Results of Reliability Program

- Simulation closely correlated with **Plant KPIs** & NERC Analyses
- Simulation results used to justify and reprioritize major capital replacements driving EFOR




Reliability Assessment

Results - System Analysis

Analyzed GADS data from 2004-2008, ran a discrete event simulation, projected the results for 2009 and compared them to the actual values.

Furnace Walls	Predicted 2009	Actual 2009
Mean Availability (All Events)	94.1%	95.3%
Expected Number of Failures	8.2	8
Mean Time To First Failure (MTTF)	40	34
System Up Time (Days)	343	349
System Down Time (Days)	21.6	15.9
Total Throughput (MW Days)	211,865	215,414

Plant/System/Component KPI Dashboard



KPIs

- Component Availability
- MTBF (Mean Time Before Failure)
- MTTR (Mean Time To Repair)
- Criticality Index

Asset Optimization

Energy Efficiency and Thermal Performance

*i*LifeCycle™ Energy Assessment Process

The Energy Efficiency and Thermal Performance area looks at the operating plant as a complete system. Consideration is given on how changes in performance in one area impact other equipment in the cycle.

The Energy Assessment identifies areas where the current plant can improve efficiency by making repairs or operational changes. It also considers possibilities for cycle design changes which could further improve efficiency.

Energy Assessment


- Energy Assessment/Thermal Cycle Analysis
 - Engineering & Economic Evaluation
 - Design basis review and benchmarking
 - Plant staff interviews
 - Use of Plant Instrumentation
 - VWO Test/Prior test results review
 - As-Found vs. Design Heat Balance comparison
 - Operational Adjustments to deliver short term results
 - Point solutions on a \$/BTU/kWh pick-up
 - Programmatic and ‘Best in Class’ recommendations

Energy Assessment

Unit #1 Energy Losses

Design Heat Rate 9192 BTU/kWhr
Design Heat Rate 2316 kcal/kWhr
Design Heat Rate 9692 kJ/kWhr

As Found Heat Rate 9488 BTU/kWhr
As Found Heat Rate 2396 kcal/kWhr
As Found Heat Rate 10004 kJ/kWhr



Energy Assessment - Savings

Unit 1 Net Heat Rate		DESIGN		CURRENT	
		9,192		9,488	
Heat Rate Affected Items	Units	Design	Current	Effect on Heat Rate	Yearly \$Savings
1. BOILER PERFORMANCE				50.22	(\$468,345)
AHTR Exit Gas Temperature	Deg F	308	335	63.33	(\$590,581)
Excess Oxygen (O2)	Percent	3.54	3.93	0.00	\$0
Coal Moisture	Percent	30.60	30.60	0.00	\$0
Unburned Carbon Loss	Percent	0.08	0.10	2.16	(\$20,154)
Boiler Efficiency - Other	BTU/NkWhr			-2.85	\$26,544
Blowdown + Boiler Leakage	Percent	0.0%	0.0%	0.00	\$0
SH Desuperheater Spray	Lb/Hr	0	323,807	0.00	(\$16)
RH Desuperheater Spray	Lb/Hr	0	-1	0.00	\$14
SH Steam Temperature	Deg F	1,050	1,053	-4.77	\$44,444
RH Steam Temperature	Deg F	1,050	1,056	-7.66	\$71,404
2. TURBINE PERFORMANCE				233.21	(\$3,236,112)
HP Turbine Efficiency	Percent	85.00	85.87	-11.95	\$111,416
IP Turbine Efficiency	Percent	91.63	92.84	-13.85	\$129,193
LP Turbine Efficiency	Percent	91.41	85.78	259.02	(\$2,415,380)
3. CONDENSER PERFORMANCE				51.45	(\$479,747)
Condenser Back Pressure	In Hg	2.48	2.80	45.41	(\$423,446)
Condenser Subcooling	Deg F	0.00	1.00	6.04	(\$56,301)
4. CYCLE ISOLATION				50.00	(\$466,260)
Steam Line Drain Leakage	Lb/Hr	0.00	0.50	50.00	(\$466,260)
Extraction Drain Leakages	Lb/Hr	0.00	0.00	0.00	\$0
Heater Drain Leakages	Lb/Hr	0.00	0.00	0.00	\$0
Make-up Water Flow	Percent	0.00	0.00	0.00	\$0
5. FW HEATER PERFORMANCE				-5.16	\$48,088
Feedwater Heater TTDs	Deg F	-1.02	-0.51	-5.16	\$48,088
6. AUXILIARY POWER USAGE				9.83	(\$91,658)
Auxiliary Power Use	MW	32.00	32.71	9.83	(\$91,658)
Totals - Estimated Difference		390	BTU/kW Hr	(\$4,694,035)	
Measured Difference		296	BTU/kW Hr	(\$2,759,371)	

Energy Assessment – Prioritized Recommendations

Recommendations for Improving Net Heat Rate

	Cost	Heat Rate Impact	Annual Savings	IRR	NPV
1 Gland Steam + Leaking MS Stop Valve Repair	\$ 400,000	196.6	\$ 4,054,785	1013.7%	\$16,985,912
2 Clean Condenser	\$ 100,000	52.5	\$ 1,082,789	1082.8%	\$4,542,223
3 Repair Air Heater	\$ 400,000	53.9	\$ 1,112,075	277.9%	\$4,389,806
4 Reduce Aux Power	\$ 1,000,000	53.1	\$ 1,095,163	108.2%	\$3,761,859
5 Increase RH temperature	\$ 100,000	21.8	\$ 448,996	449.0%	\$1,829,311
6 Improve FW Heater Performance	\$ 200,000	22.8	\$ 470,446	235.1%	\$1,828,532
7 Repair LP Section of Turbine	\$ 9,000,000	100.8	\$ 2,078,542	10.2%	\$563,748

Recommendations

		N2 Fixed and No CRH to			
		RH Fixed	no CRH	BFPT	Test Design
Gross Power	MW	711.27	703.96	703.15	698.41 722.20
Net Power	MW	679.27	671.96	671.15	666.41 690.20
Fuel Flow	t/h	334.44	332.10	332.65	356.15 353.09
Heat Input	kcal/h (000,000)	1505.00	1494.47	1496.96	1602.73 1588.95
Heat Rate	kJ/kwh	9276.44	9311.71	9338.28	10069.37 9638.55
Heat Rate	kcal/kwh	2215.64	2224.06	2230.41	2405.03 2302.13
Capacity Factor	%	80.0%	80.0%	80.0%	80.0% 80.0%
Revenue per hour		\$45,511	\$45,021	\$44,967	\$44,650 \$46,244
Hourly Savings		\$861	\$372	\$318	\$1,594
Annual Savings		\$6,037,236	\$2,605,492	\$2,226,211	\$11,171,115

Background – Why is Energy Efficiency Important

- Increasing Global Concern for Greenhouse Gas Emissions
- US Congress will eventually pass CO₂ Legislation or EPA will regulate
- Some Form of Cost for emitting Carbon likely
- Increasing recognition of the role of Energy Efficiency in reducing GHG as well as other emissions
- Lack of accurate methodology to measure CO₂ limits implementation of UN Clean Development Mechanism (CDM) under the Kyoto Protocol

Example of Carbon Economics

- 610 MWE Net Coal plant burning Coal
 - 8368 Btu/lb coal with 5.21 % ash
 - Current heat rate 9395 Btu / Net Kwh
 - 85% capacity factor
 - Burns 2551 kTons of coal annually
 - Produces 4.61 million tons of CO₂ annually
- Cost of CO₂ \$10/Ton
- Cost of Coal \$25.10/Ton delivered
- Cost of NO_x Credits \$1000/Ton
- Cost of SO₂ Credits \$250/Ton
- Cost of Ash Disposal \$50/Ton


Existing Economics

Cost of Generation

Annual Costs Million \$

Cost of Fuel	64.0
Cost of NOx Credits	2.1
Cost of SO2 Credits	1.6
Cost of Ash Disposal	6.6
O&M Costs	8.3
Total Cost	82.7

Cost per MWhr \$ 18.21




Carbon Economics

Cost of Generation

Annual Costs Million \$

Cost of Fuel	64.0
Cost of NOx Credits	2.1
Cost of SO2 Credits	1.6
Cost of Ash Disposal	6.6
O&M Costs	8.3
Cost of CO2 Credits	49.6
Total Cost	132.3


Cost per MWhr \$ 29.12



Market Drivers – Fuel


Fuel Cost – Merit Order

Fuel Cost \$/MWh





Market Drivers – Merit Order - Fuel + CO2 cost (CO2 @ \$23/t converted to \$/MWh by station emission intensity)

Fuel Cost + CO2 cost @ \$23/t
\$/MWh



Effect of Cost Reduction on Service Factor



With only a \$1 improvement in the cost of Generation the Plant can expect to increase Service Hours by up to 400hrs or 12%

US Coal Plants 2008 CO₂ Data


Weighting typical ultimate values

Coal Source	Fixed Carbon (%)	Higher Heating Value (Btu/lb)	Coal Fired in Utility Boilers (Million Tons)	Carbon Fired (Million Tons)	CO ₂ produced (Million Tons)	Heat Produced (Million Btu's)
Western	47%	8000	565.5	263.0	964.2	9.0E+09
Appalachian	77%	13650	347.9	266.5	977.0	9.5E+09
Interior	62%	11200	130.2	80.2	294.1	2.9E+09
Total			1043.6	609.6	2235.3	2.1E+10

US Electricity Production 2.0E+12 KW-hr
 US CO₂ Production 2.1E+09 Tons
 US Coal Thermal Energy 2.1E+16 BTU

Net Plant Heat Rate 10,761 BTU/kw-hr
 Overall Efficiency 31.71 %

CO₂ Conversion Rate 0.10 Ton CO₂/MMBTU
 CO₂ Efficiency 2.15 lbs/kwhr




Source: US EIA and Alstom Fuel databases.

CO₂ in top table from fuel analysis CO₂ in lower table from EIA


Range of Heat Rates - 1,098 US Boilers

Distribution of Heat Rates for Coal-fired Generating Units



US Coal Power Plants


Installed Base (GW) vs. Age (years)




Source: Alstom & Energy Velocity databases

Coal Power Plant

Installed GW and Capacity Factor vs. Heat Rate



Heat Rate Capability



CO₂ Reduction Potential

- Given our current annual electric production from coal (1.99×10^{12} kWhr),
- If we reduce losses by 500 BTU/kW per plant (~5%),
- We would achieve an annual reduction of 100 million tons of CO₂ !
- Even greater reductions would be achieved with new Super Critical Boilers

Lower Cost of Energy Leads to Long Term Jobs for Industry

- Increasing the energy efficiency reduces the cost of generation and thus the cost to the Consumer
 - Lower fuel costs
 - Lower maintenance costs
 - Lower operating costs
 - Less emissions
- In the Industrial market reducing energy costs allows industry to be more competitive globally.
 - Lower electric rates by the utility
 - And or
 - Lower internally produced energy costs
- More competitive Industry keeps and increases jobs in the USA for the long term.

So what is stopping us?

New Source Review - NSR

Even the EPA admits that NSR has unintended consequences:

“As applied to existing power plants and refineries, EPA concludes that the NSR program has impeded or resulted in the cancellation of projects which would maintain and improve reliability, efficiency and safety of existing energy capacity. Such discouragement results in lost capacity, as well as lost opportunities to improve energy efficiency and reduce air pollution.”

Source: EPA - New Source Review: Report to the President June 2002

EPA Math (Abbott & Costello video)




Improving Existing Plant Performance


- Establish Target Performance
- Test Existing Unit
 - Using ASME PTC 46 Methodology
- Analyze Differences
- Identify Root cause of performance Issues
- Plan and Implement repairs

EPRI Heat Rate Approximate Impacts for Various Deviations on Plant Performance

HP Turbine Efficiency	18.8	BTU/kWh/%	19.8	kJ/kWh/%
IP Turbine Efficiency	14.5	BTU/kWh/%	15.3	kJ/kWh/%
Throttle Temperature	1.4	BTU/kWh/°F	2.7	kJ/kWh/°C
Throttle Pressure	0.35	BTU/kWh/Psi	5.36	kJ/kWh/bar
RH Temperature	1.3	BTU/kWh/°F	2.5	kJ/kWh/°C
SH Spray Flow	0.246	BTU/kWh/kLb/Hr Flow	0.03	kJ/kWh/kg/s
RH Spray Flow	2.15	BTU/kWh/kLb/Hr Flow	0.29	kJ/kWh/kg/s
Excess O2	29.4	BTU/kWh/%	31.0	kJ/kWh/%
AH Outlet Temp	2.7	BTU/kWh/°F	5.1	kJ/kWh/°C
Condenser Backpressure	204	BTU/kWh/In. Hg	6.36	kJ/kWh/mbar
Make Up	24	BTU/kWh/%	25.3	kJ/kWh/%
Top FW Htr	2.1	BTU/kWh/Deg F(TTD)	4.0	kJ/kWh/°C(TTD)
Next to Top FW Htr	0.54	BTU/kWh/Deg F(TTD)	1.03	kJ/kWh/°C(TTD)
Top FW Htr out of Service	94	BTU/kWh	99	kJ/kWh



14.504	PSI	=	1	bar	=	100	kPa
7.937	klb/h	=	1	kg/s			
0.948	BTU	=	1	kJ			



Efficiency Improvement Options (Steam Power Plants)

Steam Plant Efficiency = (Boiler Efficiency) x (Steam Cycle Efficiency) x (1- Auxiliary power fraction)

Boiler Efficiency Improvements

Reduce Stack Loss

Reduce Stack Temperature

Air Heater Upgrade

Inc Air Flow Through AH

Minimize Tempering air flow

Minimize air leakage

Condensing Heat Exchanger

Sootblowing Optimization

Timing

Sequence

Locations

Nozzles

Pressure

Medium

Reduce Stack Flow

Low Excess Air

Reduced Air Infiltration

Reduce Stack Moisture

Fuel Change

Reduce Other Losses

Less Unburned Carbon / CO etc.

Flyash carbon separation/combustion

OFA / Burner / Mill optimization

Better Insulated Unit

Heat Recovery from Ash

Pulverizer Rejects

Steam Cycle Efficiency Improvements

Higher Steam Conditions

Pressure, Temperature

Additional Reheat Stages

Additional Regeneration

More FWH's

Topping De-superheaters

Lower Condenser Pressure

Cooling Tower Improvements

Better Steam Expansion

Blade Profile Improvements

Minimize leaks

Reduce Exhaust Loss

Larger LP Turbines

Lower Pressure Drops

Steam and Water

Better Pump Efficiency

Boiler Feed Pump

Condensate Pump

Cooling System Pumps

Smaller Leakage Quantities

Minimize De-superheater Spray Quantities

Reheater(s)

Superheater

Auxiliary Power Reductions

Lower Excess Air

Lower Pressure Drops

Air and Gas Side

CFB combustor, FBHE

Less combustor inventory

Water Steam Side

Better Component Efficiencies

Fans

Pressurized unit (no ID fan)

Pulverizers

Pumps

Generator

Transformer

Drive Motors

Air Pollution Control System

Adipic acid addition

Coarser limestone

Reduce flue gas bypass

ESP instead of Fabric Filter

Miscellaneous

Sootblowing Optimization

Reduce Air Heater Leakage

Proven New Technologies to help improve Efficiency

- New Unit Technologies – Supercritical and Ultra Supercritical
- Turbine upgrades with new higher efficiency blading
- New Condenser Designs
- New Cooling Tower designs
- New Controls
- Boiler design changes to reflect current operation
- Pulverizers – Dynamic Classifiers etc, to reduce Carbon Loss
- AH – Leakage control, high efficiency baskets
- Variable speed drives for Fans, CW pumps for part load operation

Supercritical versus Subcritical Cycle - Impact on Emissions

		Subcritical	Supercritical
Plant Efficiency, %*		34 - 37	37 - 41
Plant Heat Rate, Btu / kW-hr	10,000 - 9,200	9,200 - 8,300	

Plant Efficiency, %

34%

37%

41%

Fuel Consumption and Total Emissions including CO₂

Base

Base-8%


Base-17%



*** HHV Basis**


Sub vs. Supercritical / Ultra-Supercritical Cycles

Heat rate improvement vs. steam conditions (single reheat)



Lower Fuel Consumption and Lower Emissions/ kWh

Comparable Availability of Supercritical and Subcritical Units



Studies to investigate differences in availability due to subcritical / supercritical steam parameters:

- **NERC-US (1989):**
“Boiler tube failure trends”
- **VGB-D (1988-97):**
“Availability of thermal power plants”

All studies came to the conclusion:

“There is no significant difference in availability due to subcritical/supercritical steam parameters for today’s plant designs”


Optimized Plant Retrofit

Essentially a Steam Turbine *and* Boiler Retrofit *and* Emissions Control System Evaluation and Upgrade conforming to a thermal specification which is established by a team of plant specialists (Alstom & Customer) to optimize the plant as a whole.



Turbine Retrofit

+



Boiler Retrofit

+




Environmental
Retrofit

Optimized Plant Retrofit Objectives & Scope

- Maximize potential of existing power plant assets
 - Identify latent steam generating capability of boiler
 - Determine requirements for turbine to accept full boiler output
- Optimize increase in Heat Rate, Efficiency, & Power Output
- Assess Balance of Plant capabilities/limitations
 - Assess BOP systems and components (fans, pumps, ash handling, water handling, etc.) to support boiler turbine island
- Reduce Relative Emissions with Efficiency and/ or Equipment Improvements




CO₂ Emissions vs Net Plant Efficiency




New Condenser Design

- Optimizes Thermal Performance
 - Minimizes air binding
 - Less Condensate sub cooling



Cooling Tower Improvements

Improvement Cell Cooling Towers



Presentation title 01/01/2007 P 15

ALSTOM © 2007. We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

Controls Modification

- Modern DCS Controls
- Neural Net Controls
- Intelligent Sootblowing
- Advanced Steam Temperature Control



Before and After Controls Upgrade



Boiler Modifications to Improve Efficiency

- Optimizing Boiler Pressure Parts Surfaces
 - Attaining Full Steam Temperatures
 - Optimizing Sprays
 - Controlling Exit Gas Temperature
 - Optimizing Excess Air Levels

Air Heater Heat Transfer Surface Development

Cold End - DNF[®] Surface

Old NF profile



Latest DNF[®] profile




Upgrading the cold end layer to the latest design of DNF[®] heat transfer surface profiles can enhance thermal recovery while maintaining closed channel cold end cleanability of the surfaces.


Heat Transfer Surface Development

Hot End - DN7™ Surface

Old DU profile




Latest DN7™ profile



Upgrading the hot end layers to the latest design of DN7™ heat transfer surface profiles can enhance thermal recovery, and improve flow distribution through the layers.


Pulverizer DYNAMIC™ Classifier Applications



DYNAMIC™ Classifier Applications – Case Study


Test	Unit # 2	
	Base Line Test	Guarantee
% UBC	6.24%	2.85%
% UBC Reduction		54%
% Thru 200 Mesh	58.5% to 68.4%	81.1% to 88.1%
% Thru 50 Mesh	97.9% to 99.1%	99.9% to 99.97%

Joint Project Team Design (JPTD) Process



JPTD Boiler & Turbine Modeling Results Example

Run No. 21 Run Type Same as Run 20 (with new Steam Turbine Condition with RH Finishing on 9.5" centers - platenized & New In-Line SFS Econ) but running Steam Turbine at 2470psig Throttle pressure and increase main steam flow and 6 mill in Service



General Performance Information

SH Steam Flow	3,935,613 lbs/hr
RH Steam Flow	3,535,221 lbs/hr
SHO Temp	1001.0 °F
SH Desup Spray	0.30 %
RH Desup Spray	1.10 %
SHDesuperheater Spray	11263 lbs/hr
RHDesuperheater Spray	39359 lbs/hr
RHO Temp	1004.0 °F
RHDESUP OUT TMP	610.0 °F
Feedwater Temp	491.0 °F
Econ Exit Gas Temp	769.0 °F
AH TGO Uncorr	320.0 °F
AH TGO Corr	306.0 °F
Tilt	-11 degree
Excess Air	26 %
Fuel Fired	618,334 lbs/hr
Boiler Efficiency	85.45 %
NHI/PA	2.08 Mbtu/h

Steam Turbine Performance

Output	571,060 KWs
Turbine Heat Rate	8,128 BTU/K
Superheater Outlet Flow	3,935,613 lbs/hr
Main Steam Temp.	1,000 °F
Throttle Pressure	2,470 psia
Cold RH Flow	3,495,862 lbs/hr
Cold RH Pressure	638 psia
Cold RH Temp.	633 °F
Hot RH Flow	3,531,173 lbs/hr
Hot RH Pressure	569 psia
Hot RH Temp.	1,000 °F
Reheater Spray Flow	35,312 lbs/hr
Main Condenser Pressure	1.8 psia

Mill Performance

Air In Per Mill	197,938 lbs/hr	Outlet Moisture	15.66 %
COAL FLOW PER MILL	103,056 lbs/hr	Hot Air Temperature Required	569.6 °F
NO. MILLS IN SERVICE	6 OF 6	TEMPERING AIR TEMP.	82 °F
Grinding Capacity	79.1 %	AVAILABLE HOT AIR TEMP.	691 °F
MIXTURE TEMPERATURE	146 °F		

Boiler Parameters Impact on Heat Rate

Superheater Steam Temp. Effects on Heat Rate

PARAMETRIC VARIABLES

2.00 Fuel Cost \$/Million BTU

600 Generator Output MW

80.00 Capacity Factor Percent

**Yearly Fuel
Savings**

\$176,602

CONDITIONS

10,200 Assumed Net Unit Heat Rate - Btu/KWhr

1,005 New SH Steam Temperature - deg.F

990 Original SH Steam Temperature - deg.F

*Calculations are based on 1986
EPRI Report CS-4554 on "Heat
Rate Improvements Guidelines for
Existing Fossil Plants"*

-21.00 Btu/kWh Effect on Heat Rate

0.21% Change in Heat Rate

Boiler Parameters Impact on Heat Rate

Reheater Steam Temp. Effects on Heat Rate

PARAMETRIC VARIABLES

2.00 Fuel Cost \$/Million BTU
600 Generator Output MW
80.00 Capacity Factor Percent
3.00 Yearly Fuel Inflation Percent
5 Year Evaluation Period

Yearly Fuel Savings
\$163,987

CONDITIONS

10,200 Assumed Net Unit Heat Rate - Btu/KWhr
1,005 New RH Steam Temperature - deg.F
990 Original RH Steam Temperature - deg.F

Calculations are based on 1986 EPRI Report CS-4554 on "Heat Rate Improvements Guidelines for Existing Fossil Plants"

-19.50 Btu/kWh Effect on Heat Rate

-0.19% Change in Heat Rate

Boiler Parameters Impact on Heat Rate

Reheat Desuperheater Effects on Heat Rate

PARAMETRIC VARIABLES

2.00 Fuel Cost \$/Million BTU

600 Generator Output MW

80.00 Capacity Factor Percent

Yearly Fuel Savings
\$690,829

CONDITIONS

10,200 Assumed Net Unit Heat Rate - Btu/KWhr

0 New Spray Flow - lbs/hr

150,000 Original Spray Flow - lbs/hr

3,725,000 Cold Reheat Steam Flow - lbs/hr

*Calculations are based on 1986
EPRI Report CS-4554 on "Heat
Rate Improvements Guidelines for
Existing Fossil Plants"*

-82.15 Btu/kWh Effect on Heat Rate

0.81% Heat Rate Improvement

Boiler Parameters Impact on Heat Rate

Superheat Desuperheater Effects on Heat Rate

PARAMETRIC VARIABLES

2.00 Fuel Cost \$/Million BTU
600 Generator Output MW
80.00 Capacity Factor Percent

Yearly Fuel Savings
\$117,734

CONDITIONS

10,200 Assumed Net Unit Heat Rate - Btu/KWhr
0 New Spray Flow - lbs/hr
200,000 Original Spray Flow - lbs/hr
4,080,000 Main Steam Flow - lbs/hr

*Calculations are based on 1986
EPRI Report CS-4554 on "Heat
Rate Improvements Guidelines for
Existing Fossil Plants"*

-14.00 Btu/kWh Effect on Heat Rate

0.14% Heat Rate Improvement

Boiler Parameters Impact on Heat Rate

Boiler Efficiency Effects on Heat Rate

PARAMETRIC VARIABLES

2.00 Fuel Cost \$/Million BTU
600 Generator Output MW
80.00 Capacity Factor Percent

Yearly Fuel Savings
\$484,621

CONDITIONS

10,200 Assumed Net Unit Heat Rate - Btu/KWhr
88.00 Original Boiler Efficiency
88.50 New Boiler Efficiency

*Calculations are based on 1986
EPRI Report CS-4554 on "Heat
Rate Improvements Guidelines for
Existing Fossil Plants"*

-57.63 Btu/kWh Effect on Heat Rate

0.56% Heat Rate Improvement

The Performance & Environmental Monitor

This system has two objectives;

- To be a state of the art measurement system for CO₂ emissions exceeding by far the accuracy of anything available today
- A performance enhancement service where experts from Alstom work with plant personnel to improve energy efficiency (heat rate) and thus reduce the carbon footprint of the facility.

The Performance and Environmental Monitor*

- CO2 Monitor
 - More accurate than conventional CEMS (CEMS are potentially +/- (more likely +) 7.5% Alstom CO2 monitor +/- 1.6%)
 - CEMS tend to overestimate stack flow & Factors are biased high
 - The 5.9% difference is worth \$2.7 Million additional per year for a typical 600 MW Coal-Fired Unit (CO2 @ 10\$/T)
- Heat Rate Deviation reporting
 - Identifies areas where efficiency is being lost
- Remote Expert Support
 - Helps customer sort through data and identify causes of heat rate deviations
 - Recommends solutions to identified problems




Methodology


- Boiler Efficiency by Heat Loss Method
- Heat absorbed by steam divided by Boiler Efficiency to determine heat input per hr
- Pounds of CO₂ per million BTU determined from fuel analysis
- Product of Lb CO₂ per MMBTU x Heat Fired = lbs of CO₂ per hr

Uncertainty Analysis Result

- CEMS are +/- 7.5%
- Direct Coal Flow Method +/- 5.7% (Estimate is probably low)
- Alstom Energy Balance CO₂ monitor +/- 1.6%



Comparison of a 600 MW Unit Emissions using Alstom Energy Balance CO₂ Monitor vs. Conventional Techniques



Eight Day Period - 11,520 Scans

Alstom Monitor tons of CO₂ reported was 5,603 tons less than the CEMS CO₂ reported, or about 700 tons per day


Existing Economics

Cost of Generation

Annual Costs Million \$

Cost of Fuel	64.0
Cost of NOx Credits	2.1
Cost of SO2 Credits	1.6
Cost of Ash Disposal	6.6
O&M Costs	8.3
Total Cost	82.7

Cost per MWhr \$ 18.21




Carbon Economics

Cost of Generation

Annual Costs Million \$

Cost of Fuel	64.0
Cost of NOx Credits	2.1
Cost of SO2 Credits	1.6
Cost of Ash Disposal	6.6
O&M Costs	8.3
Cost of CO2 Credits	49.6
Total Cost	132.3

Cost per MWhr \$ 29.12



Carbon Economics

(with more accurate CO2 Measurement)

Cost of Generation


Annual Costs Million \$

Cost of Fuel	64.0
Cost of NOx Credits	2.1
Cost of SO2 Credits	1.6
Cost of Ash Disposal	6.6
O&M Costs	8.3
Cost of CO2 Credits	46.8
Total Cost	129.6

Cost per MWhr \$ 28.52

5.9% reduction

Total Savings = \$2.7 Million annually



Q&A





www.alstom.com

ALSTOM
Shaping the future

Methodology

$$\text{INPUT} = \text{OUTPUT} + \text{LOSSES}$$

Input-Output or Direct Method

$$\eta_{blr} = \frac{\text{Output}}{\text{Input}}$$

$$\eta_{blr} = \frac{\text{Input} - \text{Losses}}{\text{Input}}$$

Energy Balance or Heat Loss Efficiency

Indirect Method

$$\eta_{blr} = 1 - \frac{\text{Losses}}{\text{Input}}$$

Calculate Boiler efficiency η_{BLR} in accordance with ASME PTC 4

1) Calculate the heat supplied to the boiler using the relationship

$$\text{HeatInput} = \frac{\text{EnergyAbsorbed}}{\text{BoilerEfficiency}}$$

$$Q_{FIRED} = \frac{Q_{BLR}}{\eta_{BLR}}$$

Uncertainty Comparison

	Average Value	Total Positive		Total Negative		Student t	Random Component	Positive Systematic	Negative Systematic
		%	Tons	%	Tons				
Customer 1		%	Tons	%	Tons		Tons	Tons	Tons
Indirect Method	628.84	2.6%	16.06	2.4%	14.88	2	0.26	16.05	14.87
Direct Method	735.26	5.7%	41.68	5.7%	41.68	2	0.56	41.67	41.67
CEMS	609.14	8.3%	50.36	7.5%	45.65	2	0.36	50.35	45.64
Customer 2									
Indirect Method	176.54	2.9%	5.17	2.3%	4.10	2	0.11	5.16	4.09
Direct Method	191.54	5.7%	10.86	5.7%	10.86	2	0.11	10.85	10.85
CEMS	180.47	8.8%	15.82	8.0%	14.51	2	0.35	15.81	14.50

Uncertainty Analysis

Random Component

Systematic Component

Standard Deviation of the Sample

$$S_x = \sqrt{\sum_{i=1}^N \frac{(X_i - \bar{X})^2}{(N-1)}}$$

Standard Deviation of the Mean

$$\bar{S}_x = \frac{S_x}{\sqrt{N}}$$

$$S_R = \sqrt{\sum_{i=1}^N (\theta_i' \bar{S}_x)^2}$$

Sensitivity Coefficient

$$\theta = \frac{(\Delta R)}{(\Delta X)}$$

$$U = \sqrt{tS_r^2 + b_r^2}$$

$$\bar{b}_x = \sqrt{b_{\%}^2 + b_{UOM}^2}$$

$$b_R = \sqrt{\sum_{i=1}^N (\theta_i' \bar{b}_x)^2}$$

$$M_{qCO_2} = \frac{\%C}{HHV} \times \frac{MW_{CO_2}}{MW_C} \times 10^6 = \frac{\%C}{HHV} \times \frac{44}{12} \times 10^6 \quad \text{Lb CO}_2/\text{ Million BTU}$$

$$M_{eCO_2} = \frac{M_{qCO_2} \times Q_{Fired}}{kW} \quad \text{Lb CO}_2 / \text{ kW}$$

$$M_{TCO_2} = \frac{M_{qCO_2} \times Q_{Fired}}{2000} \quad \text{Tons CO}_2 / \text{ hr}$$

Note: Q_{Fired} is in Million BTU/hr

Calculate Boiler efficiency η_{BLR} in accordance with ASME PTC 4

1) Calculate the heat supplied to the boiler using the relationship

$$\text{HeatInput} = \frac{\text{EnergyAbsorbed}}{\text{BoilerEfficiency}}$$

$$Q_{FIRED} = \frac{Q_{BLR}}{\eta_{BLR}}$$