

REINHOLD ENVIRONMENTAL Ltd.



**2015 NO_x-Combustion Round Table
& Expo Presentations**

February 23 & 24, 2015, in Richmond, VA / Hosted by Dominion

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.

Implementation of Co-Firing of Biomass or Natural Gas

Danny Gelbar

2/23/15

ALSTOM Power Inc. – Thermal Services



Biomass Background

Biomass Fundamentals and Technical Considerations

Natural Gas Background

Natural Gas Fundamentals and Technical Considerations

Why Co-Fire Biomass?

- Greenhouse Gas Emissions
- Other Environmental Issues

Greenhouse Gas Emissions

- Biomass is Considered a CO₂ “Neutral Fuel”
- Major Concern in Some Parts of the World

Biomass Background

Biomass Fundamentals and Technical Considerations


Natural Gas Background

Natural Gas Fundamentals and Technical Considerations

Biomass Categories

- Untreated wood
 - Fire wood, forest residues, logs
- Agricultural residues
 - Palm kernels, olive pits, sunflower hulls, bagasse
- Treated biomass
 - Pelletized or torrefied products, sawdust, sander dust
- Energy crops
 - Herbaceous crops such as miscanthus, switchgrass
 - Short rotation coppice, including willow poplar
- Waste derived fuels
 - Food industry
 - Sewage sludge, waste derived fuels, RDF, MSW

Types of Biomass



Sample Biomass Fuel Types



Pellets



Miscanthus




Straw



Wood chips



Waste wood



Wheat shorts

2-23-15- P 7

Sample Biomass Fuel Types



Logs ~45% H₂O



Woodchips ~30% H₂O



Pelletized wood ~10% H₂O

**Miscanthus
~20% H₂O**



2-23-15- P 8




**Coppiced
Willow
~45% H₂O**

Biomass vs. Coal Fuel and Ash Analyses



FUEL		Coal (Bit)	Coal (Subbit)	Wood Pellet	Coal (Lignite)	50% H ₂ O Wood
Excess Air		(20% XA)	(20% XA)	(20% XA)	(20% XA)	(30% XA)
Fuel Analysis						
Carbon	%	66.6	50.64	48.23	41.69	21.68
Hydrogen	%	4.7	3.45	5.86	2.8	2.26
Nitrogen	%	1.2	0.7	0.09	0.8	0.15
Oxygen	%	6.8	11.72	36.3	12.71	14.23
Sulfur	%	3.7	0.4	0.01	0.43	0.02
Ash	%	8.5	5.2	1.5	10.74	11.59
Moisture	%	8.5	27.9	8	30.83	50.07
		100.0	100.0	100.0	100.0	100.0
VM	%	38.0	31.0	70.0	27.8	32.2
HHV	Btu/lb	12,000	8,692	7,945	7,154	3,625
Typical XA	%	18	20	20	20	30
Wet Air	lb/MBtu	758.5	767.7	765.2	757.3	745.3
Dry Gas Weight	lb/MBtu	929.9	945.1	936.7	942.7	1008.3
% Change in Fuel Flow (lb/MBtu vs. Bit)	%	100%	143%	162%	164%	318%
% Change in Air Flow (lb/MBtu vs. Bit)	%	100%	102%	99%	100%	106%
% Change in Total Products (lb/MBtu vs. Bit)	%	100%	105%	104%	105%	123%
Boiler Efficiency	%	88.0	85.5	84.0	84.1	68.0
Weighted Total Fuel (Based on B.E. or Q _p)	lb/MBtu	86	127	147	148	356
Weighted Total Air (Based on B.E. or Q _p)	lb/MBtu	1031	1084	1073	1080	1416
Weighted Total P (Based on B.E. or Q _p)	lb/MBtu	1118	1212	1219	1228	1772
% Change in Fuel Flow (vs. Bit)	%	100%	147%	170%	171%	412%
% Change in Air Flow (vs. Bit)	%	100%	105%	104%	105%	137%
% Change in Flue Gas Flow (vs. Bit)	%	100%	108%	109%	110%	159%

Constituent Comparison with Coal on Heat Input Basis



2-23-15- P 10

Pelletized Biomass

- Lower Moisture and Required Storage Volume
- Potential for minimal reduction in boiler efficiency based on current coal fired
- Smaller increase in flue gas flows versus co-firing higher moisture biomass fuels

	Pelletized Wood Biomass	Woodchips Biomass
Proximate Analysis:		
% Moisture	6.00	30.00
% Ash	0.40	1.15
% Volatile	76.30	57.40
% Fixed Carbon	17.30	11.45
Ultimate Analysis:		
% Moisture	6.10	30.00
% Carbon	45.70	35.52
% Hydrogen	5.60	4.19
% Nitrogen	0.20	0.04
% Sulfur	0.01	0.08
% Ash	0.40	1.15
% Oxygen	41.99	29.02
HHV (BTU/lb)	7,900	6,050
lb Fuel/MMBtu	127	165

- Suspension Firing
 - Direct injection
 - Using Mills to reduce particle size
- Stoker Firing

Key Parameters Effecting Technology Choices




- Fuel Sizing
- Fuel Constituents
- Fuel Fired Quantity & Variability
- Physical Constraints
- Performance Constraints
- Economic Constraints
- Environmental Constraints

Suspension Fired with Pulverized Coal



- Typ. Can Co-fire 5% to 25% Biomass
- Typ. Moisture Range of 10% to 30%
- Requires Finer Particle Sizing
- May Require Dump Grate (depending on size of fuel being fired)




Principally, there are two main methods for firing biomass within an existing coal boiler:


- Co-Milling
 - Generally limited by fuel type up to <10%

- Dedicated co-firing
 - Experience up to 20+% with dedicated mills


Biomass Pellets Firing System Design Concept #1



Biomass Pellets Firing System Design Concept #2




Biomass Firing System Design Concept #3



Spreader Stoker Fired

- Designed to Fire 50 to 100% Biomass
- Can Co-fire Oil, Gas, PC or Stoker Coal
- Can Handle Coarse Material (4" top size)
- Can Handle Wet Material (~55% moisture)
- Uses Belts, Drag Chains and Feed Screws
- Use Gravity Feed Chutes and Air Assisted Spreaders



Co-Firing with Biomass: Key Issues & Challenges



- Local Regulations
- Transport & Storage of Volatile Fuel
- Volume of Material Due to Low Heating Value & Lower Density
- Site Constraints
- Dust Emissions
- Variability of Fuel; Moisture Content, Ash Constituents, N, Cl, etc.
- Boiler Performance
- AQCS Performance
- Ash Quality / Saleability of Ash

Co-Firing with Biomass (cont'd): Boiler Performance



- Boiler Load
 - Fuel Input
 - De-rating
- Boiler Efficiency
- Steam Temperatures
- Gas Weights / Velocities
- Flue Gas Outlet Temperature
- Slagging / Fouling
- Corrosion / Erosion
- Air Heaters
- Auxiliary Equipment – ESP, FD, ID Fans, etc

Co-Firing with Biomass (cont'd): Boiler Performance




- Impact on Boiler Load, Efficiency and Steam Temperatures
- Impact on Flue Gas Velocities (Erosion) and Flue Gas Outlet Temperatures
- Impact on Sub-cooling Delta Temperature & Circulation
- Impact on Furnace Slagging and Fouling
- Impact on Corrosion / Erosion of Various Boiler Components / Sections
- Location of Biomass Burner
- Impact on Emissions (I.e. NO_x, SO_x, CO, etc.)
- Impact on Backend Equipment (i.e., ESP, Baghouse, SCR, etc.)
- Impact on Auxiliary Equipment (i.e., FD Fans, ID Fans, Air Heaters, etc.)
- Selection of Equipment Suitable for Grinding Type of Biomass Materials
- Design / Location of Milling Plant and Pneumatic Transport system
- Dust Control and Explosion Prevention

2-23-15- P 22

Storage Considerations

- Bulk Storage
 - Acts as a buffer between delivery and utilization
- Considerations
 - Fuel type and physical properties
 - Low energy density compared to coal
 - Bulk density
 - Moisture content
 - Storage time, weekend or longer
 - Delivery schedule
 - Climatic conditions



Fiddler's Ferry Co-firing Experience

ALSTOM

Fiddlers Ferry

- 4 x 500 MWe T-Fired Boilers - Units 2 and 4
- First dedicated Biomass co-firing plant in the UK
- Previously tried co-milling, decision made to go to dedicated co-firing system
- 20% MCR Biomass by heat input basis
- Wide range of biomass fuels; wood pellets, palm kernels, olive stones, olive cake <15% moisture

Design of dedicated biomass co-firing system




Operational findings

- Plant fully commissioned and operational since mid 2006
- Plant availability ~95%
- CO₂ savings per year = > 1million tons/yr (based on 100% capacity)
- Plant consistently delivers rated output of 100 MWe per unit
- Each stream capable of processing up to 1440 t/day
- Multi fuel capability – limited moisture <15%

-
- Gas volumes increase slightly due to higher proportion of moisture within the gas stream and increased gas temp.
 - No major impact on steam temp
 - Slagging and fouling not observed
 - 20% MCR Biomass has minimal impact on efficiency <0.4% diff.
 - Performance of ID fan and ESP not affected

Emissions - CO₂, NO_x, SO₂ and UBC (Palm Kernels)



Economics

- More Cost Effective to Co-fire Biomass at Existing Plant than to Build a New Facility
- Potential Low Cost “Opportunity” Fuel Supply
- Potential State & Federal Funding Incentives
- Potential “Green Power” Pricing Premiums

Agenda



Biomass Background

Biomass Fundamentals and Technical Considerations

Natural Gas Background


Natural Gas Fundamentals and Technical Considerations

Items to be covered


- Boiler Sizing
- Gas Firing – Emissions
- Converting Bituminous Coal Fired Boiler to Gas Firing
- Converting PRB Coal Fired Boiler to Gas Firing
- Pulverizer and Fan Systems
- Summary

Normal Boiler Sizing

- Boilers are normally designed for a specific fuel.
- Anytime a boiler has a change in fuel, there will be performance compromises.



Coal Fired Boilers



2-23-15- P 34

Basic Fuel Effects on Performance



FUEL		Coal (Bit)	Coal (Subbit)	Coal (Lignite)	Natural Gas	Oil
Excess Air		(20% XA)	(20% XA)	(20% XA)	(12.5% XA)	(20% XA)
Fuel Analysis						
Carbon	%	66.6	50.64	41.69	71.77	86
Hydrogen	%	4.7	3.45	2.8	23.9	10.1
Nitrogen	%	1.2	0.7	0.8	4.32	0.7
Oxygen	%	6.8	11.72	12.71		0
Sulfur	%	3.7	0.4	0.43		2.55
Ash	%	8.5	5.2	10.74		0.35
Moisture	%	8.5	27.9	30.83		0.3
		100.0	100.0	100.0	100.0	100.0
VM	%	38.0	31.0	27.8		-
HHV	Btu/lb	12,000	8,692	7,154	22,808	18,096
Typical XA	%	18	20	20	10	6
Wet Air	lb/MBtu	758.5	767.7	757.3	732	742.6
Dry Gas Weight	lb/MBtu	929.9	945.1	942.7	763.0	893.4
% Change in Fuel Flow (lb/MBtu vs. Bit)	%	100%	143%	164%	58%	72%
% Change in Air Flow (lb/MBtu vs. Bit)	%	100%	102%	100%	91%	98%
% Change in Total Products (lb/MBtu vs. Bit)	%	100%	105%	105%	88%	96%
Boiler Efficiency	%	88.0	85.5	84.1	84.5	88.9
Weighted Total Fuel (Based on B.E. or Q _F)	lb/MBtu	86	127	148	52	62
Weighted Total Air (Based on B.E. or Q _F)	lb/MBtu	1031	1084	1080	975	1002
Weighted Total P (Based on B.E. or Q _F)	lb/MBtu	1118	1212	1228	1026	1064
% Change in Fuel Flow (vs. Bit)	%	100%	147%	171%	60%	72%
% Change in Air Flow (vs. Bit)	%	100%	105%	105%	95%	97%
% Change in Flue Gas Flow (vs. Bit)	%	100%	108%	110%	92%	95%

2-23-15- P 35

Gas Firing - Emissions

NOx is formed by two primary mechanisms:

- Thermal fixation of atmospheric nitrogen--
“thermal NOx”
- Fixation of nitrogen contained in the fuel--
“fuel NOx” (no fuel NOx in gas)

Boiler Operation

- Unit Load
- Tilt Position
- Excess Air
- WB Air Distribution
- Fuel/Air Staging

Boiler Design

- Heat Release Rates
- Air Inleakage
- Firing Systems Design

Fuel Properties

- Fuel Nitrogen - Not applicable

- Current NOx Emissions Levels
- Required (or desired) NOx Emissions Levels
- Available Options
- Current Performance
- Performance Requirements

Reduce Burner Zone Stoichiometry

- Low NOx Burners
- Lower Excess Air
- Overfire Air (OFA)
- Flue Gas Recirculation

Lower Flame Temperature

- Reduce Secondary Air Temperature
- Reduce Load
- Steam/H₂O Injection
- Flue Gas Recirculation
- Spread Out the Heat Release

Flue Gas Recirculation (can also be used to maintain outlet steam temperatures)

- Forced
- Induced
- Premixed

Reburn

SNCR

Biomass Background

Biomass Fundamentals and Technical Considerations

Natural Gas Background

Natural Gas Fundamentals and Technical Considerations

Possible Issues Include:

- An increase in SH desuperheater spray water flow
- An increase in RH desuperheater spray water flow
- An increase in forced draft fan volumetric flow
- SHO & RHO steam temperatures may not be achieved in some cases
- These issues may or may not require capacity increases in their respective equipment

Bituminous Coal with Natural Gas Co-Firing

Solution:

- Increase the SH desuperheater spray water capacity
- “Tip” the forced draft fans to increase their volumetric flow capacity
- May require re-surfacing for steam temperature

PRB/Lignite Coal with Natural Gas Co-Firing

Possible Issues Include:

- Inability to attain design SH steam outlet temperature
- Inability to attain design RH steam outlet temperature
- Insufficient forced draft fan volumetric capacity
- Insufficient forced draft fan motor size
- Primary air system not useful
- Exceeding steam turbine steam inlet temperature lower limits
- Exceeding steam turbine SH/RH steam inlet differential temperature limits

Co-Firing Natural Gas in a Coal Fired Boiler



- Up to 15% NG, there should be little change to boiler performance.
- From 15% to 50% NG, a cursory study may be need but in most cases the boiler will maintain performance.
- From 50% to 100% NG, a detail study is needed to determine how much the boiler performance is effective. Determine boiler modifications that are needed to restore performance.

Co-Firing Natural Gas in a Coal Fired Boiler (con't)



- Boilers from 100 MWs to 600 MWs can co-firing NG.
- Boilers that are 600 MWs or larger normally co-firing NG for start-up fuel or low load operation only.
 - Pipeline may be limiting factor.

www.power.alstom.com

ALSTOM