

# **REINHOLD ENVIRONMENTAL Ltd.**



## **2011 NO<sub>x</sub>-Combustion Round Table & Expo Presentation**

February 7-8, 2011, in Birmingham, AL / Hosted by Southern Company

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



---

***Update on EPA Rules Impacting the Biomass Power Industry***

---

# US Tailoring Rule

## - The Bumpy Road to US CO2 Regulation Continues

- **In May 2010, EPA issued its tailoring rule setting thresholds for when PSD (Prevention of Significant Deterioration) and Title V operating permits will require GHG BACT standard**
  - 1<sup>st</sup> Phase (Jan-Jun 2011), no new permits are required solely based on GHG emissions. Only for sources emitting over 75 ktpy CO<sub>2</sub>e (11 MWe) and require permits for other pollutants
  - 2<sup>nd</sup> Phase (July 2011-July 2013), all new sources with GHG emissions over 100 ktpy CO<sub>2</sub>e (15 MWe) or modified sources with over 75 ktpy CO<sub>2</sub>e will be required to get a permit, reducing to 50 ktpy beginning July 1, 2013
- **Since Jan 1, 2011, States are required to follow GHG rules when issuing permits**
  - EPA threw BACT determination “hot potato” to states, providing only loose guidance for efficiency improvements and biomass as possible BACT measures
- **Expect continued bumpy road for US GHG regulation**
  - The EPA has taken away Texas’s authority to grant PSD and Title V permits involving GHG emissions. Texas temporarily blocked EPA’s permitting “coup” but ultimately failed
  - To settle lawsuits from states and environmental groups, in Dec 2010, EPA agreed to propose GHG BACT standards for power plants by July 26, 2011 and to issue final standards by May 26, 2012
  - States now have GHG BACT “hot potato” and don’t know how to line-up with EPA’s 2012 standards
  - After receiving 7000 comments on the greenness of biomass CO<sub>2</sub> emissions, EPA announced a 3 year delay (2014) of its GHG permitting requirements for biomass fueled sources

# SOx and NOx Regulation

## - In the middle of a transition

- **The Death of the Clean Air Interstate Rule (CAIR)**
  - In place since 2005 allowing 31 eastern states to freely trade SOx and NOx allowance credits
  - Two step 2009/2010 and 2015 cap reduction with overall 60-70% NOx and SOx reduction from 2005 base year
  - Invalidated by DC district court in 2008 due to disconnect with state national ambient air quality standards (NAAQS)
  - Resulted in complete loss of SOx and NOx allowance value needed as payback to AQCS investments
  - To stabilize the market, the EPA temporarily reinstated CAIR until a new program was in place
- **The Birth of the Transport Rule (TR)**
  - In August 2010, EPA releases the draft of TR for public comment
  - Expected to be finalized after the comment period in Spring 2011 and be up and running by end of 2011, but rule could get tied up in litigation causing substantial delay
  - Very similar to CAIR SOx, NOx cap and trade program with about same overall 60-70% reductions
  - Key difference: TR will limit trading among states which contribute to downwind state NAAQS non-compliance.
  - Upwind states like Ohio, Pennsylvania, Michigan, Kentucky could see much tighter SOx, NOx budgets
  - Also has additional 2012 compliance point that we don't believe can be achieved due to poor timing

# The Industrial Boiler MACT Rule

## - Outlook and Impact

- **Targets major sources facilities and will impact:**
  - 13.5K boilers and process heaters at 1600 industrial facilities
  - Some universities, municipalities, and military installations
  - All types of boilers and heaters: coal, biomass, gas and liquid fueled
  - Major sources defined as producing over 10 tpy of any single HAP or 25 tpy for all HAPs
  - Up to 25 MWe in size at which point the Utility MACT rule applies
- **Set emissions limits and MACT standard for boilers over 10 Mbtu/hr (1 MWe) heat input**
  - Sets emission limit and MACT standard for 5 HAPs: Hg, CO, HCl, PM, dioxin/furan
  - Annual compliance testing for all pollutants with annual unit tune-ups
  - CEMs for CO, PM (units over 250 Mbtu/hr heat input) with 30 day rolling average compliance
  - Establishes MACT standards: ACI+Baghouse for Hg, PM, FGD for HCl, Combustion for CO, dioxin
  - Natural gas and units under 10 Mbtu/hr heat input require only work practice standard and annual tune-ups
  - **Biomass, agricultural and industrial group opposing rule due to its high cost burden**
  - 106 members of Congress sent a bi-partisan (45 Democrats) letter to EPA
  - 41 Senators sent letter to EPA
  - **EPA requested 15 month delay (Apr 2012) to issue rule due to strong pushback but request denied by DC District court and must issue by Feb 21, 2010**
  - **EPA saying final rule will be “significantly” different from proposed rule**


# Utility Clean Air Mercury Rule (CAMR)

## - Regulation Outlook

- **In 2005, EPA proposed a mercury cap-and-trade regulation (under section 110 of the Clean Air Act) which was struck down in its entirety by the DC Circuit Court of Appeals in March, 2008**
- **The court instructed EPA to develop a new rule under section 112 of the CAA requiring a maximum achievable control technology (MACT) standard for hazardous air pollutants (HAPs)**
  - including mercury and other yet-to-be defined metallic HAPs, acid gases, dioxin/furan organic HAPs; and other organic HAPs. Expect definition in mid March 2011
- **The MACT standard requires unit-level performance commensurate with the average emission rate of the best 12% of the fleet and applies to all coal utility boilers**
- **Currently the draft rule requires all units to be in compliance by 2015**
- **To settle lawsuits from environments groups, the EPA agreed to release a draft of its Utility MACT Rule by March 16, 2011 and a final version of the rule by November 16, 2011**

# Biomass Solutions for Existing Steam Generators

- **Co-firing – Direct Combustion**
  - Blend biomass with coal or separate injection with or without burner modification
  - Up to 5+% by heat input for PC
  - Up to 100% for CFB
- **Co-Firing – Gasification**
  - Substitute fuel for coal, oil/gas boilers
  - Substitute fuel for HRSG firing duct burner
  - Over 50% by heat input
  - FW has supplied 8 gasifiers commercially
- **100% Biomass Conversions**
  - Converting PC firing system to fire 100% pulverized biomass in suspension mode
  - Convert existing oil, gas, or PC units into bubbling bed units
  - FW has performed over 25 BFB conversions



**FW Biomass Gasifier in PC Co-fire Application**



## ***Biomass Steam Generators***

---

*Module 50 Biomass Boilers 011111*

A thick, solid blue horizontal bar spans the width of the page at the bottom.

## We have been very active in Biomass Technology

- **We have Supplied a Wide Range of Technologies**

- 66 CFB Boilers
- 94 Bubbling Boilers
- 204 Grate Boilers
- 11 Biomass Gasifier
- 25 Biomass Boiler Conversions

- **We Have Delivered Some of the Largest 100% Biomass Units in the World**

- 125 MWe Kaukas Biomass Unit in Finland
- 56 MWe Fibrominn Turkey Litter Unit in the US
- 50 MWth Biomass Gasifiers in Europe

- **We Are Advancing Biomass Technology**

- Building World's Largest Biomass unit in Poland
  - 190 MWe Polaniec unit can burn up to 20% Agro
- Increasing Agro Fuel Range and Steam Conditions
- Developing Biomass Gasification Technology for Renewable Diesel Production.


### FW Biomass Fuel Experience

- |  |   |
|--|---|
| <ul style="list-style-type: none"> <li>• Demolition Wood</li> <li>• Recycled Wood</li> <li>• Saw Dust</li> <li>• Forest Residue</li> <li>• Bark</li> <li>• Sludges</li> <li>• Peat</li> <li>• Paper Waste</li> <li>• Plastic</li> <li>• Bagasse</li> <li>• Rice Husk</li> <li>• Straw</li> <li>• Wood Residue</li> </ul> | <ul style="list-style-type: none"> <li>• Wood Chips</li> <li>• Hog Fuel</li> <li>• Olive Pits</li> <li>• Coffee Grounds</li> <li>• Waste Fiber</li> <li>• Chicken &amp; Turkey Litter</li> <li>• Agricultural Waste</li> <li>• Sun Flower Seed Hulls</li> <li>• MSW &amp; RDF</li> <li>• Broom Corn Refuse</li> <li>• Hogged Plywood</li> </ul> |
|--|---|

# A Comparison Of Biomass Steam Generator Technologies


## GRATE FIRING

(FIXED BED)




## PULVERIZED FIRING

(ENTRAINED BED)




## FLUIDIZED-BED FIRING

BFB




CFB



<b>Furnace Gas Velocity</b>	<b>8-10 ft/sec</b>	<b>15-30 ft/sec</b>	<b>4-10 ft/sec</b>	<b>15-22 ft/sec</b>
<b>Fuel Feed Size</b>	<b>1-1/2" x 0</b>	<b>1/100" x 0</b>	<b>1/2" x 0</b>	<b>1/2" x 0</b>
<b>Furnace Temp.</b>	<b>2000-2500°F</b> <b>1093-1371°C</b>	<b>2200-2800°F</b> <b>1204-1538°C</b>	<b>1500-1700°F</b> <b>816-927°C</b>	<b>1500-1700°F</b> <b>816-927°C</b>

# FW has a Wide Solid Fuel Experience



# Biomass Properties










	Peat	Saw Dust	Recycled Wood	Timber Pellets	Timber Chips	Grass	RDF	Bagasse	Straw
<b>Moisture %</b>	50	45-60	25	5-10	20-50	13	25	8	12
<b>MJ/kg</b>	9.3	6-10	14	17	7.5-13.9	17	13	16	14.7
<b>Btu/lbm</b>	4000	2580-4300	6020	7310	3225-5975	7310	5590	6875	6320
<b>Bulk Density kg/m<sup>3</sup></b>	340	300-350	300-400	650	130-280	650	650	650	650
<b>Bulk Density lb/ft<sup>3</sup></b>	21	19-22	19-25	41	8-17	40	40	40	40
<b>MWh/m<sup>3</sup></b>	0.9	0.45-0.7	1.3	3	0.55	3	2.3	2.9	2.7
<b>Ash % ka</b>	5.1	0.4-0.5	5	0.9	0.4-5.3	3	12	6	7
<b>S % ka</b>	0.22	<0.05	0.1	<0.1	<0.1	0.1	0.1-0.5	<0.05	0.01-0.03
<b>Cl % ka</b>	0.02-0.06	<0.03	0.1	<0.03	<0.05	0.3	0.3-1.2	<0.03	0.1-0.8
<b>Alkalis mol/MWh</b>	1.0	3.2	6.1	7.8	7.8	11	24	29	60
<b>S/Cl</b>	6	0.7	2.2	1.9	1.9	1.2	0.7	0.5	0.4

# We have Classified Biomass Fuels for their “Burn-ability”

<b>BIO-1</b> <b>”Clean BIO”</b>	<b>BIO-2</b> <b>”Challenging BIO”</b>	<b>BIO-3</b> <b>”Hard to burn BIO”</b>
<ul style="list-style-type: none"> <li>• no contaminated</li> <li>• no agro</li> <li>• no fast growing</li> <li>• K+Na &lt;...; Cl&lt;...</li> <li>• Ca,K&gt; Si,</li> <li>• physical properties</li> </ul>	<ul style="list-style-type: none"> <li>• some agricultural residues, straw, contaminated, fast growing</li> <li>• FW has experience, know the limits,,,</li> <li>• K+Na &lt;...; Cl&lt;... (eng.)</li> <li>• Ca,K&lt; Si</li> <li>• S, P low; Cl high</li> </ul>	<ul style="list-style-type: none"> <li>• grain residues (corn, oat, barley, wheat, ...)</li> <li>• FW has no reference info.</li> <li>• K+Na &lt;...; Cl&lt;... (eng.)</li> <li>• Ca,K&gt; Si</li> <li>• S, P high; Cl low/high</li> </ul>

**Chemical and physical properties of biomass determine technology fit and design for 0-100% biomass firing**

# Impacts to Steam Generators by “Bio” Type

	Agglomeration	Fouling	Corrosion
Bio-1	 <p>Low</p>	 <p>Low</p>	 <p>Low</p>
Bio-2	 <p>High (additives/co-firing needed)</p>	 <p>High (additives/co-firing needed)</p>	 <p>High (additives/co-firing needed)</p>
Bio-3	 <p>Extremely high (no commercial references)</p>	 <p>High</p>	 <p>Extremely high</p>

# Which Technology is Right for Your Application?

*Unit Reference Basis: 500 kpph Steam Flow (50 MWe), 950°F, 1500psig Steam, Bio-1 Fuel*

<b>Emissions</b>		<b>Grate</b>	<b>BFB</b>	<b>CFB</b>
<b>Max SO<sub>2</sub>, SO<sub>3</sub>, Reduction<sup>1</sup></b>	% Reduction	0	20-30	70-90
<b>Max HCl, HF Reduction<sup>1</sup></b>	% Reduction	0	30-50	80-100
<b>NOx</b>				
Combustion NOx	lb/mbtu	0.20-0.30	0.15-0.25	0.10 - 0.15
Boiler Exit NOx w/SNCR (assumes 30% reduction)	lb/mbtu	0.14-0.21	0.10-0.18	0.07-0.10
Boiler Exit NOx w/SNCR+SCR (assumes 60% reduction)	lb/mbtu			0.03-0.06
Max Stack Ammonia Slip w/SNCR only	ppm	20-30	10-20	5-10
Max Stack Ammonia Slip w/SNCR+SCR	ppm			0-3
<b>CO</b>	lb/mbtu	0.20-0.30	0.07-0.15	0.05-0.12
<b>Schedule</b>				
Project NTP to CO	months	22-24	32-39	32-39
Equipment Delivery	strt-fin mnth	15-18	12-24	12-24
<b>Budgetary Steam Generator Capital Cost Range</b>				
Design and Supply of Boiler Island Equipment <sup>2</sup>	M\$	28-32	36-40	38-42
Boiler Island Erection <sup>3</sup>	M\$	22-26	29-32	31-34
Installed Boiler Island	M\$	50-58	65-72	69-76
<b>% Difference Installed Boiler Island</b>		-23%-10%	Base	0%+5%
<b>% Difference on Overall Plant Cost<sup>4</sup></b>		-7%-3%	Base	0%-2%
<b>Power Consumption<sup>5</sup> (% of Grss Plt Power)</b>		3	5	5
<b>Combustion Efficiency</b>				
Fuel Carbon Loss in Ash	%	2.0-2.5	0.5	0.3
Boiler Efficiency	%	70-75	72-77	73-78
<b>Fuel Flexibility</b>				
Max. Fuel Chlorine Content <sup>6</sup>	% in Dry Fuel	0.20%	0.20%	0.20%
Max. Fuel Alkali <sup>6</sup> (Total Acid Soluble Sodium Eq in Ash)		20%	5%	8%
Max % firing of fuels containing sulfur w/o FGD		0%	up to 30%	100%
Max % firing of high carbon fuels (Tires, Coal, Pet Coke)		0%	up to 30%	100%




---

## *Grate Steam Generators*

---

# Anatomy of FW's Grate Fired Boiler System




# FW Grate Boiler Design Features

---

- **Conservative Furnace Design**
  - Volumetric Liberation Rates
  - Cross-sectional Heat Flow Rate less than 2.5 mbtu/ft<sup>2</sup>/hr
- **Conservative Superheater Design**
  - Convective and Drainable
  - Conservative Metallurgical Design over Operating Range
  - Advanced Anti-vibration Design
- **Drums And Drum Internals**
  - Two Steam Drum Options for each Model to Minimize Cost and Optimize Performance Flexibility
  - Utility Quality Drum Internals
- **Convective Bank**
  - Three Convective Banks for each Model to Minimize Horsepower and Maximize Performance

# FW's Grate Boiler Technology Experience

- **Extensive Experience with Grate Technology**
  - 210 Units Sold
  - 2,889 MWe
  - Units Sold Since 1930
- **Fuel Experience**
  - Up to 57% Moisture Fuel
  - Up to 20% Tires
  - Up to 20% Sludge
  - Up to 30% Hulls
  - Up to 40% Coal
- **Steam Capacity Range**
  - 20-650 kpph
  - 2-56 MWe



## Recent FW Grate Fired Installations

Order Date	Start-Up Date	Client	Plant	Plant Country	Steam Capacity		Main Steam Flow		Main Steam Pressure		Main Steam Temp		Primary Fuel
					MWe	MWth	kpph	kg/s	psi(g)	bar(g)	°F	°C	
2005	2006	Laurentian Energy Authority	Virginia Pub. Utility	USA	15	37	135	17	614	42	830	443	Biomass- Energy Crop Biomass- Wood Residual
2005	2006	Laurentian Energy Authority	Virginia Pub. Utility	USA	15	37	135	17	614	42	830	443	Biomass- Energy Crop Biomass- Wood Residual
2004	2007	Fibrominn LLC	Fibrominn	USA	56	165	489	62	1,552	107	981	527	Biomass- Turkey Litter
2003	2007	Sumitomo Heavy Industries	Miyazaki Plant	Japan	14	41	120	15	909	63	847	453	Biomass- Chicken Litter
2001	2005	Trigen-Cinergy Solutions	St. Paul Cogen	USA	35	105	309	39	1,249	86	950	510	Biomass- Wood Residual
1999	2003	Greif Bros. Corporation	Riverville Mill	USA	17	45	150	19	624	43	716	380	Biomass- Wood Residual
1998	2002	Potter Station Power Company	Potter Station	Canada	28	85	249	32	909	63	855	457	Biomass- Wood
1996	2000	Taylor Woodrow	Taylor	United Kingdom	45	135	396	50	950	66	842	450	Biomass- Chicken Litter
1996	2000	The Mead Corporation		USA	34	102	299	38	1,300	90	905	485	Biomass- Wood Residual




---

## ***Bubbling Fluid Bed Steam Generators***

---

## FW's BFB Technology Experience

- **Extensive Experience with Bubbling Bed Technology**
  - 91 Units Sold Firing or Co-Firing Biomass Fuels
  - 2,347 MWe
  - Units in Operation Since 1970
- **Fuel Experience**
  - 100% Biomass and Waste Fuels
  - Up to 25% Demo Wood
  - Up to 30% Coal
- **Steam Capacity Range**
  - 20-600 kpph
  - 2-65 MWe




## BFB Boiler Design Features

---

- Stepped Grid for Most Difficult Fuels, Conventional Grid for Cleaner Fuels
- Bed Temperature Selection and Continuous Bed Flushing Minimizes Bed Agglomeration with the Most Difficult Fuels
- Fuel Gas Recirculation for Bed Temperature Control Avoids In-Bed Tubes
- High Gas Residence Time to Ensure Dioxin, CO, and Fly Ash Carbon Decomposition
- Multiple Levels of Secondary Air to Minimize NO<sub>x</sub> Formation
- Wide Superheater, Evaporator and Economizer Tube Banks Spacing and Retractable Soot Blowing to Maintain High Boiler Efficiency and Long Tube Life
- Low Gas Velocity for Minimum Heat Transfer Surface Erosion

## Two Grid Options - Step Grid vs. Arrow Head



## Step Grids Can Effectively Remove Bed Contaminants



## Recent BFB Projects

Order Date	Start-Up Date	Client	Plant	Plant Country	Steam Capacity		Main Steam Flow		Main Steam Pressure		Main Steam Temp		Primary Fuel	Secondary Fuel
					MWe	MWth	kpph	kg/s	psi(g)	bar(g)	°F	°C		
2005	2007	SembCorp Utilities Ltd.	Wilton 10	United Kingdom	31	92	293	37	1,334	92	900	482	Biomass - Wood	Biomass - Demo Wood Biomass - Crop Waste
2002	2006	Portucel Viana	Portucel Viana 1	Portugal	11	35	93	12	914	63	806	430	Biomass - Bark	Waste - Paper Sludge
2002	2006	Stora Enso Hylte AB	Hylte Bruk	Sweden	23	69	198	25	914	63	842	450	Waste- Deinking Sludge	Waste - Paper Sludge Biomass - Demo Wood Biomass - Bark
1999	2003	Celulosa Arauco y Constitucion	Valdivia	Chile	17	51	156	20	899	62	842	450	Biomass - Bark	Biomass - Wood Residual Waste - Sludge, Oil
1998	2002	Aanevoima Oy	Aanevoima Mill	Finland	38	157	477	60	1,523	105	995	535	Biomass - Bark	Biomass - Wood Residual Waste - Sludge, Peat, Oil
1998	2002	Jamsankosken Voima Oy	Jamsankosken Mill	Finland	62	185	554	70	1,552	107	995	535	Peat	Biomass - Bark, Biomass, Forest Residual, Crop Waste, Oil
1998	2002	Katrinefors Kraftvarme AB	Katrinefors Bruk	Sweden	12	36	103	13	1,160	80	896	480	Waste- Deinking Sludge	Biomass - Wood Residual



---

## ***Circulating Fluid Bed Biomass Boilers***


---

# FW is the Leading Global Supplier of CFBs

- **Sold 370 Units Firing All Fuels\***
  - 48 Units Firing 100% Biomass
  - 7 Units Firing 100% Refuse Derived Fuel (RDF)
  - 46 Units Co-firing Biomass
  - Units in Operation Since 1979
- **Fuel Experience**
  - 100% Biomass
  - 100% Coal
  - 100% MSW
  - 100% Pet Coke
  - Up to 70% Demo Wood
- **Steam Capacity Range**
  - 20-5,000 kpph
  - 2-800 MWe

Units Firing 100% Biomass include all Biomass and all Waste Fuels as Primary Fuels. Units Co-firing Biomass include all Biomass & all Waste Fuels as Secondary Fuels

**Historic World CFB Biomass Boiler Market  
GPG Served Market Over 2001-2010 Period**




**Total 1.3 GWe, 29 Units**

FW Order database. All Biomass CFB Fuel types excluding refused derived fuels. Served market excludes domestic orders provided by domestic suppliers in China, India, Japan, and S. Korea. Other includes suppliers with less than 2% of the market share. Market share based on GWe.

# Typical CFB Plant Configuration


458 MWth, 220 Mwe, 160/142 kg/s,  
164/43 bar(a), 560/560°C




Jyväskylän Energia Oy  
Jyväskylä, Finland

# CFB Process Advantages

<u>Feature</u>	<u>Benefit</u>
Low Furnace Temps	Low NO <sub>x</sub> In-Bed SO <sub>2</sub> Capture Fuel Flexibility
Hot Circulating Solids	Tolerant to Fuel Variations Simple Feed Systems Uniform Heat Flux Ideal for SNCR
Long Solid Residence Time	Good Fuel Burnout Good Sorbent Utilization



## Arrowhead Grid Nozzles Reduce Pluggage and Pressure Drop



- **Over 82 Units in Operations**
- **Operating Units since 1996**
- **Experience in Unit Sizes Ranging from 12 MWe to 460 MWe**
- **Over 12 Retro-fitted Units**

# Step Grids Can Handle the Most Difficult Fuels




<u>PROJECT</u>	<u>MWe</u>	<u>Start-up Year</u>
PAK, S.A.	55	2012
Prokon Nord, Oostrozebeke	25	2010
Kaukaan Voima	125	2010
Soderenergi	85	2009
NV Huisvuilcentrale	28	2008
Bundersforste	23	2008
Oji Paper	30	2006
Prokon Nord, Emlichheim	20	2006
Prokon Nord, Hamburg	20	2006
Harpen Energie	20	2005
Stora Kvarnsveden	39	2005
Prokon Nord	19	2003
MVV	18	2003
Narva	73	2003
Jamtkraft	38	2002
Kehl	13	2002
Munksund	29	2001
Kauttua*	20	2000
Hornstex, Horn	28	2000
TCC	41	2000
Lycksele	14	2000
Vasteras	47	2000
Viken	11	2000
Hogdalen	27	1999
YFY*	31	1999
Lomma	5	1998
Hornstex, Beekskow	26	1997
Norske Skog	15	1997

\*Year if retrofit for these plants


**28 CFBs Operating with Stepped Grid**

## Advanced Refractory Lining Offer The Longest Life



Thin Studded Refractory Lining Provides:


- **Reduced Weight**
- **Reduced Maintenance**
- Studs Stabilize Refractory
- Cooler Refractory Reduces Erosion Rates



1 Inch


# Vertical Superheater and Evaporator Panels Designed For Long Life

- Offered Since 1990
- Operating in over 60 Units Worldwide
- Mostly Superheater Applications (45)




## Compact Separator: Improves Unit Reliability

- Eliminates Traditional Expansion Joint and Associated Maintenance
- Common Furnace/ Separator Wall Reduces Boiler Footprint
- Offered Since 1992
- Operating in over 40 Units Worldwide




## SNCR Delivers Low NO<sub>x</sub> Emissions, Low Cost and Low Maintenance



- No Catalyst Replacement Required
- Simple Reagent Injection Based on NO<sub>x</sub> Limits
- Excellent Mixing in Solids Separator Minimizes Ammonia Slip
- Operating in over 20 Units since 1985

# Fouling and Corrosion Areas Experienced with Biomass and Waste Fuels




## Reducing the Risk of Fouling, Corrosion, Agglomeration for Biomass and Waste Fired CFBs

---

- **Locating Superheater and Reheater Coils in INTREX**
- **Idle Back Pass**
- **Quick Change Superheaters**
- **Reducing Final Design Stream Temperature**
- **Continuous Flushing of Bed with Sand**
- **Adding Bed Conditioners**
- **Reducing Bed Temperature**
- **Limiting K, Na, P, and Ca concentration in Fuel**

# The Market is seeing value in the Biomass Flexibility of CFB Technology

- **Co-Firing Carbon Neutral Fuels in utility CFBs provides an Optimum Solution**
  - Maximum Environmental Benefit since CFB is Flexible to Cope with Seasonally Varying Biomass Supply
  - Economical Electricity due to Large Plant Scale
  - Reliable Electricity due to Coal Back-up
- **Large utility CFBs are being built today designed to utilize biomass with traditional fuels like coal, peat, lignite, and pet coke**
- **We are developing Supercritical CFB technology capable of burning more challenging Agro biomass**



**Dominion is Building a 600 MWe CFB Plant that can Co-Fire up to 20% Biomass**

Note: PC coal plant assumed to have an annual capacity factor of 90% and a heat rate of 10,000 Btu/KWh, CFB plant assumed to have same capacity factor and a heat rate of 10,000 Btu/KWh (subcritical), 8200 Btu/KWh (supercritical)

## Recent 100% Biomass CFB Projects

Order Date	Start-Up Date	Client	Plant	Plant Country	Steam Capacity		Main Steam Flow		Main Steam Pressure		Main Steam Temp		Primary Fuel
					MWe	MWth	kpph	kg/s	psi(g)	bar(g)	°F	°C	
2010	2012	GDF Suez Energia Polska	Polaniec Power Station	Poland	190	447	1251	158	1,828	126	995	535	Biomass – Wood (80%) Biomass – Crop Waste (20%)
2009	2012	PAK, S.A.	Konin	Poland	55	154	473	60	1,407	97	1,004	540	Biomass – Wood (80%) Biomass – Crop Waste (20%)
2008	2010	Prokon Nord Energiesysteme GmbH	A & S Oostrozebeke	Belgium	26	71	222	28	1,305	90	932	500	Biomass - Demo Wood
2008	2010	E.ON Varme Sverige AB	P15	Sweden	30	85	246	31	957	66	842	450	Waste - RDF
2007	2010	Kaukaan Voima Oy	Kaukas	Finland	125	385	1180	149	1,668	115	1022	550	Biomass
2007	2009	Soderenergi AB	Igelsta	Sweden	85	240	721	91	1,291	89	1004	540	Biomass
2006	2008	NV Huisvuilcentrale Noord-Holland (HVC-NH)	HVC Bio-energiecentrale, Alkmaar	Netherlands	28	171	222	28	1,291	89	932	500	Biomass - Demo Wood
2005	2008	Lomellina Energia S.r.l.	Lomellina	Italy	17	75	234	30	918	63	830	443	Waste - RDF
2002	2006	Prokon Nord Energiesysteme GmbH	BMHKW Emlichheim	Germany	20	67	212	27	1,305	90	932	500	Biomass - Demo Wood

## FW CFB Boilers with SCR catalyst

Start-up Date	Client / Plant / Country	Capacity	Steam data			Fuel
		MW <sub>e</sub>	Flow kpph	Pressure psi(g)	Temp. F	
2012	GDF Suez Energia Polska / Polaniec / Poland	190	1251 / 1071	1828 / 276	995 / 995	Biomass – Wood / Crop Waste
2011	Kawasaki Biomass Electric Power Corporation / Japan	33	301	1479	955	Biomass – Wood Chips
2006	BKMW / Simmering / Austria	23	160 / 138	1805 / 235	968 / 968	Biomass – Wood Chips
2002	Jämtkraft AB / Östersund / Sweden	45	404	2100	1013	Biomass – Wood Residue
2001	Mälarenergi AB / Västerås / Sweden	58.7	440 / 398	2480 / 580	1004 / 1004	Biomass – Wood Residue
1996	Brista Kraft AB / Märsta / Sweden	45	397	2088	1004	Biomass – Wood Residue
1996	Växjö Energi AB / Växjö / Sweden	35	325	2059	1004	Peat

(1)

(2)

(1 Boiler Delivered By Doosan Heavy Industries (complete SCR System)

(2 Boiler Delivered By Sumitomo Heavy Industries

## FWOy SCR Catalyst Life with Biomass Experience

---

<b>Vaxjo, delivered 1996</b>	<b>SCR replaced 2004</b>
<b>Brista, delivered 1996</b>	<b>SCR not replace yet, but the current NOx reduction is low</b>
<b>Vasteras, delivered 2001</b>	<b>SCR replaced 2005</b>
<b>Jamtkraft, delivered 2002</b>	<b>SCR partially replace 2006 (damage from tube failure)</b>
<b>Simmering, delivered 2006</b>	<b>SCR not replaced</b>

# Kaukaan Voima Oy, CFB Boiler

**Location:** Lappeenranta, Finland  
**Customer:** Kaukaan Voima Oy  
**Fuel:** Biomass, Peat


**SCHEDULE:**

Contract Award: 2007  
 Start of Erection: 2008  
 Commercial Operation: 2010



Steam Capacity	Main Steam Flow	Main Steam Pressure	Main Steam Temp.	Feed-Water Temp.
125 MWe	1183 kpph	1668 psi	1022°F	415°F
385 MWth	149 kg/s	115 bar	550°C	213°C

# Simmering CFB Boiler



Steam Capacity	Main Steam Flow	Main Steam Pressure	Main Steam Temp.
23 MWe	160 kpph	1,805 psi	968°F
61 MWth	20 kg/s	124 bar	520°C

**Location:** Vienna, Austria  
**Customer:** Bundersforste Biomasse Kraftwerk  
**Start-Up Year:** 2006  
**Fuel:** Biomass- Wood Chips



---

## *Optional Slides*

---

# Soderenergi (Igelsta) CFB Boiler

**Location:** Sodertalje, Sweden  
**Customer:** Soderenergi AB  
**Fuel:** Biomass- Demo Wood  
 Waste- RDF (up to 25%)


**SCHEDULE:**

Contract Award: 2007  
 Start of Erection: 2008  
 Commercial Operation: 2009



Steam Capacity	Main Steam Flow	Main Steam Pressure	Main Steam Temp.	Feed-Water Temp.
85 MWe	730 kpph	1,305 psi	1005°F	392°F
240 MWth	92 kg/s	90 bar	540°C	200°C

# Kaukaan Voima Oy, CFB Boiler



## FUEL DATA

	<i>Biomass</i>	<i>Peat</i>
<b>Sulphur</b>	0.05%	0.2%
<b>Nitrogen</b>	0.6%	1.9%
<b>Moisture</b>	48.0%	45.0%
<b>Ash</b>	2.5%	5.0%
<b>LHV</b>	9.2 MJ/kg (3955 btu/lbm)	11.3 MJ/kg (4858 btu/lbm)

## DESIGN PERFORMANCE, O<sub>2</sub> 6% in dry gases

	<i>Biomass</i>	<i>Peat (75% of MCR)</i>
<b>Flue Gas Exit Temperature</b>	149 °C (300°F)	140 °C (284°F)
<b>Boiler Efficiency</b>	91%	
<b>Emissions</b>		
- NO <sub>x</sub>	150 mg/Nm <sup>3</sup>	150 mg/Nm <sup>3</sup>
- SO <sub>2</sub>	200 mg/Nm <sup>3</sup>	200 mg/Nm <sup>3</sup>
- CO	200 mg/Nm <sup>3</sup>	200 mg/Nm <sup>3</sup>
<b>Particulate Matter (dry)</b>	20 mg/Nm <sup>3</sup>	20 mg/Nm <sup>3</sup>

# Soderenergi (Igelsta) CFB Boiler


## MAIN FUEL MIXES

	<i>Mix 1</i>	<i>Mix 2</i>	<i>Mix 3</i>
<b>Brances and Tops</b>	75%	30%	100%
<b>REF Pellets</b>	25%	0%	0%
<b>Demolition Wood</b>	0%	70%	0%
<b>H<sub>2</sub>O</b>	44.3%	35.6%	50.0%
<b>LHV</b>	9.7 MJ/kg (4170 btu/lbm)	11.0 MJ/kg (4729 btu/lbm)	8.3 MJ/kg (3568 btu/lbm)
<b>Ash</b>	3.6% a.f.	3.0% a.f.	2.0% a.f.
<b>Suphur</b>	0.05% a.f.	0.05% a.f.	0.03% a.f.
<b>Nitrogen</b>	0.6% in d.s.	0.8% in d.s.	0.5% in d.s.
<b>Chlorine</b>	0.12 in d.s.	0.08 in d.s.	0.02 in d.s.

## DESIGN PERFORMANCE, O<sub>2</sub> 6% in dry gases

### Emissions

- Particles	10 mg/nm <sup>3</sup>	HCl	10 mg/nm <sup>3</sup>
- SO <sub>2</sub>	75 mg/nm <sup>3</sup>	HF	1 mg/nm <sup>3</sup>
- NO <sub>x</sub>	35 mg/MJ (0.081 lb/Mbtu)	Cd + T	10.05 mg/nm <sup>3</sup>
- CO	50 mg /nm <sup>3</sup>	Hg	0.05 mg/nm <sup>3</sup>
- NH <sub>3</sub>	10 ppm	Metals	0.5 mg/nm <sup>3</sup>
- TOC	10 mg/nm <sup>3</sup>	Dioxines & Furanes	0.1 ng/nm <sup>3</sup>



# E.ON Varme Sverige CFB Boiler

**Location:** Norrkoping, Sweden  
**Customer:** E.ON Varme Sverige AB  
**Fuel:** Refuse Derived Fuel


**SCHEDULE:**

Contract Award: 2008  
 Start of Erection: 2009  
 Commercial Operation: 2011

Steam Capacity	Main Steam Flow	Main Steam Pressure	Main Steam Temp.	Feed-Water Temp.
30 MWe	246 kpph	957 psi	842°F	275°F
85 MWth	31 kg/s	66 bar	450°C	135°C



# E.ON Varme Sverige CFB Boiler



## FUEL DATA

	<i>Refuse Delivered Fuel (RDF)</i>
<b>Sulphur (as received)</b>	0.08% (weekly average)
<b>Nitrogen (as received)</b>	0.22% (weekly average)
<b>Moisture</b>	27%
<b>Ash (as received)</b>	14.3%
<b>LHV (as received)</b>	12.9 MJ/kg (5546 btu/lbm)


## DESIGN PERFORMANCE, O<sub>2</sub> 11% in dry gases

	<i>RDF</i>
<b>Flue Gas Exit Temperature</b>	168 °C (334°F)
<b>Boiler Efficiency</b>	90.2%
<b>Emissions</b>	
- NO <sub>x</sub>	< 35 mg/MJ (0.081 lb/Mbtu)
- CO	< 50 mg/Nm <sup>3</sup>

# Large Scale and High Efficiency CFB for Clean Biomass

## 300MW<sub>e</sub> with Wood Pellets & Wood chips

### 179/43.5 bar(a), 560/565°C



Steam Capacity	Main Steam Pressure	Main Steam Temp.
300 MWe	2,500 psi	1040°F
815 MWth	179 bar	560°C

Fuel		Wood Pellets
Moisture	[%] <sub>ar</sub>	6 - 10
Ash	[%] <sub>dry</sub>	0,4 – 2.5
Nitrogen	[%] <sub>dry</sub>	0 – 2.7
Sulfur	[%] <sub>dry</sub>	0 – 0.05
Chlorine	[ppm] <sub>dry</sub>	< 500
LHV	[MJ/kg] <sub>ar</sub>	15.5 - 18

# Coal and Biomass Co-Combustion in CFB

## National Power Supply Co. Ltd.



**2 x 370 MW<sub>th</sub>, 134/122 kg/s, 161/35 bar,  
542/542 °C**

### FUELS:

- Anthracite
- Bit. Coal
- Bark
- Rice Husk

} 50% Biomass of Energy

*Located in Tha Toom,  
Prachinburi, Thailand*



---

## ***Bubbling Fluid Bed Boiler Conversions***

---

## BFB Conversion Benefits

---

- **Fuel Switch to Low Cost Opportunity Fuels**
- **Reduce Boiler Emissions**
- **Restore Unit Steam Capacity**

# FW's BFB Conversion Experience

## Original Unit Design


- Grate Fired
- Chemical Recovery
- Pulverized Coal
- Pulverized Peat
- Oil
- MgO
- La Mont
- Pyrite Roasting

## New Fuels

- Anthracite
- Coal
- Peat
- Graphite
- Bark
- Wood Residue
- Wood Chips
- Waste Fiber
- Primary Sludge
- Bio Sludge
- De-inking Sludge


**Converted 30 Units With Over 2000 MWth Capacity**

# Bubbling Fluid Bed Retrofits In Europe and Russia




# Before and After BFB Conversion

Before: Pulverized Peat Boiler



After: Peat, Bark, Sludge BFB



Metsa Serla Project in Simpele, Finland

## Potential BFB Conversion Scope Items

---

- **Fuel Prep, Storage and Feed System**
- **SH, Econ Material Upgrade**
- **SH, Evap and Economizer Surface Rebalance**
- **Air Heater Sizing and Location**
- **PA and SA Upgrade**
- **ESP Upgrade**
- **Primary Air Boost**
- **Ash Systems Upgrade (Bed and Fly )**
- **Steel Support Structure Modification**
- **Soot Blowing Upgrade**
- **Electrical**
- **I & C**

## Key Steps To BFB Conversion

---

- **Establish Goals:**
  - Fuel, Emissions, Performance
- **Boiler Assessment:**
  - Space, Boiler Capacity
- **Design Study to Establish Project Scope**
- **Perform Conversion**
- **Commissioning and Performance Testing**

**No Two Projects Are Alike**

# Grate Boiler Response Characteristics


- **Start-up times**
  - Cold start 70°F (21°C) drum water to full pressure is based on 100°F (38°C) rise in drum saturation temperature per hour (i.e., for a boiler operating pressure of 650 psig (45 bar) (saturation temp of 497°F (258°C)), the start time would be approximately 4.3 hours
  - Warm and hot standby follow the same criteria, so timing depends on drum saturation temperature at restart
- **Steam swing**
  - 10% of boiler MCR (no steam accumulation) without boiler trip
- **Boiler ramp rate**
  - 10%/min of 100% MCR steam flow
  - Range 40 - 100% MCR increasing or decreasing
  - Steam temp  $\pm 15^\circ\text{F}$  over the specified control range
  - Steam pressure  $\pm 10\%$  of set point based on header pressure fluctuations

# BFB Response Characteristics

- **Start-up times**
  - 7 Hours for Cold Start (over 36 hrs Standby)
  - 2 Hours for Warm Start (less than 10 hrs Standby)
  - 1 Hour for Hot Start (less than 1 hr Standby)
- **Steam swing**
  - 10% of boiler MCR (no steam accumulation) without Boiler Trip
- **Boiler ramp rate**
  - 4%/min of 100% MCR Steam Flow
  - Range 50 - 90% MCR increasing, 100 - 50% MCR decreasing
  - Steam Temp +5/-8°C (+9/-15°F)
  - Steam pressure  $\pm 8$  bar ( $\pm 116$  psig)

# Water/Steam Cooled Cyclone Offers Many Benefits

- Thin Refractory Means Reduced Weight
- Thin Refractory Means Low Maintenance
- Low Surface Temperature Means Reduced Fuel Costs
- Operating in 26 Units
- Installed Since 1988



FB53b

# CFB Response Characteristics

- **Start-up times**
  - 7 Hours for Cold Start (over 36 hrs Standby)
  - 2 Hours for Warm Start (less than 10 hrs Standby)
  - 1 Hour for Hot Start (less than 1 hr Standby)
- **Steam swing**
  - 10% of boiler MCR (no steam accumulation) without Boiler Trip
- **Boiler ramp rate**
  - 5%/min of 100% MCR Steam Flow
  - Range 50 - 90% MCR increasing, 100 - 50 % MCR decreasing
  - Steam Temp +5/-8°C (+9/-15°F)
  - Steam pressure  $\pm 8$  bar ( $\pm 116$  psi)

## Expected Emissions Controls (Grate)


Emission	Avg. Uncontrolled Emission at Boiler Exit (lb/MMBtu)	Adage Emission Limit at Stack (lb/MMBtu)	Emissions Removal Required	(PRELIMINARY) Expected Control Technology
CO	0.25	0.08	67%	Tail-End CO Catalyst <sup>(1)</sup>
NOx	0.25	0.08	67%	Tail-End SCR Catalyst <sup>(2)</sup>
NH3	n/a	10 (ppmvd @7%O2)	n/a	Tail-End SCR Catalyst
SO2	0.11	0.08	24%	Dry Injection <sup>(3)</sup>
HCl (60 tpy MACT limit)	0.027	0.02	23%	Dry Injection <sup>(3)</sup>
HCl (10 tpy MACT limit)	0.027	0.0034	87%	Dry FGD <sup>(4)</sup>
PM-10	5.88	0.012	99.8%	ESP <sup>(5)</sup>

1. Preliminary information indicates it may be better to install CO catalyst downstream of Dust Collector - FW is evaluating both options.
2. Tail-End SCR is expected to be more economical than Hot-Side SCR, since gas must be reheated anyway to accommodate CO Catalyst. Also, it may not be feasible to install Hot-Side SCR due to possible catalyst poisoning - FW is evaluating cost and feasibility of both options.
3. Involves only injection of dry sorbent (Lime), with no water injected or Scrubber vessel required.
4. If 60 tpy MACT limit is required this will likely require a Dry-FGD - i.e., Scrubber vessel similar to Allied-type, with water and Lime injection.
5. Baghouse cannot be used on Grate boiler due to potential for fire from embers.

# Possible Emissions Control Options

## Option 1 (Grate)

(Grate Boiler w/Tail-End SCR -- No Dry FGD Required for HCl)



## Expected Emissions Controls (BFB)


Emission	Avg. Uncontrolled Emission at Boiler Exit (lb/MMBtu)	Adage Emission Limit at Stack (lb/MMBtu)	Emissions Removal Required	(PRELIMINARY) Expected Control Technology
CO	0.110	0.08	26%	Tail-End CO Catalyst <sup>(1)</sup>
NOx	0.20	0.08	59%	Tail-End SCR Catalyst <sup>(2)</sup>
NH3	n/a	10 (ppmvd @7%O2)	n/a	Tail-End SCR Catalyst
SO2	0.11	0.08	24%	Dry Injection <sup>(3)</sup>
HCl (60 tpy MACT limit)	0.027	0.02	23%	Dry Injection <sup>(3)</sup>
HCl (10 tpy MACT limit)	0.027	0.0034	87%	Dry FGD <sup>(4)</sup>
PM-10	5.88	0.012	99.8%	ESP or Baghouse <sup>(5)</sup>

1. Preliminary information indicates it may be better to install CO catalyst downstream of Dust Collector - FW is evaluating both options.
2. Tail-End SCR is expected to be more economical than Hot-Side SCR, since gas must be reheated anyway to accommodate CO Catalyst. Also, it may not be feasible to install Hot-Side SCR due to possible catalyst poisoning - FW is evaluating cost and feasibility of both options.
3. Involves only injection of dry sorbent (Lime), with no water injected or Scrubber vessel required.
4. If 60 tpy MACT limit is required this will likely require a Dry-FGD - i.e., Scrubber vessel similar to Allied-type, with water and Lime injection.
5. ESP may be cheaper.

# Possible Emissions Control Options

## Option 2 (BFB)

(BFB Boiler w/Tail-End SCR -- No Dry FGD Required for HCl)



\* Limestone injection into Boiler may not be necessary if DI system can also meet the required SO<sub>2</sub> removal.


# Possible Impact of Using Hot-Side SCR

- **Potential for Catalyst Poisoning**

- Due to presence of potassium, sodium, and phosphorous in wood
  - Potassium aerosols formed in back-pass section of Boiler may be major cause
    - Stoker boilers may be more likely to form these aerosols than BFB or CFB
      - Ceram has stated they will not quote Hot-Side SCR for Grate Boilers, but will consider on case-by-case for CFB and BFB
      - Haldor will consider Stoker, BFB, and CFB Boilers on case-by-case
      - Currently in discussions with Argillon, KWH, and other catalyst suppliers
  - If limestone is injected in CFB or BFB Boiler, presence of calcium in ash may partially offset catalyst deactivation due to poisoning
  - Type of wood (trimmings, demolition, etc.) may have substantially different levels of poisons – fuel, ash, and trace analysis should be carefully evaluated for each project
  - Whenever possible, testing catalyst sample in actual flue gas slipstream is highly recommended

# Technology Solutions that FW is Developing for Tomorrow's Transportation Fuels


- **Awarded Contract for Pilot-Scale Biomass CFB gasifier and Syngas Cleaning System in Finland**
  - Client is NSE Biofuels Oy Ltd., a joint venture between Stora Enso Oy and Neste Oil Corporation
- **FW's Technology is a Key Part of Renewable Diesel Fuel Plant**
  - Potential for converting a wide spectrum of biomass and wastes into carbon-neutral diesel fuels for transportation
  - Avoids "Food Competition" Issue
  - Uses Fischer-Tropsch process to produce renewable diesel fuel from clean syngas
- **Pilot Plant has been Operating for Over a Year**
  - 12 MWth plant capable of producing 4 kton/yr of FT Liquids
- **Follow-on Commercial Size Plant under Discussion with Client**
  - 450 MWth plant producing 150 kton/yr of FT Liquids



**GPG's Biomass Gasifier Island**

## FW's Traveling Grate Boiler Technology


- **Used for most difficult fuels**
- **Extensive experience with Detroit Stoker's Rotor Grate**
- **Most experience firing 100% Poultry Litter**
- **Steam capacity range:**
  - 75-300 kpph (9-38 kg/s) on Poultry Litter
  - 75-600 kpph (9-76 kg/s) on Biomass



## Advantages of the Vibrating Grate

- Minimal Moving Parts for High Availability and Lowest Maintenance Cost
- Drive Components Located Outside Hot Zone
- One Piece Grate Half the Size as Travelers
- Easy Under Grate Access with Zoning for Better Air Control
- Shop Assembled Grate Modules for Sizing Flexibility
- Intermittent Grate Drive Operation
- Automatic Ash Removal

### Water Cooled Vibrating Grate



# Step Grids Can Handle the Most Difficult Fuels





PROJECT	MWth	START-UP
Wilton	92	2007
Hylte	69	2006
Jamsankoski	185	2002
Aanekoski	157	2002
Myllykoski	88	2001
Katrinefors	36	2001
Haapajarvi*	7	2000
Voimavaasu	32	2000
Stracel*	31	2000
Rauma*	60	1999
Forssa*	57	1998
Kaukas	109	1996
Cheng Kung	6	1995
Mikkeli	27	1984

*\* Retrofit Application*

**14 BFBs Operating with Stepped Grid**

# Step Grid Nozzles can easily be replaced




## FW's Furnace Tube Design Eliminates Erosion

- Offered Since 1990
- Operating in over 100 Units Worldwide
- Up to 460 MWe Single Unit Experience



Old



New

## FW is a Proven Supplier of Biomass Boilers

Technology	Installed Units	Fuels	Size (MWe)
Circulating Fluid Bed	88	Demolition & Recycled Wood, Saw Dust, Forest Residue, Bark, Sludges, Peat, RDF, Paper Waste, Plastic, Bagasse, Rice Husk, Straw	4-125
Bubbling Fluid Bed	91	Bark, Wood Residue & Waste, Forest Residue, Saw Dust, Sludge, Peat, Recovered Fuel, Wood Chips, Hog Fuel, Olive Pits, Coffee Grounds, Rice Husk, Waste Fiber	2-62
Grate	210	Chicken & Turkey Litter, Agricultural Waste, Wood & Wood Waste, Wood Residue, Bark, Peat, Bagasse, Sun Flower Seed Hulls, Coffee Grounds, Muni-Refuse, Hog Fuel, Veneer, Sawdust, Broom Corn Refuse, Hoggged Plywood	1-56

Note: Units listed fire biomass and waste as primary fuel. Some units also fire fossil fuels as secondary fuels. Capacity range based on 100% primary fuel firing.