

# Reinhold Environmental Ltd.



## 2010 NO<sub>x</sub>-Combustion Round Table & Expo Presentation

***February 8 & 9, 2010***

***Chattanooga, TN***

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



# Boiler Combustion Advancements

*Ray Johnson  
Reinhold NOx Conference  
Chattanooga, TN  
February 8, 2010*

# Agenda

- Review of ProcessLink & solutions
- Review traditional combustion optimization results
- Introduce alternative combustion optimization benefits
- Discuss comprehensive boiler optimization


# NeuCo's ProcessLink<sup>®</sup> Platform

- ProcessLink is the optimization technology platform upon which all NeuCo optimizers are built:
  - Utilizes multiple modeling and optimization techniques to deliver superior results
  - Supports optimizer integration and action coordination

# A Platform for Holistic Optimization


- **Enterprise Data Management**
  - Integrate from any source
  - Validate and replace if necessary
  - Aggregate and manage calculations
- **Hybrid Modeling Methods**
  - First-Principles: Proven equations to represent a process
  - Neural Networks/MPC: Start with data and learn relationships
  - Heuristics: Represent knowledge in the form of situation-action rules
- **Integrated Optimization Engine**
  - Coordinate local decisions based on global impact
  - Action-Centric Portals
  - Present actionable knowledge to people
  - Allow user to drill-down all of the details upon which the knowledge is based

# NeuCo Optimization Suite




# CombustionOpt®

- Provides real-time closed-loop optimization of fuel and air biases
- Using:
  - Model Predictive Control (MPC)
  - Neural Networks
  - Design of Experiments (direct search)
  - Expert Rules
- To Improve:
  - NO<sub>x</sub>
  - CO
  - Heat rate
  - Steam temps
  - Opacity
  - Constraint performance  
(Mill Dp's, Fan Amps, O2 split)



# CombustionOpt Optimization



### Unit 3: CombustionOpt Home

11/21/2008 01:32 PM (1 day)

#### Optimization Alerts


Issue	Actual	Target	!!!	NOx Svngs (...)	Fuel Svngs (...)	Relative Impa...
C'Opt MVs Partially Enabled	0.7	1	!!!!	8,720	58,334	

#### Optimization Benchmarks

Benefits (month)			
Objectives	Units	Achieved (vs. Baseline)	Achievable (vs. Actual)
Fuel	Btu/MWh	297.73	198.69
Fuel	\$	224,112.09	150,094.01
NOx	lb/MBtu	0.01	0.01
NOx	\$	24,283.09	14,448.01

#### Optimization Analysis

11/21/2008 1:32:43 PM



11/21/2008 01:23:06 PM


MV Name	Pre-Move	Post-Move	Delta Move	Objectives	Actual	Predicted	Target	Delta Cost
AUXDPR AA SEL	3.496	3.371		RH Spray Flo	59.93	57.87	< 25 (klb/h)	
AUXDPR AB SEL	-4.186	-4.061		Mill 3F dP (in)	8.82	8.82	< 7.5 (inH)	
AUXDPR BC SEL	1.059	0.996		Mill 3C dP (in)	7.92	7.92	< 7.5 (inH)	
AUXDPR CD SEL	2.233	2.296		Mill 3E dP (in)	7.48	7.48	< 7.5 (inH)	
AUXDPR DE SEL	-0.857	-0.859		Sum of Fdr Bi	0.02	0.01	0	
AUXDPR EF SEL	-2.374	-2.499		IDF 3A Amps	431.8	430.5	< 445 (A)	
AUXDPR FF SEL	0.652	0.777		Sum of Aux B	0.02	0.02	0	
FEEDER A SEL BI	-8	-8		O2 Split (perc)	-0.22	-0.22	0	
FEEDER B SEL BI	-1.226	-1.351		Mill 3A dP (in)	7.16	7.16	< 7.5 (inH)	
FEEDER C SEL BI	0.365	0.303		Mill 3B dP (in)	5.39	5.39	< 7.5 (inH)	
FEEDER D SEL BI	5	5		O2 3 & 4 (perc)	2.97	2.97	> 2.5 (perc)	


#### Setpoints (Deviations)

O2 Split	percent	-0.24	-0.36
Sum of Fdr Bia	unitless	7.81	0.39
Sum of Aux Bi	unitless	-0.01	0.03

#### Limits (%Violations)

Opacity	percent	-4.27	-33.53
O2 1, 2	percent	-3.81	4.7
O2 3, 4	percent	0	0
RH SF	klb/h	9.63	14.65
Mill 3A	inH2O	16.35	-0.2
Mill 3B	inH2O	0.14	0









# NRG Big Cajun II Case Study

- Asset: Three 600 MW coal-fired units (Riley Turbo and B&W Opposed)
- Stage 1: Combustion Optimization on Two Units
  - CombustionOpt® on Units 1 & 2
- Stage 2: Combustion Optimization Expansion
  - Added manipulated variables available via the addition of new NOx control hardware installed at Units 1 and 2
  - Installed CombustionOpt at Unit 3
- Stage 3: Real-Time Performance Management & Combustion Optimization Upgrades
  - Upgrading CombustionOpt on all three units
  - PerformanceOpt® on all three units
  - MaintenanceOpt planned for this coming year

# Impact on Operations & Performance




# BC-II Unit 1 Five Years Later (1/1/05)




# Initial Unit 3 (B&W Opposed) Results

- 10% NOx reduction
- 0.55% heat rate improvement



# Initial BC-II Unit 3 Heat Rate Improvement




# Initial Impact on Unit 3 Avg O<sub>2</sub> & CO


	Average O <sub>2</sub>			
	450-500	500-530	530-550	550-605
<b>PL &amp; O<sub>2</sub> = ON</b>	2.296	2.170	2.096	2.014
<b>PL = ON O<sub>2</sub> = OFF</b>	2.563	2.415	2.295	2.084
<b>PL = OFF</b>	2.615	2.479	2.383	2.013
<b>PL &amp; O<sub>2</sub> ON vs PL OFF</b>	-12.22%	-12.47%	-12.05%	0.03%

	Average CO			
	450-500	500-530	530-550	550-605
<b>PL &amp; O<sub>2</sub> = ON</b>	109.9998507	171.299547	243.0881189	237.2359043
<b>PL = ON O<sub>2</sub> = OFF</b>	219.5955206	268.7387142	300.3420735	352.5672106
<b>PL = OFF</b>	154.3105887	193.9514151	253.8182942	373.9144061
<b>PL &amp; O<sub>2</sub> ON vs PL OFF</b>	-28.72%	-11.68%	-4.23%	-36.55%

# Initial Unit 3 Exit Gas Temperature Impact




# On vs. Off Freq Dist for 2008 Unit 3 HR



# CombustionOpt at CPS Energy

- CombustionOpt on all coal-fired units
  - Spruce: 546 MW CE t-fired w/Ovation DCS
  - Deely: 2 x 446 MW CE t-fired w/Honeywell DCS
- First installed at Spruce in 2001
- Installed at both Deely units in 2004
- Primary objective is NOx
- Model predictive control (MPC) added in 2007
- Additional objectives addressed through MPC
  - Explicit steam temperature control
  - Minimize attemperation sprays
  - Incremental heat rate and NOx reduction

# CombustionOpt at CPS Deely 1-2



# Pre-Zolo CombustionOpt Deely Results

- Reduction of NOx by 12% (\$650,000 per year savings\*)
- Reduction in reheat and superheat spray by 30% (\$100,000 per year savings\*\*)
- Increase in reheat temperature by average of three degrees. (\$25,000 per year\*\*)
- Total benefit of CombustionOpt is estimated at \$775,000 per year
- Wide operator acceptance

\* NOx credits at \$2,500 per ton

\*\* Fuel price at 1.25 dollars per mmBtu


# Deely On vs. Off Test Results

## 4/29-5/6/09


COpt&O2 ON vs COpt OFF Comparison				
Performance Parameter	COpt OFF	COpt&O2 ON	Diff	Diff %
NOx	0.138	0.112	-0.026	-18.55%
Average O2	2.69	2.30	-0.39	-14.60%
PerfIndex	776	772	-4	-0.58%
Opacity A	2.95	2.40	-0.54	-18.46%
Opacity B	6.97	6.50	-0.47	-6.68%

# CombustionOpt at AMP-Ohio RH Gorsuch

- **Goals**
  - Reduce NOx
  - Improve fuel efficiency
- **Challenges**
  - Small units
  - Old DCS with limited connectivity
  - Concern in achieving ROI for ROFA units
- **Initial approach**
  - Apply standard CombustionOpt at all four units
  - Added OSI PI for historian and DCS connectivity
- **CombustionOpt Extension on Units 2 and 3**
  - Added connection to Mobotec ROFA controls
  - Required close collaboration between AMP, NeuCo, and Mobotec



# NOx Reduction on Unit 2 (With Mobotec ROFA)



25On 25amb 25Steam 25hdPh 25NOx 25SHL 25/C 25CO 252Probes 252Agg 252Dev 25APH 25AHB 25FanA 25aFL 25PA\_DP 25wB 25Flame 25CoolAir 25Mts 25MA 25FSpd 25MSTR 25


Services Trend Scatter Model ModelQuality Model StdErr Sensitivity Surface Tasks Advisory Pred Impr Error Log MillOut

# Recent Results for Unit 2


(From Q3-06 AM&S Quarterly Report)

CombustionOpt Variables	PL&O2 ON vs PL OFF Comparison			
	PL&O2 ON	PL OFF	Diff	Diff%
<b>NOx</b>	0.274	0.340	-0.066	-19.35%
<b>Opacity</b>	6.43	5.75	0.68	11.80%
<b>Heat Loss</b>	7.82	8.32		-0.50%


# CombustionOpt V2 at Unit 2: w/ROFA



# OMU Unit 1 RH Temps



# OMU Unit 1 SH Temps




# SCR/SNCR Systems & Optimization

- Reduce Reagent Usage
- Lengthen Maintenance Intervals
- Avoid Ammonia Slip
- Reduce risk of Ammonium Bisulfate & Sulfur Trioxide deposits
- Control “Blue-Plume” Excursions
- Better Manage System Interactions



# SCR/SNCR Systems & Optimization

- ~40 units with SCRs and CombustionOpt
  - Include reagent flow as objective
  - Reduce boiler NOx
  - Reduce variability of NOx and inlet gas temps
- ~20 units with SNCRs and CombustionOpt
  - Reduce variability of NOx and inlet gas temps




Reduced NH3 Usage and Variability

Before Enabled


After Enabled

- SCR 1A SELECTED AMMONIA FL (397.5097)
- 1 OFA Mstr Flow Cntrl PL App (50)
- 1 OFA LRD Flow Cntrl PL App (15)
- U1 Air/Fuel Ratio Cntrl PL App (-0.15)
- U1 AVG LF SECAIR BIAS (-1)
- U1 AVG UF PRIAIR BIAS (1)
- U1 AVG LR SECAIR BIAS (-1)
- SCR 1B SELECTED AMMONIA FL (378.595)
- 1 OFA RFA Flow Cntrl PL App (-3)
- ID Fan 1A Inlet Vlv Dmd PL App (-2.23289)
- FD Fan 1A Inlet Vlv Dmd PL App (-2.5)
- U1 AVG LF FDR BIAS (-1)
- U1 AVG UF SECAIR BIAS (1)
- U1 AVG UR FDR BIAS (0.7148121)
- U1 WBox/Furn DP Cntrl PL App (0.9104566)
- 1 OFA LFB Flow Cntrl PL App (6)
- ID Fan 1B Inlet Vlv Dmd PL App (2.27731)
- FD Fan 1B Inlet Vlv Dmd PL App (-2.5)
- U1 AVG LF PRIAIR BIAS (-1)
- U1 AVG LR FDR BIAS (1)
- U1 AVG UR PRIAIR BIAS (1)
- U1 Furn Press Cntrl PL App (0.0498)
- 1 OFA RRC Flow Cntrl PL App (15)
- ID Fan 1C Inlet Vlv Dmd PL App (1.467699)
- FD Fan 1C Inlet Vlv Dmd PL App (2.5)
- U1 AVG UF FDR BIAS (-1)
- U1 AVG LR PRIAIR BIAS (1)
- U1 AVG UR SECAIR BIAS (1)

# Impact on NH3




**WITHOUT** Optimization, 400-600 klb/hr NH3 flow needed to meet NOx target




**WITH** Optimization, 300-400 klb/hr NH3 flow needed to meet NOx target

# Baldwin 1 – Full Load Comparison

Ozone Ammonia Flow - 2005




Ozone Ammonia Flow - 2006




# SootOpt®

- Provides real-time closed-loop optimization of soot cleaning equipment
- Using:
  - Expert Rules
  - Neural Networks
- To Improve:
  - Sootblowing consistency
  - Unnecessary sootblowing
  - Steam temps
  - Sprays
  - Leverage on heat rate




# Sootblowing Optimization




# What SootOpt Does

- Improves heat rate
  - by improving heat transfer and heat transfer distribution
  - Be improving steam temperature control
  - by reducing use of attemperation spray and sootblowing media (steam, water, air)
- Improves availability
  - Reduced blowing reduces tube erosion and thermal fatigue
- Improves NOx control
  - through improved heat transfer, reduction of “hot spots”, and reduced firing intensity
- Reduces opacity violations
  - by using opacity data in decision-making
- Reduces operator workload and improves shift-to-shift consistency

# Overview: How SootOpt Works



# Rules Development



- Expert Rules model the effect of actions – opportunistically (*when we know them*)
- And can be described in regular sentences

# Blower Selection

- Once a Zone is Selected
- Two methods are available for blower selection
  - Greatest time-since last operation
    - Recognizes blower actuations by SootOpt or otherwise
    - Can be used alone
    - Blowers over their Maximum Allowable Idle Time trumps Predictive Neural Selection
  - Predictive (“neural”)
    - Used with Time-Since
    - Neural models are used to predict the effect of operating each blower in the zone
    - The blower with the predicted best effect is chosen

ProcessLink  
 Session Documents Debug Help

### Unit 3: SootOpt Home

8/22/2008 11:23 AM (1 day)

#### Optimization Alerts

Issue/Action	Actual	Target	!!!
Some SH boiler IKs 1A, 1, 2 are below minimum required ops	1	0	!!!
Some RH boiler IKs 11-14 are over expected ops	1	0	!!!

**SootOpt® Summary Line**

#### Optimization Analysis

Last Evaluation: 8/22/2008 11:22:07 AM, Goal: Reduce APH 3A Gas In Temp, Zone: SH\_Economizer, Device: SH12\_72

Blower Select: Model

##### Zone Selection:

Goal	Zone	Eligible	Applica...
Lower RH Steam Temp	RH_Platen	✗	✓
Lower RH Steam Temp	RH_Furnace	✗	✓
Reduce APH 3A Gas In Temp	SH_Convection	✗	✓
Reduce APH 3A Gas In Temp	SH_Economizer	✓	✓
Reduce APH 3A Gas In Temp	SH_Platen	✓	✓
Reduce APH 3A Gas In Temp	SH_Furnace	✗	✓
Reduce APH 3B Gas In Temp	RH_Furnace	✗	✓
Reduce APH 3B Gas In Temp	RH_Platen	✗	✓

**Rule Selection Table**

##### Blower Selection:

Blower	Eligible	Idle	Rank
SH11_71	✓	●	
SH12_72	✗	●	
SH13_73	✗	●	
SH14_74	✓	●	

**Blower Selection Table**

#### Optimization Benchmarks

**Average Steam Temperatures, SootOpt On vs. Off**







**Average Gas Temperatures, SootOpt On vs. Off**

**Average Unit Load, Heat Rate and NOx, SootOpt On vs. Off**

### Unit 3: SootOpt Analysis

1 day 08/27/2008 01:09:51 PM

Overview of Boiler Performance Parameters and Associated Sootblower Activities



Blower Operations	48 Hrs	24 Hrs	16 Hrs	8 Hrs
SH-IRs	99	51	31	22
SH-IKs	181	94	53	36
SH-APH	5	2	1	0
RH-IRs	149	75	45	25
RH-IKs	184	98	63	30
RH-APH	9	4	3	2

### Unit 3: SootOpt Analysis




1 day 08/27/2008 01:13:08 PM

Sootblower Counts in Superheat Section

Overview Tools Models Optimization

General Activity

SH Boiler Counts RH Boiler Counts SH Boiler Activity RH Boiler Activity



# SootOpt at Xcel Energy Tolk U1 & U2


- U2 Completed April '09
- U1 Completed July '09
- Both units already had ISB
- Objectives
  - Further NOx reduction
  - Better balancing of Sootblowing Operations
  - More consistent Sootblowing Operation
  - Lower APH gas inlet temps

# Initial Benefits: SootOpt at Tolk U1 & U2


- Operators have one less thing to worry about
  - Takes the right actions, consistently
- SH & RH temps better balanced
- Superheat sprays significantly reduced
- APH gas inlet temps significantly reduced
- Tighter control of burner tilts
- Boiler Efficiency increased (resulting in further NOx reductions)
- Helps address problems associated with changing load profile
- Better balancing furnace-to-steam circuits

# Superheat Steam Temperatures Tolk U2


Superheat Steam Temperature West 530 to 540




Superheat Steam Temperature East 530 to 540





Superheat Steam Temperature West 540 to 550





Superheat Steam Temperature East 540 to 550




# Tolk Unit 2 Superheat Spray Flows



# APH Gas Inlet Temperatures Tolk U2 (550-560 MW)



~ 30° F Reduction in Average Temperatures







# Meramec Unit 3 Results





# U3 Individual Sootblower Counts – Long Lances

	<b>Before SootOpt Totals (3/25/08 to 4/07/08)</b>	<b>After SootOpt Totals (8/9/08 to 8/22/08)</b>	<b>% Change</b>
<b>SH-LL's</b>			
LL_1	300	116	-61.3
LL_1A	256	134	-47.7
LL_2	300	134	-55.3
<b>RH-LL's</b>			
LL_1	369	253	-31.4
LL_1A	309	221	-28.5
LL_2	377	255	-32.4

# U3 SH Temps & Sprays – SootOpt Before vs. After



# U3 RH Temps & Sprays – SootOpt Before vs. After



# U3 APH Temps - SootOpt Before vs. After



Air Preheater 3A Gas Inlet Temperature Frequency Distribution and Percentage Change

APH 3A Temp Ranges (DegF)	Before SootOpt Frequency	After SootOpt Frequency	% Change
800	1631	2685	-64.62
805	62	81	-30.65
810	99	48	51.52
815	167	66	60.48
820	281	58	79.36
825	205	50	75.61
830	109	67	38.53
835	173	49	71.68
840	198	81	59.09
845	206	427	-107.28
850	676	1213	-79.44
855	1732	2267	-30.89
860	2167	1674	22.75
865	1515	946	37.56
870	605	240	60.33
875	116	69	40.52
More	108	29	73.15

**Notes**

Positive % Change = decrease in occurrence frequency  
 Negative % Change = increase in occurrence frequency

Better Control Over APH Inlet Temps is Providing 25 MW Capacity Increase



# U3 Meramec SootOpt Benefits Summary

- Narrowed superheat and reheat steam temperature variability and moved closer to setpoint
- Simultaneously reduced attemperation sprays
- Reduced manually blowing of three lances in less than half
- No erosion-related tube leaks in at least *seven months*, relative to history of every 2-8 weeks
- Improved the operators' effectiveness:
  - Before, operators had to manually manage sootblowing
  - Now they operators spend very little time managing sootblowing
  - *“We just put in SootOpt and let it fly”*—Ameren Meramec Engineer

# Meramec Unit 4 Results

# Unit 4 Sootblower Actuation Counts (Average Daily Runs Pre & Post SootOpt)

Blower	Pre SootOpt	Post SootOpt	% Change
LL 1L	6.4	4.6	-28.6
LL 2L	3.6	3.6	0.9
LL 3L	5.0	3.4	-32.4
LL 4L	5.7	4.4	-22.3
LL 5L	6.0	5.4	-10.7
LL 6L	3.3	3.5	5.6
LL 6AL	6.4	5.9	- 8.5
LL 7L	3.4	3.6	6.4
LL 8L	6.1	4.3	-29.6
LL 9L	5.7	4.6	-19.6
LL 10L	5.7	4.6	-19.9
LL 11L	6.3	5.4	-14.0
LL 12L	6.2	4.6	-26.0
LL 13L	6.1	5.4	-12.0
LL 14L	6.1	4.6	-24.8
LL 15L	6.6	7.8	17.1*
LL 16L	6.6	5.1	-22.6
LL 17L	6.4	7.9	22.6*
LL 18L	6.3	5.2	-17.6
LL AH1	2.9	4.6	55.0**
LL 1R	6.3	5.0	-20.9
LL 2R	3.4	2.4	-31.4
LL 3R	3.4	2.3	-33.7
LL 4R	6.3	3.2	<u>-48.3</u>
			-12.7


Negative % Change =  
Decrease in number of  
sootblower actuations

Positive % Change =  
Increase in number of  
sootblower actuations

\* Note: the actuation  
frequency of long  
lances 15 and 17  
were increased per  
feedback from plant  
operations personnel

\*\* Air preheater  
blower starts  
increased to respond  
to higher air  
preheater differential  
pressure since air  
preheater sootblower  
outage event





# U4 Air Preheater Gas Inlet Temperatures



# Unit 4 – Opacity

- Opacity levels with SootOpt were lower by over 50%
- Opacity excursions (> 20%) dropped notably with SootOpt

Opacity Frequency Distribution





# Unit 4 SootOpt Results Summary

- Total blower starts reduced by more than 12% -- higher reductions for many of the blowers
- Reheat steam temperature variations minimized
- Reduced delta between east and west side reheat steam temperatures
  - Deviation between east and west reheat temperature narrowed from an average of 25.4 degF without SootOpt to an average of 8 degF with SootOpt
- Air pre-heater gas inlet temperatures lowered by an average of 18.3 degF and 4.9 degF for the A and B sides respectively
- Reduced NOx levels – ranging from +0.5% to -2.6% depending on load
- Opacity levels lowered by more than 50%
- Utilization remains high -- enabled more than 95% of time

# Comprehensive Boiler Optimization

- Interrelated boiler variables must be continually managed
  - Combustion quality, fuel & air mixing, gas & steam temps, fouling, tube erosion, & emissions
  - Fluctuating constraints & changing objectives add complexity
- Independently optimizing combustion & sootblowing delivers value, but leaves benefits on the table





# Combined Impact on NOx

Comb OFF, Soot OFF



Comb ON, Soot ON

Comb OFF, Soot ON

Comb ON, Soot OFF

X-Axis: U3 GROSS GEN

X-Axis: U3 GROSS GEN



Significantly improved NOx reduction (0.085 range)

# Combined Impact on Unit Heat Rate

Standard ON/OFF

Scatter Plots (30days)

Comb OFF, Soot OFF



Comb ON, Soot ON

Comb OFF, Soot ON

Comb ON, Soot OFF

X-Axis: U3 GROSS GEN

X-Axis: U3 GROSS GEN



Combined solution provided HR benefit  
while also lowering NO<sub>x</sub>

# Breadth, Depth, and Flexibility

- Optimization can provide benefits in all these areas:
  - Heat Rate – NO<sub>x</sub> – MW – Commercial Availability
  - CO<sub>2</sub> – Opacity – SO<sub>2</sub> – Equipment Reliability
  - LOI – Particulates – Hg – Steam Temps
  - CO – Ramp Rates – NH<sub>3</sub> usage – Attemperation Sprays
  - Aux Power – Operational Consistency – Slagging & Fouling
- Maximum benefits can only be achieved with an integrated platform approach
- Platform designed for fleet-wide application, where benefits can be realized in manner best suited to differing organizations
  - Plant use
  - Centralized “war room”
  - Tailored service offering
  - Any combination of these

# Contact Information

- For more information please contact:

**Ray Johnson**

Email: [johnson@neuco.net](mailto:johnson@neuco.net)

Phone: (601) 267-3573